

**TORONTO
HYDRO ELECTRIC SYSTEM LIMITED**

EB-2012-0064

Ontario Energy Board

IN THE MATTER OF the *Ontario Energy Board Act, 1998*,
S.O. 1998, c. 15, (Schedule B);

AND IN THE MATTER OF an application by **TORONTO
HYDRO ELECTRIC SYSTEM LIMITED** for an order
approving just and reasonable rates and other charges
for electricity distribution to be effective
June 1, 2012, May 1, 2013 and May 1, 2014.

**AMPCO
CROSS-EXAMINATION COMPENDIUM
PANEL 2B**

Summary of Capital Program

| Schedule Number | Projects | Segments | Cost Estimates (\$M) | | | |
|-----------------|--|--|----------------------|---------------|---------------|-----------------|
| | | | 2012 | 2013 | 2014 | Total |
| B1 | | Underground Infrastructure | 46.94 | 53.02 | 74.92 | 174.88 |
| B2 | Underground Infrastructure and Cable | Paper Insulated Lead Covered Cable - Piece Outs and Leakers | 17.32 | 5.18 | 1.47 | 23.97 |
| B3 | | Handwell Replacement | 12.01 | 14.45 | 7.17 | 33.63 |
| B4 | | Overhead Infrastructure | 29.43 | 53.02 | 20.11 | 102.56 |
| B5 | | Box Construction | 10.20 | 20.54 | 27.76 | 58.50 |
| B6 | Overhead Infrastructure and Equipment | Rear Lot Construction | 34.37 | 20.73 | 11.03 | 66.13 |
| B7 | | Polymer SMD-20 Switches | 3.06 | 2.95 | 2.94 | 8.94 |
| B8 | | SCADA-Mate R1 Switches | 2.86 | 2.80 | 2.69 | 8.36 |
| B9 | | Network Vault & Roofs | 13.57 | 12.31 | 15.57 | 41.45 |
| B10 | Network Infrastructure and Equipment | Fibertop Network Units | 8.59 | 8.78 | 9.36 | 26.73 |
| B11 | | Automatic Transfer Switches (ATS) & Reverse Power Breakers (RPB) | 3.27 | 3.30 | 3.23 | 9.80 |
| B12 | | Stations Power Transformers | 1.30 | 2.56 | 0.87 | 4.73 |
| B13.1 & 13.2 | | Stations Switchgear - Municipal and Transformer Stations | 19.35 | 18.76 | 20.31 | 58.41 |
| B14 | Station Infrastructure and Equipment | Stations Circuit Breakers | 1.37 | 1.08 | 1.38 | 3.83 |
| B15 | | Stations Control & Communication Systems | 1.15 | 2.15 | 1.34 | 4.64 |
| B16 | | Downtown Station Load Transfers | 1.75 | 1.59 | 3.59 | 6.93 |
| B17 | Bremner TS | Bremner Transformer Station | 31.73 | 69.38 | 23.02 | 124.13 |
| B18 | Hydro One Capital Contributions | Hydro One Capital Contributions | 25.28 | 52.12 | 36.00 | 113.40 |
| B19 | Feeder Automation | Feeder Automation | 7.82 | 16.30 | 7.38 | 31.50 |
| B20 | Metering | Metering | 5.62 | 7.21 | 10.03 | 22.85 |
| B21 | Plant Relocations | Externally-Initiated Plant Relocations and Expansions | 24.27 | 17.67 | 13.34 | 55.28 |
| B22 | Grid Solutions | Grid Solutions | 2.40 | 3.60 | 0.96 | 6.95 |
| C1 | Operations Portfolio Capital | | 121.70 | 121.60 | 121.60 | 364.90 |
| C2 | Information Technology Capital | | 15.00 | 15.00 | 15.00 | 45.00 |
| C3 | Fleet Capital | | 2.00 | 2.00 | 2.00 | 6.00 |
| C4 | Buildings and Facilities Capital | | 5.00 | 5.00 | 5.00 | 15.00 |
| | Allowance for Funds Used During Construction | | 1.40 | 1.40 | 1.40 | 4.20 |
| Total | | | 448.74 | 534.48 | 439.97 | 1,422.70 |

Summary of Capital Program

| Schedule Number | Projects | Segments | Cost Estimates (\$M) | | | | |
|-----------------|--|--|----------------------|---------------|---------------|----------------------------|---------|
| | | | 2012 Forecast * | 2013 Budget | 2014 | Total for 2012 and 2013 ** | |
| B1 | | Underground Infrastructure | 28.75 | 58.94 | 74.92 | 87.70 | /UF, US |
| B2 | Underground Infrastructure and Cable | Paper Insulated Lead Covered Cable - Piece Outs and Leakers | 0.08 | 5.42 | 1.47 | 5.50 | /UF, US |
| B3 | | Handwell Replacement | 13.65 | 16.65 | 7.17 | 30.30 | /UF, US |
| B4 | | Overhead Infrastructure | 9.07 | 55.88 | 20.11 | 64.95 | /UF, US |
| B5 | | Box Construction | 0.58 | 23.04 | 27.76 | 23.62 | /UF, US |
| B6 | Overhead Infrastructure and Equipment | Rear Lot Construction | 16.36 | 29.43 | 11.03 | 45.78 | /UF, US |
| B7 | | Polymer SMD-20 Switches | - | 1.53 | 2.94 | 1.53 | /UF, US |
| B8 | | SCADA-Mate R1 Switches | - | 1.43 | 2.69 | 1.43 | /UF, US |
| B9 | | Network Vault & Roofs | 2.84 | 18.76 | 15.57 | 21.60 | /UF, US |
| B10 | Network Infrastructure and Equipment | Fibertop Network Units | 1.48 | 7.71 | 9.36 | 9.19 | /UF, US |
| B11 | | Automatic Transfer Switches (ATS) & Reverse Power Breakers (RPB) | - | 3.26 | 3.23 | 3.26 | /UF, US |
| B12 | | Stations Power Transformers | 0.38 | 3.48 | 0.87 | 3.86 | /UF, US |
| B13.1 & 13.2 | | Stations Switchgear - Municipal and Transformer Stations | 1.73 | 21.81 | 20.31 | 23.54 | /UF, US |
| B14 | Station Infrastructure and Equipment | Stations Circuit Breakers | 0.76 | 0.55 | 1.38 | 1.31 | /UF, US |
| B15 | | Stations Control & Communication Systems | 0.14 | 1.00 | 1.34 | 1.14 | /UF, US |
| B16 | | Downtown Station Load Transfers | 0.68 | 2.14 | 3.59 | 2.82 | /UF, US |
| B17 | Bremner TS | Bremner Transformer Station | 8.50 | 81.00 | 23.02 | 89.50 | /UF, US |
| B18 | Hydro One Capital Contributions | Hydro One Capital Contributions | 22.98 | 48.12 | 36.00 | 71.10 | /UF, US |
| B19 | Feeder Automation | Feeder Automation | 2.30 | 20.66 | 7.38 | 22.97 | /UF, US |
| B20 | Metering | Metering | 4.74 | 8.40 | 10.03 | 13.14 | /UF, US |
| B21 | Plant Relocations | Externally-Initiated Plant Relocations and Expansions | 10.16 | 24.84 | 13.34 | 35.00 | /UF, US |
| B22 | Grid Solutions | Grid Solutions | - | - | 0.96 | - | /UF, US |
| C1 | Operations Portfolio Capital | Operations Portfolio Capital | 120.51 | 121.63 | 121.60 | 242.14 | /UF, US |
| C2 | Information Technology Capital | Information Technology Capital | 22.00 | 15.00 | 15.00 | 37.00 | /UF, US |
| C3 | Fleet Capital | Fleet Capital | 0.80 | 2.00 | 2.00 | 2.80 | /UF, US |
| C4 | Buildings and Facilities Capital | Buildings and Facilities Capital | 5.00 | 5.00 | 5.00 | 10.00 | /UF, US |
| | Allowance for Funds Used During Construction | Allowance for Funds Used During Construction | 1.20 | 1.40 | 1.40 | 2.60 | /UF, US |
| Total | | | 274.68 | 579.09 | 439.47 | 853.78 | /UF, US |

* The sum of actual spending to August 31, 2012 and estimated spending to year end.

** THESL has asked the OEB to consider the work programs identified for 2012 and 2013 together, and to defer consideration of the work program for 2014 to a later date.

ICM Project | Fibertop Network Units Segment

1 Network Units replacement over the course of the next three years. The segment cost schedule
 2 is shown below in Table-1. Complete job listings are shown in Appendix A.

3

4 **Table-1: Project Budget Details**

| Project Title | Project Year | Estimated Cost (\$M) | |
|--------------------------------|------------------------|----------------------|----------|
| Fibertop Changeouts | 2012 | \$1.69 | /UF, /US |
| Fibertop Changeouts | 2013 | \$7.44 | /UF, /US |
| Fibertop Changeouts | 2014 | \$9.36 | |
| | Total 2013/2014 | \$9.13 | /UF, /US |

5 Figure 1 below shows the locations of the Fibertop Network Units that are scheduled to be
 6 replaced. Most are located in downtown Toronto and parts of East York, particularly along the
 7 Yonge Street corridor where dense commercial load requires reliable distribution equipment.

8

9 In the recent past THESL has replaced 40 to 60 Network units annually due to corrosion. Leaking
 10 transformers and fibertops have made up a significant portion of these replacements (40% in
 11 2009 and 60% in 2010). The proposed segment would be an increase to the existing
 12 replacement strategy as more units would be replaced annually.

**RESPONSES TO ASSOCIATION OF MAJOR POWER
CONSUMERS IN ONTARIO INTERROGATORIES ON ISSUE 2.2**

1 **INTERROGATORY 15:**

2 **Reference(s): Tab 4, Schedule B10, Page 1**

3

4 The assets selected for replacement have been identified as possessing the highest
5 probability of failure, based on inspection of all THESL units.

6


7 **a) Please confirm this finding is reflected in THESL’s Asset Condition Assessment.**

8

9 **RESPONSE:**

10 a) The Asset Condition for the network protector class can be found in the following
11 graph. The graph indicates that the majority of network protectors are in good and
12 very good condition. As discussed in the evidence (Tab 4, Schedule B10, pages 6 to
13 14), however, Fibertop protectors, particularly those outdoors below public
14 thoroughfares, have a much higher probability of catastrophic failure because of
15 deficiencies inherent in their design.

RESPONSES TO ASSOCIATION OF MAJOR POWER CONSUMERS IN ONTARIO INTERROGATORIES ON ISSUE 2.2




1 The units identified as possessing the highest probability of catastrophic failure are
 2 Fibertop Network Units that are located in public pedestrian walkways under the
 3 sidewalk. These outdoor locations are typically affected in the winter with de-icing
 4 salts that contaminate network equipment. Fibertop protectors are particularly
 5 susceptible to this contamination because of their design. Therefore they are viewed
 6 as having the highest probability of failure.

7
 8 Recently there has been an increase in maintenance for these Fibertop Units to
 9 mitigate the possibility of a catastrophic failure. Annual cleaning for all Fibertop
 10 Units is preformed in an attempt to remove contaminants that may cause vault fires.
 11 Although the increased cleaning has helped improved the overall condition of the
 12 Fibertop Network Units, the underlying flaws still exist.

RESPONSES TO ASSOCIATION OF MAJOR POWER CONSUMERS IN ONTARIO INTERROGATORIES ON ISSUE 2.2

1 The following graph shows that the population of Fibertop Network Units is generally
2 over 40 years old. As stated in the Reference (Tab 4, Schedule B10, page 2) the
3 useful life of these assets is 20 years. Therefore, although the ACA shows a good
4 condition asset, THESL has determined that these assets require replacement because
5 of their age and the risk and nature of their failure.



6 **b) Please provide a breakdown of the 187 Fibertop Network Units between poor**
7 **and very poor.**

**RESPONSES TO ASSOCIATION OF MAJOR POWER
CONSUMERS IN ONTARIO INTERROGATORIES ON ISSUE 2.2**

1 **RESPONSE:**

- 2 b) There are no Fibertop network units in the poor and very poor ACA category. As
- 3 described in the response to part a) above, although the ACA shows a good condition
- 4 asset, THESL has determined that these assets require replacement because of their
- 5 age and the risk and nature of their failure.

ICM Project | ATS and RPB Segment

1 **I EXECUTIVE SUMMARY**

2

3 **1. Project Description**

4 Automatic Transfer Switches (ATS) automatically switch a customer to a designated standby
 5 feeder in the event the normal primary feeder fails. Reverse Power Breakers (RPB)
 6 automatically open primary feeder supplies to customers in the event of feeder outages to
 7 prevent dangerous backfeed conditions. ATS and RPB assets are generally used to supply
 8 medium size customers that require a reliable supply, such as schools, supermarkets, seniors'
 9 homes, and other mid- sized buildings (See Section II, 1).

10

11 Both ATS and RPB assets have degraded rapidly in 2010 and 2011. THESL's Asset Condition
 12 Assessment (ACA) results indicate that approximately 30 ATS assets will need to be replaced
 13 over the next three years (See Section III, 1 and Appendix 1). In addition, based on physical
 14 inspection data, a further six RPB assets have been identified as requiring immediate
 15 replacement. The proposed ATS and RPB Segment will replace these assets with Stand Alone
 16 Network Protectors or Standard Network Equipment at a total cost of \$3.25M over 2012 and /UF, /US
 17 2013.

18

19 **Table 1: ATS and RPB Segment Capital Cost**

| Description | Year | Design Estimate (\$M) | Estimated Total Cost (\$M) |
|-------------------------------------|------|-----------------------|----------------------------|
| Replace 10 ATS Locations | 2013 | \$2.54 | \$2.54 |
| Replace 10 ATS Locations | 2014 | \$2.52 | |
| Replace 2 RPB Locations | 2013 | \$0.71 | \$0.71 |
| Replace 2 RPB Locations | 2014 | \$0.71 | |
| Total 2012-2013: | | | \$3.25 |

} /UF, /US

/UF

ICM Project | ATS and RPB Segment

1 **Table 2: ATS Replacement Jobs**

| Job Estimate Number | Job Title | Job Year | Cost Estimate (\$M) | |
|---------------------|---|-----------------|---------------------|----------|
| 19381 | D9012 – Near 654 Castlefield, Toronto | 2013 | \$0.32 | /US |
| 23252 | D3031 - 2108 Queen St East, Toronto | 2013 | \$0.21 | |
| 24544 | 4862 - 77 Ryerson Ave, Toronto | 2013 | \$0.14 | |
| 24546 | 4023 - Near 142 Pears Ave, Toronto | 2013 | \$0.36 | /UF, /US |
| 24548 | D9010 - 205 Richmond St W, Toronto | 2013 | \$0.14 | /US |
| 24549 | D3022 – 75 Dowling Ave, Toronto | 2013 | \$0.14 | |
| 24550 | 4064 – 295 College St, Toronto | 2013 | \$0.37 | |
| 24634 | D3002 – 70 Elmsthorpe, Toronto | 2013 | \$0.14 | |
| 24634 | D9013 - 2727 Dundas W, Toronto | 2013 | \$0.36 | |
| 24634 | 4063 - 645 Adelaide St W, Toronto | 2013 | \$0.36 | |
| 24952 | 4027 – 14 Spadina Road | 2013 | \$0.32 | |
| 24952 | 4046 – Near 130 EGLINTON, Toronto | 2013 | \$0.32 | |
| 24952 | 4129 – Heath Street East | 2013 | \$0.32 | |
| 24952 | 4158 – Duncan Ave | 2013 | \$0.32 | |
| 24953 | 4817 – ADJ. to 330 GERRARD | 2014 | \$0.36 | /US |
| 24953 | D9007 – 658 to 668 Danforth Ave, Toronto | 2014 | \$0.14 | |
| 24953 | D3014 – 2001 Bloor St W, Toronto | 2014 | \$0.14 | |
| 24953 | 4157 – 175 Elm, Toronto | 2014 | \$0.36 | |
| 24953 | D3041 – 1141 Bloor St W, Toronto | 2014 | \$0.14 | |
| 24953 | D3003 – 75 Eglinton Ave W, Toronto | 2014 | \$0.14 | |
| 24953 | 4118 – 197 Wellesley St E, Toronto | 2014 | \$0.36 | |
| 24953 | 4763 – 700 Ontario St, Toronto | 2014 | \$0.14 | |
| 24953 | 4121 – 36 Earl, Toronto | 2014 | \$0.36 | |
| 24953 | 4861 – 165 Grange Ave, Toronto | 2014 | \$0.36 | |

10

ICM Project | ATS and RPB Segment

/c

1 **Table 3: RPB Replacement Jobs**

| Job Estimate Number | Job Title | Job Year | Cost Estimate (\$M) |
|----------------------------|--|-----------------|----------------------------|
| 24905 | 4515 - 25 Lascelles Blvd, Toronto | 2013 | \$0.35 |
| 24905 | D3039 – 186 Cowan, Toronto | 2013 | \$0.35 |
| 24955 | 4175 – 160 John St, Toronto | 2014 | \$0.35 |
| 24955 | 4669 – 200 Balliol, Toronto | 2014 | \$0.35 |

} /us

ICM Project | Municipal Substation Switchgear Replacement Segment

1 **Table 1: Job Cost Estimate**

| Job Estimate Number | Job Title | Year Installed | Job Year | Cost Estimate (\$M) |
|---------------------|---|-----------------|-----------------|---------------------|
| 20427 | S12320 Leslie MS Switchgear Replacement | 1978 | 2013 | 4.08 |
| 20427 | S12320 Leslie MS Switchgear Replacement (Continuation | 1978 | 2013 | 1.04 |
| 20560 | S11032 Lawrence Golf Switchgear Replacement | 1957 | 2012 | 0.82 |
| 20561 | S11031 Brian Elinor MS Replace switchgear | 1954 | 2012 | 0.83 |
| 22620 | S11642 York MS Replace Switchgear | 1954 | 2012 | 1.39 |
| 20544 | S11040 Brimley Bernadine MS Replace Switchgear | 1959 | 2012 | 1.09 |
| 20750 | S12416 Porterfield MS Replace Switchgear | 1956 | 2013 | 1.23 |
| 21338 | S13090 Greencedar Lawrence MS Replace Switchgear | 1960 | 2013 | 0.22 |
| 21581 | S13126 Neilson Dr MS Replace Switchgear | 1954 | 2013 | 0.30 |
| 21339 | S14044 Midland Lawrence MS Replace switchgear | 1960 | 2013 | 0.24 |
| 21339 | S14044 Midland Lawrence MS Replace switchgear (Continuation) | 1960 | 2014 | 0.62 |
| 20779 | S14048 Pharmacy CPR MS Replace switchgear | 1961 | 2014 | 0.94 |
| 22804 | S14068 Islington MS Replace Switchgear | 1955 | 2014 | 1.51 |

/us

/us

/UF

/UF

ICM Project | Municipal Substation Switchgear Replacement Segment

| Job Estimate Number | Job Title | Year Installed | Job Year | Cost Estimate (\$M) |
|--|---|----------------|----------|---------------------|
| 22805 | S14070 Thornton MS Replace Switchgear (pre-work) | 1955 | 2013 | 0.11 |
| 22805 | S14070 Thornton MS Replace Switchgear (pre-work) | | 2014 | 0.86 |
| Jobs Total 2012-2013 | | | | 11.35 |
| Reconciliation for budget changes < \$100,000 and rounding | | | | \$0.05 |
| TOTAL | | | | \$11.40 |

/US

} /UF, US

2. Why the Project is Needed Now

All the Municipal Substation switchgear proposed to be replaced are over 50 years (with the exception of Leslie MS) and have reached the end of their useful life. The switchgear employ obsolete technology, such as non arc-resistance design, oil circuit breakers and mechanical relays. Non arc-resistant switchgear does not have the ability to channel the energy released during an internal arc fault in ways that minimize the potential injury to personnel and damage to equipment in the surrounding area, including damaging the entire substation.

THESL experienced two substation fires in recent years due to faults in substation equipment that were at their end of service life; one was in 2007 at Lesmil MS in North York area and the second one was in 2009 at station J, in East York area. Both substations were over 50 years old and the fire was attributed to faults in the substation switchgears. Switchgear which is over its useful design life (50 years) can fail catastrophically at any time. Lesmil MS was severely damaged as a result of the fire created due to the fault and Station J was burned down as a result of the fire created by the arc fault in the switchgear and there was no substation equipment left to repair.

The load of both of the above substations was temporarily transferred to their respective adjacent substations. Lesmil MS was ultimately converted to 27.6kV because the station was lightly loaded and replacing or repairing the aging switchgear was not cost effective. Station J MS was also lightly loaded as a result of previous load conversion so converting substation was more cost effective than replacing and/or repairing the aging switchgear. Load conversion also

ICM Project | Municipal Substation Switchgear Replacement Segment

1 **Table 1: Summary of values used in the determination of Avoided Estimated Risk Cost**

| Business Case Element | Estimated Cost (in Millions) |
|--|------------------------------|
| Present Value of Project Net Cost in 2015 (PV(PROJECT _{NET_COST} (2015))) | \$2.810 |
| Project Net Cost in 2012 (PROJECT _{NET_COST} (2012)) | \$2.155 |
| Avoided Estimated Risk Cost = (PV(PROJECT_{NET_COST}(2015)) – PROJECT_{NET_COST}(2012)) | \$ 0.655 |

/c

/c

2 When this avoided estimated risk cost is calculated as a positive value, it means that estimated
3 risk costs for the job assets in 2015 will exceed the estimated risks that exist today. By
4 performing the work immediately as opposed to waiting until 2015, THESL can eliminate these
5 estimated risks. Therefore, these avoided estimated risk costs represent the benefits of job
6 execution.

ICM Project | Municipal Substation Switchgear Replacement Segment

1 **Table 1: Summary of values used in the determination of Avoided Estimated Risk Cost**

| Business Case Element | Estimated Cost (in Millions) |
|---|-------------------------------------|
| Present Value of Project Net Cost in 2015 ($PV(PROJECT_{NET_COST}(2015))$) | \$2.355 |
| Project Net Cost in 2012 ($PROJECT_{NET_COST}(2012)$) | \$2.155 |
| Avoided Estimated Risk Cost = $(PV(PROJECT_{NET_COST}(2015)) - PROJECT_{NET_COST}(2012))$ | \$ 0.200 |

2 When this avoided estimated risk cost is calculated as a positive value, it means that estimated
 3 risk costs for the job assets in 2015 will exceed the estimated risks that exist today. By
 4 performing the work immediately as opposed to waiting until 2015, THESL can eliminate these
 5 estimated risks. Therefore, these avoided estimated risk costs represent the benefits of job
 6 execution.

ICM Project | Stations Switchgear – Transformer Stations Segment

1 | **EXECUTIVE SUMMARY**

2

3 | **1. Project Description**

4 Switchgear operating at 13.8kV in many downtown Transformer Stations (TS) are past the end
5 of their useful lives and rely on obsolete technology such as brick and mortar enclosures, non
6 arc-resistant designs with air blast or air magnetic circuit breakers and mechanical relays and are
7 in poor condition (See Section II, 3). The existing non arc-resistant switchgear does not channel
8 the energy released during an internal arc fault to minimize potential injury to personnel and
9 minimize damage to surrounding equipment. As a result, this switchgear can cause damage that
10 impacts the entire station, interrupting service to thousands of customers. This equipment has
11 been kept in service via increased maintenance, custom fabrication and harvesting parts from
12 spares. The asset condition continues to deteriorate and safety concerns are increasing.

13

14 Switchgear requiring replacement in 2012, and 2013, and 2014 include the A7-8T switchgear at
15 Strachan TS, A6-7E switchgear at Carlaw TS, A3-4W and A5-6W switchgear at Wiltshire TS, A5-
16 6WR switchgear at Windsor TS and A5-6DX at Duplex TS. All but one of these are more than 55
17 years old. The total cost of this segment is approximately \$12.14 million for the jobs shown in

/UF, US

18 Table 1

19

20 **Table 1: Job Costs**

| Estimate Number | Job Title | Year Installed | Customer Load Served (MVA) | Job Year | Cost Estimate (\$M) |
|-----------------|---|----------------|----------------------------|----------|---------------------|
| 18591 | Strachan TS A7-8 switchgear replacement preparation | 1956 | 34 | 2012 | 0.34 |
| 25425 | Strachan TS A7-8 switchgear replacement | 1956 | 34 | 2013 | 3.41 |

/UF

ICM Project | Stations Switchgear – Transformer Stations Segment

| Estimate Number | Job Title | Year Installed | Customer Load Served (MVA) | Job Year | Cost Estimate (\$M) | |
|------------------------|---|----------------|----------------------------|----------|---------------------|----------------|
| 24972 | S14406 Strachan TS Load Transfer from A7-8T to A11-12T Switchgear | 1956 | 34 | 2014 | 0.30 | |
| 22025 | Carlaw TS A6-7E switchgear replacement | 1968 | 26 | 2013 | 1.45 | /UF, US |
| 20877 | Wiltshire TS A3-4W switchgear replacement | 1954 | 20 | 2012 | 6.71 | /UF, US |
| 22719 | Wiltshire TS A5-6W switchgear replacement | 1954 | 22 | 2014 | 7.67 | |
| 21735 | Windsor TS A5-6WR switchgear replacement | 1956 | 56 | 2014 | 8.41 | |
| 20492 | Duplex TS A5-6DX switchgear replacement | 1954 | 42 | 2013 | 0.23 | /UF |
| 2012-2013 Total | | | | | 12.14 | /UF, US |

1 These switchgear were selected for replacement based on the following considerations:

- 2 • Obsolescence (brick structures, non-arc resistant design, obsolete breakers)
- 3 • Age
- 4 • Condition
- 5 • Space available for transition switchgear, and
- 6 • Station egress for cabling

7

8 All the switchgear listed are to be replaced with 3,000A air-insulated, arc-resistant type C

9 switchgear with double-bus, double-breaker or breaker-and-half configuration except Duplex

ICM Project | Stations Switchgear – Transformer Stations Segment

1 **Table 1: Summary of values used in the determination of Avoided Estimated Risk Cost**

| Business Case Element | Estimated Cost (in Millions) |
|---|-------------------------------------|
| Present Value of Project Net Cost in 2015 (PV(PROJECT _{NET_COST} (2015))) | \$ 42.037 |
| Project Net Cost in 2012 (PROJECT _{NET_COST} (2012)) | \$ 0.0298 |
| Avoided Estimated Risk Cost = (PV(PROJECT_{NET_COST}(2015))) – PROJECT_{NET_COST}(2012)) | \$ 42.007 |

/c

/c

2 When this avoided estimated risk cost is calculated as a positive value, it means that estimated
 3 risk costs for the job assets in 2015 will exceed the estimated risks that exist today. By
 4 performing the work immediately as opposed to waiting until 2015, we can eliminate these
 5 estimated risks. Therefore, these avoided estimated risk costs represent the benefits of job
 6 execution.

ICM Project | Stations Switchgear – Transformer Stations Segment

1 **Table 1: Summary of values used in the determination of Avoided Estimated Risk Cost**

| Business Case Element | Estimated Cost (in Millions) |
|--|------------------------------|
| Present Value of Project Net Cost in 2015 (PV(PROJECT _{NET_COST} (2015))) | \$ 35.235 |
| Project Net Cost in 2012 (PROJECT _{NET_COST} (2012)) | \$ 0.0298 |
| Avoided Estimated Risk Cost = (PV(PROJECT_{NET_COST}(2015)) – PROJECT_{NET_COST}(2012)) | \$ 35.205 |

- 2 When this avoided estimated risk cost is calculated as a positive value, it means that estimated
 3 risk costs for the job assets in 2015 will exceed the estimated risks that exist today. By
 4 performing the work immediately as opposed to waiting until 2015, we can eliminate these
 5 estimated risks. Therefore, these avoided estimated risk costs represent the benefits of job
 6 execution.

ICM Project | Stations Circuit Breakers Segment

1 **I EXECUTIVE SUMMARY**

2

3 **1. Description**

4 Station circuit breaker work proposed for 2012 consists of replacing 9 oil circuit breakers /UF, US
 5 (27.6kV) mounted outdoors and associated control boxes with vacuum circuit breakers at five
 6 Terminal Stations (TS). The estimated cost for the work is \$1.38 M as shown in Table 1: /UF, US

7

8 **Table 1: Job Cost Estimates**

| Job Estimate Number | Job Title | Job Year | Cost Estimate (\$M) |
|--|---|----------|---------------------|
| 17662 | S11118 Finch TS: Replace KSO CB (55M27) | 2012 | \$0.07 |
| 17669 | S11121 Finch TS: Replace KSO CB (55M28) | 2012 | \$0.07 |
| 17654 | S11130 Bathurst TS: Replace KSO CB (85M24) | 2012 | \$0.07 |
| 18403 | S12001 Leslie TS: Replace KSO OCB (51M4 and 51M6) | 2012 | \$0.39 |
| 18233 | S12036 Fairchild TS: Replace KSO CB (80M1) | 2012 | \$0.19 |
| 18237 | S12037 Fairchild TS: Replace KSO CB (80M3) | 2012 | \$0.19 |
| 18262 | S12043 Fairchild TS: Replace KSO CB (80M5) | 2012 | \$0.20 |
| 18263 | S12044 Fairchild TS: Replace KSO CB (80M9) | 2012 | \$0.20 |
| 22693 | S14052 Finch TS: Replace KSO CB (55M24) | 2014 | \$0.19 |
| 22694 | S14054 Finch TS: Replace KSO CB (55M25 and 55M8) | 2014 | \$0.41 |
| 22695 | S14055 Bathurst TS: Replace 85M1 KSO CB | 2014 | \$0.19 |
| 22698 | S14056 Bathurst TS: Replace 85M4 KSO CB | 2014 | \$0.20 |
| 22699 | S14057 Bathurst TS: Replace 85M2 KSO CB | 2014 | \$0.19 |
| 22700 | S14059 Bathurst TS: Replace 85M25 KSO CB | 2014 | \$0.19 |
| Jobs Total 2012-2013: | | | \$1.38 |
| Reconciliation for budget changes < \$100,000 and rounding | | | (\$0.07) |
| TOTAL | | | \$1.31 |

} /UF

ICM Project | Stations Circuit Breakers Segment

| Job Estimate Number | Job Title | Job Year | Cost Estimate (\$M) |
|----------------------------|--|-----------------|----------------------------|
| 22700 | S14059 Bathurst TS: Replace 85M25 KSO CB | 2014 | \$0.19 |
| | | Total: | \$3.83 |

1 **2. Why the Project is Needed Now**

2 Circuit breakers are automated switching devices that can carry and interrupt electrical currents
3 under normal and abnormal conditions. Distribution circuit breakers at THESL are commonly
4 used at transmission or distribution stations for switching 27.6, 13.8 or 4.16 kV feeders. Circuit
5 breakers operate infrequently. When an electrical fault occurs however, it is important that
6 breakers operate reliably and with adequate speed to minimize damage. Circuit breaker designs
7 have evolved over the years and many different types are currently in use. Commonly used
8 circuit breaker types include oil circuit breakers (OCB), vacuum breakers, magnetic air circuit
9 breakers and SF₆ circuit breakers. Circuit breakers may be mounted indoors or outdoors.

10
11 For OCBs, the interruption of load and fault currents involves the reaction of high pressure with
12 large volumes of hydrogen gas and other arc decomposition products. Thus, both contacts and
13 oil degrade more rapidly in OCBs than they do in either SF₆ or vacuum designs, especially when
14 the OCB undergoes frequent switching operations. Generally, four to eight interruptions with
15 contact erosion and oil carbonization will lead to the need for maintenance, including oil
16 filtration. Oil breakers can also experience re-strike when switching low load or line charging
17 currents with high recovery voltage values. Sometimes this can lead to catastrophic breaker
18 failures. Outdoor circuit breakers may experience adverse environmental conditions that
19 influence their rate and severity of degradation. For outdoor-mounted circuit breakers, the
20 following represent additional degradation factors:

- 21 • Corrosion;
- 22 • Effects of moisture;
- 23 • Bushing/insulator deterioration; and
- 24 • Mechanical.

25

ICM Project | Stations Control and Communication Segment

1 **I EXECUTIVE SUMMARY**

2
 3 **1. Description**

4 THESL relies on an extensive Supervisory Control and Data Acquisition System (SCADA) for
 5 control and monitoring of distribution equipment. THESL uses various types of communication
 6 (SONET fibre optics, copper lines, radio system and leased telephone lines) to convey
 7 information between station assets and distribution system assets. This communication system
 8 is vital for operating the system and re-routing electrical supply during planned outages and
 9 emergency situations.

10
 11 Station control and communication work proposed for 2012 and 2013 ~~and 2014~~ consists of /US
 12 improving SONET communication redundancy, upgrading SONET system communication
 13 capacity and installing SCADA RTUs. The estimated cost for the work is \$1.13M, which consists /UF, US
 14 of \$0.51M for improving SONET system and \$0.62M for replacing / installing SCADA RTUs, as /UF, US
 15 presented in Table 1 and Table 2 below. Jobs were selected for inclusion in this segment based
 16 upon need and execution capacity, and in coordination with other projects.

17
 18 **Table 1: Job Cost Estimates for SONET System Redundancy/Upgrading**

| Job Title | Job Year | Cost Estimate (\$M) |
|--|----------|---------------------|
| Improve SONET Redundancy: 14 Carlton to George and Duke MS and Esplanade TS | 2012 | \$0.23 |
| Improve SONET Redundancy: Malvern TS to Sheppard TS | 2012 | \$0.22 |
| Improve SONET Redundancy: Split Toronto SONET ring | 2013 | \$0.06 |
| Improve SONET Redundancy: Duplex TS to Fairbank TS and Warden TS to Bermondsey TS | 2014 | \$0.39 |
| Jobs Total 2012-2013: | | \$0.51 |
| Reconciliation for budget changes < \$100,000 and rounding | | \$0.01 |
| TOTAL | | \$0.52 |

/US
 /UF, US

ICM Project | Stations Control and Communication Segment

1 **Table 2: Job Cost Estimates for SCADA RTUs Replacing/Installing**

| Job Title | Job Year | Cost Estimate (\$M) |
|-------------------------------------|----------|------------------------|
| Replace 15 MOSCAD RTUs in Etobicoke | 2012 | \$0.28 |
| Install 5 MS SCADA RTUs | 2013 | \$0.34 |
| Replace 14 MOSCAD RTUs in Etobicoke | 2014 | \$0.59 |
| Install 5 MS SCADA RTUs | 2014 | \$0.36 |
| Subtotal: | | \$0.62 |

/UF

2 **2. Why This Work is Needed Now**

3 Elements of the SONET system and the radio system have developed reliability and maintenance
 4 issues that require immediate attention. This segment will address the communication issues
 5 that pose risks for THESL's continued ability to remotely monitor and control the distribution
 6 grid.

7
 8 The SONET fibre optic communication system is normally designed as a redundant ring system
 9 between station assets and the Control Centre, but some segments lack redundancy and as
 10 these fibre optic lines age or are damaged by adjacent construction, there is a risk of a complete
 11 SONET system failure (Section III, 1). Failure of the SONET system would likely result in:

- 12 • No communication to support SCADA system, which would prevent system operators
 13 from monitoring and controlling vital substation equipment. The result would be longer
 14 outages as manual, rather than remote, switching would be required.
- 15 • No information to/from the T1 data circuits used for the protection and control of HONI
 16 115kV transmission feeders that supply THESL (i.e., loss of system security and
 17 redundancy at HONI supply points and possibly longer outages from poor coordination
 18 with HONI).
- 19 • No transfer trip protection for HONI 230kV transmission in the Scarborough area,
 20 resulting in loss of system security and redundancy at HONI supply points and possibly

Ontario Energy Board **Commission de l'Énergie de l'Ontario**



ONTARIO ENERGY BOARD

Transmission System Code

June 10, 2010

10. PROTECTION SYSTEM REQUIREMENTS

10.1 TELECOMMUNICATIONS

10.1.1 A transmitter shall ensure that telecommunication facilities used for protection purposes have a level of reliability consistent with the required performance of the protection system.

10.1.2 A transmitter shall specify to all customers telecommunication channel media and protective systems.

10.1.3 A transmitter shall ensure that telecommunication circuits used for the protection and control of the transmission system are dedicated to that purpose.

10.1.4 Where each of the dual protections protecting the same system element requires communication channels, a transmitter shall ensure that the equipment and channel for each protection is separated physically and designed to minimize the risk that both protections might be disabled simultaneously by a single contingency.

- 10.1.5 A transmitter shall ensure that telecommunication systems are:
- (a) designed to prevent unwanted operations such as those caused by equipment or personnel,
 - (b) powered by the station's batteries or other sources independent from the power system, and
 - (c) monitored in order to assess equipment and channel readiness.

10.1.6 Major disturbances caused by telecommunication failures shall have annual frequency of less than 0.002 per year from the dependability aspect and less than 0.002 per year from the security aspect.

10.1.7 A transmitter shall ensure that telecommunication protection for a single transmission system circuit shall be unavailable for no more than 42 minutes per year, and for two circuits, no more than four minutes per year.

10.1.8 A transmitter shall ensure that the telecommunication false trip rate used as part of a protection system for a single transmission system circuit is no more than 0.1 false trips per year, and for two circuits, no more than 0.001 false trips per year.

10.1.9 A transmitter shall ensure that total transmission system circuit trips coincident with telecommunications failure are no more than 0.001 per year.

10.2 TEST SCHEDULE FOR RELAYING COMMUNICATION CHANNELS

10.2.1 A transmitter shall test communication channels associated with protective relaying at periodic intervals to verify that the channels are operational and that their characteristics are within specific tolerances. Testing should include signal adequacy tests and channel performance tests.

10.2.2 Signal adequacy testing for unmonitored channels shall be done at one month intervals. Signal adequacy testing for monitored channels shall be done at twelve month intervals.

10.2.3 Channel performance testing on leased communication circuits shall be conducted at 24 month intervals, while intervals for testing power line carrier equipment shall be equipment specific.

10.3 VERIFICATION AND MAINTENANCE PRACTICES

10.3.1 A transmitter shall use the maximum verification intervals established by reliability organizations and in accordance with applicable reliability standards: (a) four years for most 115kV elements, most transformer stations, and certain 230kV elements: (b) two years for all other high voltage elements. All newly commissioned protection systems shall be verified within six months of the initial in service date of the system.

10.3.2 Routine verification shall ensure with reasonable certainty that the protection systems respond correctly to fault conditions.

10.3.3 A transmitter shall use an electrically initiated simulated fault clearing check to verify new protection systems, after any wiring or component changes are made to an existing protection system, and for the routine verification of a protection system.

ICM Project | Stations Control and Communication Segment

1 longer outages from poor coordination with HONI. Operational flexibility in re-routing
2 loads also would be impacted.

3
4 The Motorola radio communication system used in the Etobicoke area (DARCOM radio system
5 and MOSCAD Terminals) has reached the end of its useful life and the equipment is obsolete. As
6 a result, when the communication between the substations in Etobicoke and the SCADA system
7 fails, control for switching restoration is unavailable, increasing the risk of longer customer
8 outages (Section III, 2). This job will ensure reliable communication by adding redundancy to the
9 SONET system and replacing the radio communication system.

10

11 The impacts of the deferral are increased risk of prolonged outages to customers served by
12 these communication systems. For example, on December 22, 2011 all control and monitoring
13 capability to 64 substations and 155 overhead Remote Terminal Units (collectively serving
14 51,937 customers) was lost for 6.5 hours. Although no outages occurred during this event, the
15 loss of SCADA control put the system at risk for longer restoration time. Without remote
16 switching capability, restoration time would move from a few minutes to a few hours, due to
17 the time it takes to send field crews to perform manual switching.

18

19 Without SCADA control and system monitoring, control personnel do not have access to the
20 following critical information to minimize outage impacts on customers:

- 21 • Alarm for circuit breaker trip (feeder outage)
- 22 • Alarm on loss of transformer voltage (transformer outage)
- 23 • Alarm on cable overloading
- 24 • Alarm on transformer pressure
- 25 • Alarm on transformer oil level
- 26 • Alarm on transformer temperature
- 27 • Alarm on battery system (loss of battery power will prevent protection relay to trip a
28 fault feeder).

29

ICM Project | Downtown Station Load Transfer Facilities Segment

1 **I EXECUTIVE SUMMARY**

2

3 **1. Project Description**

4 This segment includes the completion of the Dufferin – Bridgman feeder tie work in 2012 that
 5 was largely completed in 2011, and two new jobs for 2013 that are required to provide feeder
 6 ties between Basin and George and Duke stations; and Basin and Carlaw stations, where no such
 7 facilities present exist (See Section II).

} /US

8

9 About 21% of the \$9.4M Dufferin-Bridgman feeder ties work remains for 2012 which includes
 10 completion of electrical work, feeder transfers, some feeder capacity upgrades and
 11 commissioning (See Section II). This job plus the other two proposed jobs for 2013 combine for
 12 a total cost of \$2.8M. None of the proposed work is included in existing rates.

/UF

/UF, US

13

14 **Table 1: Proposed Feeder Ties**


| Job Number | Job Identifier | Cost Estimate (\$M) | Year of Execution |
|------------|---------------------------------|---------------------|-------------------|
| X11620 | Feeder Tie Dufferin to Bridgman | 1.94 | 2012 |
| X11424 | Feeder Tie A203BN to A240GD | 0.48 | 2013 |
| X12086 | A204BN tie to new Carlaw feeder | 0.39 | 2013 |
| X12340 | Feeder Tie A36DN to A67W | 1.78 | 2014 |
| X12342 | Feeder Tie A13DN to A35W | 1.81 | 2014 |
| | Total | 2.82 | |

/UF

/US

/UF, US

ICM Project | Downtown Station Load Transfer Facilities Segment



1 **Figure 4: Reliability Impact of Downtown Station Load Transfer Implementation**

2

3 All four major station outage events in downtown Toronto’s history occurred in the last decade.
 4 This experience indicates that the conditions in and around the 15 downtown stations are
 5 worsening as time progresses, and as a result the risks are increasing. Each of these historical
 6 events resulted from causes external to THESL that negatively impacted the station distribution
 7 equipment. Therefore, the only certain way to address such failures is to provide a back-up
 8 supply to customers.

9

10 The purpose of this segment is to provide distribution load transfer capability from one station
 11 area to another station area in order to manage the risks of partial, or complete, station
 12 outages.

13

14 An investment of \$2.8M over the period of 2012 through 2013 is expected to complete the work
 15 necessary to provide feeder-to-feeder tie capability for six feeder pairs. This work is expected to
 16 allow rapid transfer of customer loads on these feeder pairs should mitigate virtually any loss-
 17 of-supply incident occur at any of these stations.

} /UF, US

ICM Project | Feeder Automation

1 **Table 1: Business Case Evaluation of Job Areas**

| Project Location | Project Cost Allocated (\$ M) | Project Net Benefit (\$ M) | Option Benefit/Cost Ratio |
|------------------------------|-------------------------------------|-------------------------------|---------------------------------|
| Horner TS and Manby TS | \$3.40 | \$358.39 | 118.81 |
| Fairchild TS | \$2.78 | \$211.58 | 84.38 |
| Cavanagh TS and Agincourt TS | \$7.82 | \$861.34 | 111.14 |
| Scarborough East TS | \$7.66 | \$416.55 | 57.47 |

/c

2 The general scope of work for these jobs consists of two phases. The first phase involves
 3 choosing feeders that will benefit from automation. The second phase is effectively
 4 sectionalizing the feeder. Feeder selection was based on reliability, network configuration, and
 5 restoration capacity. Feeders were first selected on based on their reliability and focusing on
 6 the number of outages that occurred on the trunk. Since this project builds on the existing FA
 7 implementation, feeder selection also was based on designing a system that could connect into
 8 the existing FA implementation through interconnection with other FA feeders. Non-automated
 9 tie-points will be included where considered necessary to backfeed into established FA feeders.
 10 Each feeder selected must be able to backfeed into a section and resupply a faulted feeder.

11
 12 The number of feeders that can be addressed in an area at any one time is limited to maintain
 13 operational flexibility in the case of an outage. Power system controllers require a sufficient
 14 number of feeders available to ensure adequate flexibility to restore an area in the event of an
 15 outage. One method used to maximize the amount of FA deployment is to work in multiple
 16 areas of the system, the east, west and north areas of the city, at the same time.

17
 18 By focusing on trunk feeders and effectively deploying an FA scheme to specific areas, THESL has
 19 prepared a focused project that is expected to have a significant positive impact on SAIDI and
 20 SAIFI.

**RESPONSES TO VULNERABLE ENERGY CONSUMERS
COALITION INTERROGATORIES ON ISSUE 2.2**

1 **INTERROGATORY 90:**

2 **Reference(s):** Tab 4, Schedule B19, pages 2-3

3

4 **a) Please explain more fully why this project is considered to be non-discretionary**
5 **(i.e., must be done now).**

6

7 **RESPONSE:**

8 a) Feeder Automation is non-discretionary on the basis that it introduces a new
9 technology into the system that will significantly reduce the impact of trunk related
10 outages on targeted at risk feeders. This is explained in greater detail as demonstrated
11 on Tab 4, Schedule B19, page 3 to 4, in the section “Why the Project is Needed
12 Now”, and on Tab 4, Schedule B19, page 13 to 18, in the section “Need”.

13

14 **b) Has THESL used FA to improve the reliability in specific areas over the past 5**
15 **years (2007-2011)? If not, why not? If yes, please provide a schedule setting out**
16 **the annual spending.**

17

18 **RESPONSE:**

19 b) Yes, THESL used FA to improve the reliability in specific areas. The summary of
20 spending on FA in previous years is shown below:

| Project | Year | Location | Status | Cost |
|---------------------------------|------|------------------------------|------------------|-------------|
| Feeder Automation Pilot Project | 2010 | Fairbanks TS and Bathurst TS | Online Oct. 2010 | \$3,597,479 |

**RESPONSES TO VULNERABLE ENERGY CONSUMERS
COALITION INTERROGATORIES ON ISSUE 2.2**

1 **c) In THESL's view does a favourable Benefit/Cost ratio demonstrate that a**
2 **project is prudent or that it is non-discretionary or does it demonstrate both?**

3

4 **RESPONSE:**

5 c) By itself a positive Benefit/Cost ratio supports the prudence of a proposed project, not
6 its non-discretionary character. However, as explained in the Manager's Summary at
7 page 17, where alternative timings or stagings of a project would generate materially
8 different costs, THESL considers it non-discretionary to pursue the lower cost
9 alternative, assuming that all requirements are met.

ICM Project | Feeder Automation

1 **2. Why the Project is Needed Now**

2


3 The project needs to be constructed on the selected feeders now for three reasons:

- 4 (a) to reduce the current reliability impact of feeder trunk outages,
 5 (b) to reduce the risk of future outages due to the high probability of equipment failure,
 6 and
 7 (c) to ensure effective FA saturation on the system.

8

9 Of the customer interruptions (CI) on the selected feeders, 68% are attributable to the trunk /c
 10 portions these feeders; for customer hours interrupted (CHI), 58% are attributable to the feeder
 11 trunk (See Figure 1). By deploying FA on these feeders a potential reliability savings of 51% for /c
 12 CI and 44% of CHI on the feeders can be achieved (See Section III). /c

13



14 **Figure 1: Reliability Impact and FA Savings on Selected Feeders**

ICM Project | Feeder Automation

1 **III NEED**

2

3 This project is necessary to help THESL maintain reliability by reducing the impact of feeder
4 trunk related outages on SAIDI and SAIFI. As discussed above, FA helps limit the number of
5 customers impacted by trunk outages and reduces the duration of these outages. In the face of
6 aging infrastructure and financial and physical limitations on the pace of capital replacement, FA
7 is a cost effective method of addressing reliability performance.

8

9 Examining the impacts of trunk related outages throughout the THESL system demonstrates the
10 potential benefits of FA to improve reliability. Figures 4, 5 and 6 illustrate the reliability of the
11 THESL distribution system over the last ten years using CI, SAIDI and SAIFI metrics. These figures
12 show that trunk feeders have a much greater impact on overall reliability than lateral feeders.
13 Figure 4 shows that in terms of the number of interruptions, trunk feeders cause more than
14 twice as many as lateral feeders. This difference translates into more than 500,000 additional
15 customer interruptions due to outages on trunk feeders. Figure 5 compares SAIDI over the last
16 ten years for trunk and lateral feeders. In most years the SAIDI for trunk feeders is more than
17 twice the SAIDI for lateral feeders, but in 2011, it is more than three time higher. Figure 6 shows
18 that SAIFI is also several times higher for trunk feeders.

19

20 The reason for the greater reliability impacts of feeder trunks is that faults on lateral feeders
21 affect relatively few customers compared to those on feeder trunks. Lateral feeder faults only
22 affect the small number of customers that are protected by the fuse on that lateral. By
23 comparison, faults on the feeder trunk cause the feeder's circuit breaker to open and disrupt
24 power to all customers served by the feeder.

**RESPONSES TO SCHOOL ENERGY COALITION
 INTERROGATORIES ON ISSUE 2.2**

1 **INTERROGATORY 23:**

2 **Reference(s): Tab 4/B21**

3

4 With respect to Externally – Initiated Plant Relocations and Expansions:

5

6 **a) [p.4] Please breakdown each job into a) relocation costs and b) expansion costs.**

7

8 **RESPONSE:**

9 a)

| Job Title | Agency | Total Estimated Project Cost | Project Breakdown | | | |
|--------------------------------|-----------------------|------------------------------------|-------------------|------------------|---------------------|--------------------|
| | | (\$M) | Relocation (%) | Expansion (%) | Relocation (\$M) | Expansion (\$M) |
| Queens Quay Rebuild Phase 1 | Waterfront Toronto | \$4.67 | 13% | 87% | \$0.60 | \$4.07 |
| Queens Quay Rebuild Phase 2 | Waterfront Toronto | \$5.30 | 11% | 89% | \$0.60 | \$4.70 |
| Queens Quay Rebuild Phase 3 | Waterfront Toronto | \$3.42 | 18% | 82% | \$0.60 | \$2.82 |
| Queens Quay Rebuild Phase 4 | Waterfront Toronto | \$12.43 | 22% | 78% | \$2.70 | \$9.73 |
| Queens Quay Rebuild Phase 5 | Waterfront Toronto | \$7.98 | 13% | 87% | \$1.00 | \$6.98 |

RESPONSES TO SCHOOL ENERGY COALITION INTERROGATORIES ON ISSUE 2.2

| Job Title | Agency | Total Estimated Project Cost | Project Breakdown | | | |
|--|------------|------------------------------------|-------------------|------------------|---------------------|--------------------|
| | | (\$M) | Relocation (%) | Expansion (%) | Relocation (\$M) | Expansion (\$M) |
| Metrolinx West of Hwy 27 | GO Transit | \$0.23 | 100% | 0% | \$0.23 | \$0.00 |
| GTS Bridge – Hwy 27 | GO Transit | \$0.14 | 100% | 0% | \$0.14 | \$0.00 |
| Weston Tunnel | GO Transit | \$0.47 | 100% | 0% | \$0.47 | \$0.00 |
| Martin Grove Bridge | GO Transit | \$0.12 | 100% | 0% | \$0.12 | \$0.00 |
| Black Creek and Weston UG Reinstatement | GO Transit | \$0.09 | 100% | 0% | \$0.09 | \$0.00 |
| GO Strachan UG Crossing Civil | GO Transit | \$0.26 | 100% | 0% | \$0.26 | \$0.00 |
| GO Strachan UG Crossing Civil | GO Transit | \$0.13 | 100% | 0% | \$0.13 | \$0.00 |
| Strachan Electrical Relocation Part 1 | GO Transit | \$1.98 | 100% | 0% | \$1.98 | \$0.00 |
| Strachan Electrical Relocation Part 2 | GO Transit | \$1.73 | 100% | 0% | \$1.73 | \$0.00 |

**RESPONSES TO SCHOOL ENERGY COALITION
 INTERROGATORIES ON ISSUE 2.2**

| Job Title | Agency | Total Estimated Project Cost | Project Breakdown | | | |
|---|--------------------|------------------------------------|-------------------|------------------|---------------------|--------------------|
| | | (\$M) | Relocation (%) | Expansion (%) | Relocation (\$M) | Expansion (\$M) |
| Strachan Electrical Relocation Part 3 | GO Transit | \$1.34 | 100% | 0% | \$1.34 | \$0.00 |
| Strachan Electrical Relocation Part 4 | GO Transit | \$0.92 | 100% | 0% | \$0.92 | \$0.00 |
| Keele St and Hwy 401-PH2- Tunnelling Under Hwy 401 | MTO | \$1.69 | 100% | 0% | \$1.69 | \$0.00 |
| Eglinton Ramp Onto Hwy 427 | MTO | \$0.24 | 100% | 0% | \$0.24 | \$0.00 |
| Dunn Ave Directional Drilling | City of Toronto | \$0.72 | 100% | 0% | \$0.72 | \$0.00 |
| Dundas Street Overhead to Underground Phase 1 - Design | City of Toronto | \$0.64 | 100% | 0% | \$0.64 | \$0.00 |
| Dundas Street Overhead to Underground Phase 2 | City of Toronto | \$8.77 | 100% | 0% | \$8.77 | \$0.00 |

**RESPONSES TO SCHOOL ENERGY COALITION
INTERROGATORIES ON ISSUE 2.2**

| Job Title | Agency | Total Estimated Project Cost | Project Breakdown | | | |
|--|--------------------|------------------------------------|-------------------|------------------|---------------------|--------------------|
| | | (\$M) | Relocation (%) | Expansion (%) | Relocation (\$M) | Expansion (\$M) |
| Dundas Street Overhead to Underground Phase 3 | City of Toronto | \$8.01 | 100% | 0% | \$8.01 | \$0.00 |
| North West PATH Addition Phase 1 | City of Toronto | \$1.62 | 95% | 5% | \$1.54 | \$0.08 |
| North West PATH Addition Phase 2 | City of Toronto | \$1.38 | 90% | 10% | \$1.24 | \$0.14 |
| Front Street Streetscape Improvement | City of Toronto | \$0.52 | 100% | 0% | \$0.52 | \$0.00 |
| Beecroft OH Reconfiguration | City of Toronto | \$1.07 | 100% | 0% | \$1.07 | \$0.00 |
| Lawrence Avenue Relocation | City of Toronto | \$0.15 | 100% | 0% | \$0.15 | \$0.00 |

- 1 **b) Have any of the requesting Agencies/Governments made official requests to**
- 2 **date? If so, for which projects?**
- 3
- 4 b) Yes. Official requests have been made for all projects.

**RESPONSES TO SCHOOL ENERGY COALITION
INTERROGATORIES ON ISSUE 2.2**

1 **c) Between 2008 and 2010, how many externally – initiated plant relocations and**
2 **expansions jobs (and there costs) were i) budgeted and ii) actual incurred in the**
3 **year budgeted.**

4

5 **RESPONSE:**

6 **c)**

| Year | Number of Projects Budgeted | Amount Budgeted (\$M) | Number of Projects Completed in Budget Year | Actual Costs Incurred in Budgeted Year (\$M) |
|------|-----------------------------|-----------------------|---|--|
| 2008 | 7 | 2.97 | 2 | 0.73 |
| 2009 | 0 | 0 | 1 | 2.24 |
| 2010 | 17 | 3.57 | 7 | 3.18 |

Note: Projects typically require 12-18 months to complete.

ICM Project | Externally-Initiated Plant Relocations and Expansions

1 If only the required infrastructure for relocation is built at the present time, THESL will be
2 limited by the existing civil infrastructure along Queens Quay Boulevard. This civil
3 infrastructure, as detailed in Figure 6, is undersized and insufficient to accommodate existing
4 circuits plus the additional feeders required to serve the loads anticipated along Queens Quay
5 Boulevard shown in Figure 2.

6
7 The restrictions and possible lack of space along the new revitalized Queens Quay Boulevard
8 from Yo Yo Ma Lane to Parliament Street would prevent THESL from utilizing that route unless
9 new ducts and chambers are added as part of the Queens Quay refurbishment. Otherwise,
10 additional capital funds will have to be spent in future years for THESL to install the necessary
11 new civil infrastructure for new feeders to supply customers via Bremner TS.

12
13 This new civil infrastructure would, in turn, require new trenching along major routes such as
14 York Street and Lakeshore Boulevard in order to access the high growth areas. This work would
15 be significantly more costly because while the distance to be covered along Lakeshore is similar
16 to that for Queens Quay Boulevard, additional work would be required on York Street.
17 Moreover, Lakeshore is a higher traffic route resulting in more complex construction and
18 maintenance restrictions. Overall, the long term costs associated with this approach are
19 significantly higher than the costs associated with installing the necessary facilities as part of the
20 expansion along Queens Quay Boulevard.

21 22 **1.2. Business Case Evaluation (BCE) Results**

23 The total cost for THESL to perform the relocations as requested by Waterfront Toronto and
24 increase the duct capacity and civil infrastructure for future requirements is estimated at
25 \$25.53M. This estimate can be divided into two portions. Portion 1, to be funded one hundred /UF
26 percent by Waterfront Toronto, is estimated at \$4.50M and includes the civil and electrical plant /UF
27 relocation based on preliminary design during project development and alignments proposed by
28 Waterfront Toronto. Portion 2, required by THESL estimated at \$21.32M and includes the /UF
29 expansion to a 32-duct 3.2 kilometre duct bank along Queens Quay Boulevard from Yo Yo Ma
30 Lane to Parliament Street, approximately 55 cable chambers, all associated structure
31 stabilization and all required road crossings.

ICM Project | Externally-Initiated Plant Relocations and Expansions

1
2 Alternatively, the total cost involved for THESL to perform only the relocations required, and
3 then in future years construct new infrastructure to meet demand is an estimated \$35.32M. /UF
4 Similar to the scenario described above, this estimate includes a \$4.50M portion to be fully paid /UF
5 for by Waterfront Toronto for the proposed civil and electrical relocation. In addition, it also
6 includes an estimated \$30.82M THESL portion for a 24-duct 3.2 kilometre duct bank along /UF
7 Lakeshore Boulevard from Yo Yo Ma Lane to Parliament Street, approximately 45 cable
8 chambers, all associated structure stabilization and all required road crossings, plus the rebuild
9 of approximately 150 metres and 300 metres of civil infrastructure on York Street and
10 Parliament Street respectively for distribution customer servicing.
11
12 The projected savings of an estimated \$10.79M arise because of the cost savings from not /UF
13 executing construction on Lakeshore Boulevard as well as the elimination of new facilities on
14 York Street and Parliament Street. Compared to Queens' Quay, Lakeshore Boulevard is a main
15 roadway with work restrictions that would result in escalated costs and complex construction
16 requirements. In addition, by performing its civil infrastructure activities in alignment with
17 external parties' required work, potential customer disruptions can be minimized.
18
19 The requested funds for the THESL expansion in both scenarios are initially driven from third
20 parties as a result of their relocation activities which are performed at their expense. THESL, in
21 turn, must respond to these third-party investments performing immediate expansion of THESL-
22 owned infrastructure located in these same locations to address future growth considerations.
23 If THESL does not take immediate action to address these assets, due to restrictions that are
24 placed by the third parties (such as Waterfront Toronto) following the execution of their
25 projects, THESL risks being unable to address the immediate load growth concerns and future
26 source of supply for customers.
27
28 All costs identified above for both scenarios include work required for relocation as requested
29 by Waterfront Toronto and work associated to additional expansion required by THESL. Only
30 the incremental capital required by THESL is being justified in this Business Case and does not

ICM Project | Externally-Initiated Plant Relocations and Expansions

1 include the portion of relocation work to be one hundred percent funded by Waterfront
 2 Toronto.

3
 4 Given that THESL must undertake the relocation and expansion work on Queens Quay
 5 Boulevard, installing sufficient duct capacity to meet future needs is the most prudent approach
 6 for ratepayers. In addition, it will result in strategically located facilities that are optimally
 7 integrated with the planned Bremner TS. It will also minimize construction disruption for the
 8 neighbourhood area. In contrast, if future needs are not addressed, THESL will have insufficient
 9 ducts and associated facilities to supply new customers along Queens Quay Boulevard and will
 10 be forced to construct more expensive facilities in undesirable locations that will not support or
 11 strengthen THESL's distribution system.

12
 13 **1.3. Detailed Descriptions of Specific Central Waterfront Revitalization Jobs**

14
 15 **Table 2: Waterfront Revitalization Jobs and Cost Estimates (2012-2013~~2014~~)**

| Estimate Number | Job Title | THESL Cost Estimate (\$M) |
|------------------|---|---------------------------|
| 22851 | Queens Quay Rebuild Phase 1 (2012) | \$3.78 |
| 22853 | Queens Quay Rebuild Phase 2 (2013) | \$4.70 |
| 22854 | Queens Quay Rebuild Phase 3 (2013) | \$2.82 |
| 24729 | Queens Quay Rebuild Phase 4 (2013) | \$9.73 |
| 24731 | Queens Quay Rebuild Phase 5 (2014) | \$6.98 |
| | TOTAL | \$21.03 |

/US

/UF

/US

/US

/UF, US

16 The scope of work for this entire expansion project includes constructing a new 32-duct 3.2
 17 kilometre duct bank along the south side of Queens Quay Boulevard from Yo Yo Ma Lane to
 18 Parliament Street. The duct bank to be constructed will be designed as two 4x4 duct banks with
 19 associated cable chambers required for splicing and jointing. Approximately 55 cable chambers
 20 and structure stabilization material, such as Helix Anchors and piles for cable chamber
 21 installation, will be required as a part of this project.

**RESPONSES TO ONTARIO ENERGY BOARD STAFF
INTERROGATORIES ON ISSUE 2.2**

1 **INTERROGATORY 27:**

2 **Reference(s):** T2/App. 4, T4/S B11/pp. 22-23 and T4/S B16/pp. 10-11

3

4 The first reference explains in detail the theoretical constructs of the “Feeder Investment
5 Model” (“FIM”), and the theoretical constructs of the Model for the “Cost of Ownership”
6 (“COO”).

7

8 The second reference discusses an outage cost based on \$30 per customer per interruption
9 and \$15 per kWh interrupted.

10

11 The third reference discusses an outage cost based on \$30/kW outage event cost and \$15
12 per kWh outage duration cost.

13

14 **a) Please explain the apparent differences between the basis of the two referenced
15 customer interruption costs.**

16

17 **RESPONSE:**

18 a) The two references use consistent customer interruption costs. In both cases the
19 applied customer interruption costs (CICs) are as follows:

20

21 i. $CIC = \text{Event Cost} + \text{Duration Cost}$

22

23 ii. $\text{Event Cost} = (SAIFI_{EFFECT})(\text{Total Load})$

24

Where:

25

- SAIFI_{EFFECT} (\$30) represents the cost associated with the
26 occurrence of the interruption.

**RESPONSES TO ONTARIO ENERGY BOARD STAFF
INTERROGATORIES ON ISSUE 2.2**

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24

- Total Load represents the peak load in kVA that will be interrupted due to the outage event.

iii. $Duration\ Cost = (SAIDI_{EFFECT})(Total\ Load)(Outage\ Duration)$

Where:

- SAIDI_{EFFECT} (\$15) represents the cost associated with the duration of the interruption.
- Total Load represents the peak load in kVA that will be interrupted due to the outage event.
- Outage Duration represents the average duration of the outage event in hours.

b) Please clarify whether or not a fixed set of referenced customer interruption costs are used for all customer interruptions in all the FIM and COO type business case evaluations, and if so please provide that fixed set.

RESPONSE:

b) As noted in (a), THESL has adopted the use of a \$30/kVA (peak load) customer interruption cost value to represent the outage occurring (The “Event”) and a \$15/kVA-hour (peak load) customer interruption cost value to represent the length of the outage (The “Duration”). These costs are adopted within every FIM and COO business case evaluation presented within the ICM filing.

c) Please provide supporting evidence/calculations justifying this cost.

RESPONSES TO ONTARIO ENERGY BOARD STAFF INTERROGATORIES ON ISSUE 2.2


1 **RESPONSE:**

2 c) The customer interruption costs applied by THESL as part of every FIM and COO
3 business case were developed with consultants, who have worked with other utilities
4 in establishing similar parameters. Reliability valuation studies, such as those from
5 Roy Billinton, were used to aid in the development of these parameters, which are
6 applied consistently to quantify power interruptions to all types of customers.

7

8 Figure 1 and chart 1 illustrate how THESL's customer interruption costs compare to
9 those established via reliability valuation studies. Figure 1 illustrates the total cost of
10 a four-hour outage using these various customer interruption costs. Those employed
11 by THESL are shown in red. Table 1 shows the Event Cost per Customer and
12 Duration Cost per Customer-Hour using each of these customer interruption costs,
13 including those employed by THESL. The chart also contains the source of the
14 information shown in the blue bars in Figure 1, and in Table 1, THESL's customer
15 interruption costs are within the range of the other sampled costs. In addition,
16 THESL has also confirmed that the current customer duration cost employed by
17 THESL is within the range of customer duration costs used by Hydro One Networks
18 Inc.

**RESPONSES TO ONTARIO ENERGY BOARD STAFF
 INTERROGATORIES ON ISSUE 2.2**



1 **Figure 1 – Cost of a Typical 4-Hour Outage**

2 **Table 1 – Customer Interruption Cost Breakdown**

| | Study Name | Duration Cost (\$/kVA) | Event Cost (\$/kVA) | Reference | Page Number on PDF |
|---|---|------------------------|---------------------|-----------|--------------------|
| A | Interruption Costs Netherlands | 8.721 | 6.579 | N/A | 4 |
| B | THESL | 15 | 30 | N/A | N/A |
| C | The Use of Customer Outage Cost Surveys in Policy Decision-Making | 14.436 | 35.982 | N/A | 5 |
| D | Consumer Expectations of DNOs and WTP for Improvements in Service | 22.539 | 8.769 | Table 29 | 35 |
| E | Economic Valuation of Electrical Service Reliability | 17.631 | 86.652 | N/A | 9 |
| F | How to Estimate the Value of Service Reliability Improvements | 50.94 | 42.93 | Table 1 | 3 |