

## **EXHIBIT 2 – RATE BASE**

# EXHIBIT 2 – RATE BASE

## Table of Contents

<b>RATE BASE</b> .....	<b>4</b>
<b>Overview</b> .....	<b>4</b>
Table 2-1 – Summary of Rate Base .....	5
<b>Fixed Asset Continuity Schedules</b> .....	<b>5</b>
Table 2-2 – Summary of Continuity Schedules.....	6
<b>Gross Assets – Property, Plant and Equipment and Accumulated Depreciation</b> .....	<b>7</b>
<b>Variance Analysis of Gross Asset Balances</b> .....	<b>8</b>
Table 2-4 – Gross Asset Balances 2013 to 2017.....	8
2013 Board Approved vs. 2013 Actuals .....	9
2013 Actuals vs. 2014 Actuals .....	13
2014 Actuals vs. 2015 Actuals .....	16
2015 Actuals vs. 2016 Bridge.....	20
2016 Bridge vs. 2017 Test.....	24
<b>Change in Accumulated Depreciation</b> .....	<b>28</b>
Table 2-11 – Accumulated Depreciation Balances 2013 to 2017.....	29
<b>Capital Additions Reconciliation to Capital Spending</b> .....	<b>30</b>
Table 2-12 – Reconciliation of Capital Additions to Capital Spending.....	31
<b>Allowance for Working Capital</b> .....	<b>32</b>
Table 2-14 – Summary of Working Capital Allowance .....	32
<b>Treatment of Stranded Assets Related to Smart Meter Deployment</b> .....	<b>33</b>
<b>CAPITAL EXPENDITURES</b> .....	<b>34</b>
<b>Planning</b> .....	<b>34</b>
<b>Required Information</b> .....	<b>35</b>
Efficiencies Realized Due to Deployment of Smart Meters and Related Technologies .....	35
Rate-Funded Activities to Defer Distribution Infrastructure.....	37
<b>Analysis of Capital Expenditures</b> .....	<b>39</b>
Table 2-16 – Capital Expenditures 2012 – 2017.....	42
Capital Projects Longer than One Year .....	45
Reconciliation to Total Capital Budget .....	45
A Comparison between 2013 and 2017.....	45
<b>Infrastructure</b> .....	<b>47</b>
Substation Rebuilds (A).....	48
Subdivision Rebuilds (B) .....	50

Main Feeders (C).....	55
Networks (F) .....	60
Overhead Line Work (G) .....	66
Automation (H) .....	71
TS Upgrade (CC) .....	75
Demand.....	79
City Works (D) & Developer Works (E) .....	80
Metering (M) .....	85
Fleet and Facilities .....	106
Vehicles and Major Equipment (N).....	107
Operating Equipment (O) .....	109
Office Furniture and Equipment (Q) .....	111
Buildings and Fixtures (R) .....	113
Information Systems .....	118
Hardware and Software (V) .....	119
Application Development (W).....	133
<b>Capital Spending by DSP Investment Category.....</b>	<b>158</b>
Table 2-42 – Capital Spending by DSP Investment Category 2012 - 2017 .....	158
Capitalization Policy .....	159
Capitalization of Overhead .....	163
Costs of Eligible Investments for the Connection of Qualifying Generation Facilities .....	165
Addition of Previously Approved ACM and ICM Project Assets to Rate Base .....	166
New Policy Options for the Funding of Capital - Advance Capital Module .....	167
Service Quality and Reliability Performance .....	176
<b>Prescribed Tables Listing.....</b>	<b>179</b>
<b>Appendix 2-1: Fixed Asset Continuity Schedules .....</b>	<b>181</b>
<b>Appendix 2-2: Capitalization Policy.....</b>	<b>187</b>
<b>Appendix 2-3: Lead Lag Study .....</b>	<b>205</b>
<b>Appendix 2-4: New Policy Options for the Funding of Capital.....</b>	<b>241</b>
<b>Appendix 2-5: Service Quality and Reliability Performance.....</b>	<b>251</b>
<b>Appendix 2-6: Distribution System Plan .....</b>	<b>253</b>

# 1 RATE BASE

---

## 2 Overview

3 The following Exhibit contains both details and analysis of London Hydro's rate base for the  
4 years 2013 Actual, 2013 Board Approved, 2014 Actual, 2015 Actual, 2016 Bridge Year, and  
5 2017 Test Year. Actuals for 2012 are also included in the Capital Expenditures section (Page  
6 34). Rate base has been calculated in accordance with the OEB's Filing Requirements for  
7 Electricity Distribution Rate Applications – 2016 Edition for 2017 Rate Applications, issued on  
8 July 14, 2016.

9 London Hydro's 2017 Cost of Service Rate Application, like its 2013 Application, has been filed  
10 in accordance with Modified International Financial Reporting Standards ("MIFRS"). All  
11 schedules and number references in this Application are in accordance with MIFRS. For  
12 external financial statement purposes, London Hydro implemented International Financial  
13 Reporting Standards ("IFRS") effective January 1, 2015. The Company had previously chosen  
14 to accept the available deferral to IFRS due to issues surrounding rate-regulated accounting for  
15 regulatory assets and liabilities, which have now been temporarily resolved. For rate-making  
16 purposes, London Hydro, in essence, moved to MIFRS effective January 1, 2012. This early  
17 adoption was accomplished by implementing required MIFRS changes acceptable under the  
18 CGAAP accounting standard. Accordingly, the transition to IFRS has no impact for rate-making  
19 purposes.

20 The net fixed assets include those distribution assets that are associated with the delivery of  
21 electricity to the inhabitants of the City of London. London Hydro's rate base calculation  
22 excludes any non-distribution assets, work-in-progress as well as inventory held for capital  
23 projects. Controllable expenses used in the calculation of the working capital allowance include  
24 operations and maintenance, billing and collections, community relations, eligible donations,  
25 and administration expenses.

26 Table 2-1 below presents a summary of London Hydro's rate base for the 2013 Board Approved  
27 Year, 2013-2015 Historical Years, 2016 Bridge Year, and 2017 Test Year. Rate base for the  
28 2017 Test Year is calculated at \$301,746,404.



1 Note that the gross fixed assets and accumulated depreciation balances used in London  
 2 Hydro's rate base calculation correspond directly to the Fixed Asset Continuity Schedules that  
 3 can be found in Appendix 2-1, within this Exhibit.

4 **Table 2-1 – Summary of Rate Base**

SUMMARY OF RATE BASE								
	2013 Actual	2013 Board Approved	2014 Actual	2015 Actual	2016 Bridge	2017 Test	2013 Board Approved to 2017 Test	CAGR
	\$	\$	\$	\$	\$	\$	\$	%
Opening Balance, January 1	223,433,727	222,156,052	228,404,051	235,609,045	247,353,386	258,767,468	36,611,416	3.9%
Closing Balance, December 31	228,404,051	230,954,219	235,609,045	247,353,386	258,510,661	268,869,300	37,915,081	3.9%
1576 CGAAP to IFRS Adjustment	471,922	471,922	393,268	275,288	157,307		(471,922)	-100.0%
Adjusted Closing Balance, December 31	228,875,973	231,426,141	236,002,313	247,628,674	258,667,968	268,869,300	37,443,159	3.8%
Net Fixed Assets (Average)	226,154,850	227,027,058	232,439,143	241,815,493	253,148,321	263,768,634	36,741,576	3.8%
Allowance for Working Capital	42,538,003	41,958,198	45,338,048	47,397,023	51,285,613	37,977,770	(3,980,428)	-2.5%
<b>Rate Base</b>	<b>268,692,852</b>	<b>268,985,256</b>	<b>277,777,190</b>	<b>289,212,516</b>	<b>304,433,933</b>	<b>301,746,404</b>	<b>32,761,148</b>	<b>2.9%</b>
Annual Change		292,403	8,791,935	11,435,326	15,221,417	(2,687,529)		
Annual Change %		0.1%	3.3%	4.1%	5.3%	-0.9%		12.2%

5  
 6 Total rate base has increased by \$32,761,148 between the 2013 Board Approved amounts and  
 7 the 2017 Test Year, representing a total increase of 12.2% or a 2.9% compound annual growth  
 8 rate (CAGR). (Note: The 2016 closing balance differs from the 2017 opening balance by  
 9 \$256,807. This amount represents the net book value of the renewable connection and smart  
 10 grid regulatory deferral accounts, budgeted to be brought into rate base on January 1, 2017).  
 11 Details of this transfer are shown in Table 2-2 below. More information about the transfer of  
 12 these regulatory deferral accounts can be found in Exhibit 9, "Deferral and Variance Accounts".  
 13 Details regarding the calculation of working capital allowance can be found on Page 32 within  
 14 this Exhibit.

15 **Fixed Asset Continuity Schedules**

16 London Hydro has completed Fixed Asset Continuity Schedules, in accordance with Appendix  
 17 2-BA of the Filing Requirements, for each of the following years: 2013 Board Approved, 2013  
 18 Actuals, 2014 Actuals, 2015 Actuals, 2016 Bridge and 2017 Test Year. Refer to Table 2-2 below  
 19 for a summary of those continuity schedules. Individual schedules can be found at the end of  
 20 this Exhibit, Appendix 2-1.

1

**Table 2-2 – Summary of Continuity Schedules**

<b>SUMMARY OF FIXED ASSET CONTINUITY SCHEDULES</b>						
	<b>2013 Actual</b>	<b>2013 Board Approved</b>	<b>2014 Actual</b>	<b>2015 Actual</b>	<b>2016 Bridge</b>	<b>2017 Test</b>
	\$	\$	\$	\$	\$	\$
<b>Gross Fixed Assets</b>						
Opening balance	414,817,196	413,940,268	415,328,059	429,305,453	433,843,637	451,710,106
Transfer regulatory deferrals Jan 1, 2017	-	-	-	-	-	438,897
Additions	21,772,739	25,153,400	24,651,127	29,237,293	29,800,000	28,092,000
Disposals	(21,261,877)	(12,022,015)	(10,673,733)	(24,699,109)	(11,933,531)	(10,921,994)
Closing balance (excluding WIP)	415,328,059	427,071,653	429,305,453	433,843,637	451,710,106	469,319,009
Average Gross Fixed Assets	415,072,627	420,505,960	422,316,756	431,574,545	442,776,871	460,734,006
<b>Accumulated Depreciation</b>						
Opening balance	191,383,469	191,784,216	186,924,008	193,696,409	186,490,251	193,199,445
Transfer regulatory deferrals Jan 1, 2017	-	-	-	-	-	182,089
Additions	16,746,338	16,365,169	17,423,639	17,492,952	18,642,725	17,984,944
Disposals	(21,205,799)	(12,031,951)	(10,651,238)	(24,699,109)	(11,933,531)	(10,916,770)
Closing balance	186,924,008	196,117,434	193,696,409	186,490,251	193,199,445	200,449,709
Average Accumulated Depreciation	189,153,738	193,950,825	190,310,208	190,093,330	189,844,848	196,915,622
<b>Net Fixed Assets</b>	<b>228,404,051</b>	<b>230,954,219</b>	<b>235,609,045</b>	<b>247,353,386</b>	<b>258,510,661</b>	<b>268,869,300</b>

2

3 Table 2-3 below reconciles the change in Accumulated Depreciation, shown above, to the  
 4 annual depreciation expense (as reported in Exhibit 4, Page 379).

5 **Table 2-3 – Reconciliation of Change in Accumulated Depreciation to Depreciation Expense**

<b>DEPRECIATION EXPENSE RECONCILIATION 2013 - 2017</b>						
	<b>2013 Actual</b>	<b>2013 Board Approved</b>	<b>2014 Actual</b>	<b>2015 Actual</b>	<b>2016 Bridge</b>	<b>2017 Test</b>
	\$	\$	\$	\$	\$	\$
Change in Accumulated Depreciation	16,746,338	16,365,169	17,423,639	17,492,952	18,642,725	17,984,944
Add: Amortization of 1576 MIFRS Transition	78,654	117,981	117,981	117,981	118,000	-
Less: V&E (included in OH Allocation)	(726,900)	(726,800)	(814,974)	(865,252)	(1,019,430)	(1,076,551)
Less: Deferred Revenue	-	-	20,811	78,721	167,569	219,919
<b>Depreciation Expense</b>	<b>16,098,091</b>	<b>15,756,350</b>	<b>16,747,457</b>	<b>16,824,401</b>	<b>17,908,864</b>	<b>17,128,312</b>

6

7



## 1 **Gross Assets – Property, Plant and Equipment and Accumulated** 2 **Depreciation**

3 Below are the details of London Hydro's Gross Asset and Accumulated Depreciation balances  
4 for the 2013 Board Approved Year, 2013-2015 Historical Years, 2016 Bridge Year, and 2017  
5 Test Year. This information is captured in the following tables:

- 6       ➤ Table 2-4 – Gross Asset Balances 2013 to 2017 – Page 8
- 7       ➤ Table 2-11 – Accumulated Depreciation Balances 2011 to 2013 – Page 29

8 These tables break down gross assets and accumulated depreciation first by function and then  
9 further by major plant account.

10 The gross assets and accumulated depreciation are broken down into the following four  
11 functions:

- 12       • Distribution Plant Asset Accounts include the Uniform System of Accounts (USoA)  
13       accounts 1805 – 1860
- 14       • General Plant Asset Accounts include the USoA accounts 1908 – 1980 (excluding 1920)
- 15       • Information Systems Asset Accounts include the USoA accounts 1920 and 1611  
16       (formerly 1925)
- 17       • Contributions and grants include the USoA accounts 1995 and 2440

18 For each of these functionalized plant items, a detailed breakdown by major plant account is  
19 provided. Each plant item is accompanied by a description in accordance with the Board's  
20 USoA, including the 2017 test year, per Filing Requirement 2.2.1.2.

21

1 **Variance Analysis of Gross Asset Balances**

2 London Hydro's gross asset balances are projected to be \$469,319,009 at the end of the 2017  
 3 Test Year, representing an increase of \$42,247,356 between the 2013 Board Approved Year  
 4 and 2017. Significant annual variances broken down by function are discussed below.

5 **Table 2-4 – Gross Asset Balances 2013 to 2017**

GROSS ASSET BALANCES 2013 TO 2017							
	2013 Actual	2013 Board Approved	2014 Actual	2015 Actual	2016 Bridge	2017 Test	2013 OEB Approved to 2017 Test
	\$	\$	\$	\$	\$	\$	\$
<b>Distribution Plant</b>							
1805 Land - Substations	385,690	385,690	385,690	385,690	385,690	385,690	(0)
1806 / 1612 Land Rights	366,233	322,234	383,514	414,759	414,759	414,759	92,525
1808 Buildings - Substations	1,128,336	1,278,336	1,128,336	1,128,336	1,168,336	1,210,336	(68,000)
1820 /1610 Substation Equipment	17,123,890	16,739,536	17,396,761	17,563,552	17,679,652	17,794,152	1,054,616
1830 Poles, Towers & Fixtures	39,738,167	41,493,467	41,662,934	43,125,558	45,079,658	47,273,458	5,779,991
1835 OH Conductors & Devices	55,136,846	55,679,739	58,467,100	61,194,389	64,476,589	67,987,489	12,307,750
1840 UG Conduit	35,698,363	35,319,448	38,211,108	43,296,851	47,849,151	52,171,051	16,851,604
1845 UG Conductor & Devices	101,576,155	109,523,965	96,726,669	90,803,781	90,510,422	92,535,816	(16,988,149)
1850 Line Transformers	79,632,662	77,245,338	83,540,538	89,220,013	93,490,013	97,784,813	20,539,475
1855 Services (OH & UG)	24,720,934	22,381,015	27,008,301	29,459,220	30,974,120	32,569,920	10,188,905
1860 Meters	25,081,481	25,318,013	25,774,558	26,831,646	27,925,246	29,038,746	3,720,734
	<b>380,588,758</b>	<b>385,686,781</b>	<b>390,685,509</b>	<b>403,423,795</b>	<b>419,953,636</b>	<b>439,166,230</b>	<b>53,479,450</b>
<b>General Plant</b>							
1908 Buildings & Fixtures	22,091,652	23,749,979	22,780,090	23,396,955	24,500,503	23,096,571	(653,408)
1910 Leasehold Improvements	-	-	-	-	-	-	-
1915 Office Furniture & Equipment	731,859	922,307	732,848	520,905	797,931	860,704	(61,603)
1930 Transportation Equipment	11,472,907	11,602,662	11,826,499	12,813,264	13,219,310	13,589,831	1,987,169
1935 Stores Equipment	278,138	266,776	273,759	267,598	345,540	234,972	(31,804)
1940 Tools, Shop & Garage Equipment	1,023,409	1,204,152	1,040,004	941,130	989,586	1,020,795	(183,357)
1945 Measurement & Testing Equipment	119,614	156,864	202,476	516,606	726,606	865,590	708,726
1950 Power Operated Equipment	931,471	1,214,137	951,281	1,032,283	1,032,283	1,106,979	(107,158)
1955 Communication Equipment	3,756,098	3,788,534	3,992,791	4,064,185	4,834,685	5,582,185	1,793,651
1960 Miscellaneous Equipment	-	-	-	4,039	4,039	4,039	4,039
1980 System Supervisory Equipment	2,154,497	3,300,223	2,439,074	3,385,233	3,716,233	4,006,818	706,595
	<b>42,559,643</b>	<b>46,205,634</b>	<b>44,238,822</b>	<b>46,942,197</b>	<b>50,166,717</b>	<b>50,368,484</b>	<b>4,162,850</b>
<b>Information Systems</b>							
1920 Computer - Hardware	3,200,325	2,640,094	3,381,156	2,523,106	1,763,237	632,829	(2,007,265)
1925 /1611 Computer - Software	28,241,375	30,301,668	32,132,701	25,875,825	26,834,803	28,260,752	(2,040,916)
	<b>31,441,700</b>	<b>32,941,762</b>	<b>35,513,857</b>	<b>28,398,931</b>	<b>28,598,040</b>	<b>28,893,581</b>	<b>(4,048,182)</b>
<b>Total Gross Balance before Contributed Capital</b>	<b>454,590,101</b>	<b>464,834,177</b>	<b>470,438,188</b>	<b>478,764,923</b>	<b>498,718,392</b>	<b>518,428,295</b>	<b>53,594,118</b>
1995 /2440 Contributions and Grants	(39,262,043)	(37,762,524)	(41,132,735)	(44,921,286)	(47,008,286)	(49,109,286)	(11,346,762)
	<b>415,328,059</b>	<b>427,071,653</b>	<b>429,305,453</b>	<b>433,843,637</b>	<b>451,710,106</b>	<b>469,319,009</b>	<b>42,247,356</b>



1 **2013 Board Approved vs. 2013 Actuals**

2 In 2013, London Hydro's gross asset balances were lower than 2013 Board Approved amounts  
 3 by \$11,743,594, or 2.8%. See Table 2-5 below for breakdown of gross asset balances by  
 4 function and major plant account.

5 **Table 2-5 – 2013 Board Approved vs. 2013 Actuals Gross Assets by Account**

<b>GROSS ASSET VARIANCE ANALYSIS</b>				
<b>2013 BOARD APPROVED vs. 2013 ACTUALS</b>				
	<b>2013</b>	<b>2013</b>	<b>Variance</b>	<b>Variance</b>
	<b>Actual</b>	<b>Board Approved</b>		
	<b>\$</b>	<b>\$</b>	<b>\$</b>	<b>%</b>
<b>Distribution Plant</b>				
1805 Land - Substations	385,690	385,690	(0)	0%
1806 / 1612 Land Rights	366,233	322,234	43,999	12%
1808 Buildings - Substations	1,128,336	1,278,336	(150,000)	-13%
1820 /1610 Substation Equipment	17,123,890	16,739,536	384,354	2%
1830 Poles, Towers & Fixtures	39,738,167	41,493,467	(1,755,300)	-4%
1835 OH Conductors & Devices	55,136,846	55,679,739	(542,893)	-1%
1840 UG Conduit	35,698,363	35,319,448	378,916	1%
1845 UG Conductor & Devices	101,576,155	109,523,965	(7,947,810)	-8%
1850 Line Transformers	79,632,662	77,245,338	2,387,324	3%
1855 Services (OH & UG)	24,720,934	22,381,015	2,339,919	9%
1860 Meters	25,081,481	25,318,013	(236,532)	-1%
	<b>380,588,758</b>	<b>385,686,781</b>	<b>(5,098,023)</b>	<b>-1%</b>
<b>General Plant</b>				
1908 Buildings & Fixtures	22,091,652	23,749,979	(1,658,327)	-8%
1910 Leasehold Improvements	-	-	-	-
1915 Office Furniture & Equipment	731,859	922,307	(190,448)	-26%
1930 Transportation Equipment	11,472,907	11,602,662	(129,755)	-1%
1935 Stores Equipment	278,138	266,776	11,362	4%
1940 Tools, Shop & Garage Equipment	1,023,409	1,204,152	(180,743)	-18%
1945 Measurement & Testing Equipment	119,614	156,864	(37,250)	-31%
1950 Power Operated Equipment	931,471	1,214,137	(282,666)	-30%
1955 Communication Equipment	3,756,098	3,788,534	(32,436)	-1%
1960 Miscellaneous Equipment	-	-	-	-
1980 System Supervisory Equipment	2,154,497	3,300,223	(1,145,726)	-53%
	<b>42,559,643</b>	<b>46,205,634</b>	<b>(3,645,991)</b>	<b>-9%</b>
<b>Information Systems</b>				
1920 Computer - Hardware	3,200,325	2,640,094	560,231	18%
1925 /1611 Computer - Software	28,241,375	30,301,668	(2,060,293)	-7%
	<b>31,441,700</b>	<b>32,941,762</b>	<b>(1,500,062)</b>	<b>-5%</b>
<b>Total Gross Balance before Contributed Capital</b>	<b>454,590,101</b>	<b>464,834,177</b>	<b>(10,244,076)</b>	<b>-2%</b>
1995 /2440 Contributions and Grants	(39,262,043)	(37,762,524)	(1,499,519)	4%
<b>Total</b>	<b>415,328,059</b>	<b>427,071,653</b>	<b>(11,743,594)</b>	<b>-2.8%</b>



1 *Revised 2013 OEB Approved Amounts*

2 The 2013 OEB Approved gross asset balances did not factor in the increased disposals that  
3 were deemed to have taken place when the asset lifespans were updated in 2012, due to the  
4 conversion to IFRS. Because of this, London Hydro has prepared an additional schedule,  
5 comparing 2013 Actuals to revised 2013 OEB Approved amounts, utilizing actual 2013 OEB  
6 Approved amounts, and adjusting for the actual amount of 2013 disposals (including those due  
7 to the change in lifespans). Table 2-6 below, provides a better comparison of gross asset  
8 balances for the 2013 year.

9 The following pages describe a high level summary of variances in gross capital asset balances.  
10 Details specific to capital purchases can be found in the 'Capital Expenditures' section within  
11 this Exhibit, commencing on page 34.

12

1 **Table 2-6 – 2013 Board Approved (Revised) vs. 2013 Actuals Gross Assets by Account**

<b>GROSS ASSET VARIANCE ANALYSIS</b>				
<b>2013 BOARD APPROVED REVISION vs. 2013 ACTUALS</b>				
	<b>2013</b>	<b>2013</b>		
	<b>Actual</b>	<b>Board Approved</b>	<b>Variance</b>	<b>Variance</b>
	\$	\$	\$	%
<b>Distribution Plant</b>				
1805 Land - Substations	385,690	385,690	(0)	0%
1806 / 1612 Land Rights	366,233	322,234	43,999	12%
1808 Buildings - Substations	1,128,336	1,278,336	(150,000)	-13%
1820 /1610 Substation Equipment	17,123,890	16,704,716	419,174	2%
1830 Poles, Towers & Fixtures	39,738,167	42,290,730	(2,552,563)	-6%
1835 OH Conductors & Devices	55,136,846	56,509,543	(1,372,697)	-2%
1840 UG Conduit	35,698,363	35,543,291	155,073	0%
1845 UG Conductor & Devices	101,576,155	102,778,364	(1,202,209)	-1%
1850 Line Transformers	79,632,662	79,660,816	(28,154)	0%
1855 Services (OH & UG)	24,720,934	22,381,015	2,339,919	9%
1860 Meters	25,081,481	25,135,799	(54,318)	0%
	<b>380,588,758</b>	<b>382,990,534</b>	<b>(2,401,776)</b>	<b>-1%</b>
<b>General Plant</b>				
1908 Buildings & Fixtures	22,091,652	21,516,407	575,245	3%
1910 Leasehold Improvements	-	-	-	
1915 Office Furniture & Equipment	731,859	706,027	25,832	4%
1930 Transportation Equipment	11,472,907	11,654,025	(181,118)	-2%
1935 Stores Equipment	278,138	282,520	(4,382)	-2%
1940 Tools, Shop & Garage Equipment	1,023,409	1,090,483	(67,074)	-7%
1945 Measurement & Testing Equipment	119,614	126,305	(6,692)	-6%
1950 Power Operated Equipment	931,471	1,214,137	(282,666)	-30%
1955 Communication Equipment	3,756,098	3,788,534	(32,436)	-1%
1960 Miscellaneous Equipment	-	-	-	
1980 System Supervisory Equipment	2,154,497	1,916,975	237,521	11%
	<b>42,559,643</b>	<b>42,295,413</b>	<b>264,230</b>	<b>1%</b>
<b>Information Systems</b>				
1920 Computer - Hardware	3,200,325	1,615,748	1,584,578	50%
1925 /1611 Computer - Software	28,241,375	28,703,471	(462,096)	-2%
	<b>31,441,700</b>	<b>30,319,218</b>	<b>1,122,482</b>	<b>4%</b>
<b>Total Gross Balance before Contributed Capital</b>	<b>454,590,101</b>	<b>455,605,165</b>	<b>(1,015,064)</b>	<b>0%</b>
1995 /2440 Contributions and Grants	(39,262,043)	(37,773,374)	(1,488,669)	4%
<b>Total</b>	<b>415,328,059</b>	<b>417,831,791</b>	<b>(2,503,733)</b>	<b>-0.6%</b>



1

2 *Distribution Plant: Variance (\$2,401,776)*

3 In 2013, Actual Distribution Plant assets were \$2,401,776 less than the 2013 Revised Board  
4 Approved amount. Details regarding this variance are explained below:

- 5
- 6 • Investments in Poles and Overhead Conductors and Devices (Accounts 1830 and 1835)  
7 were significantly lower than planned primarily due to delays in Overhead Voltage  
8 Conversions for Substations 1, 2 and 28. See capital expenditures discussion on Page  
9 66 within this Exhibit for more information).
  - 10 • Additions to Underground Conductors and Devices were \$642,448 lower than  
11 anticipated for 2013. The remaining variance in this account is attributable to difference  
in the prior year actual ending balance and the 2012 Bridge Year ending balance.

12 *Information Systems: Variance \$1,122,482*

13 In 2013, Actual Information Systems assets were \$1,122,482 more than the 2013 Revised  
14 Board Approved amount. Additions to Hardware were \$947,608 higher than the 2013 Board  
15 Approved amounts. This is primarily as a result of additional spending due to unforeseen costs  
16 required in network development to replace core switches.

17 *Contributions and Grants: Variance (\$1,488,669)*

18 In 2013, London Hydro collected \$1,488,669 more contributed capital than the 2013 Board  
19 Approved Amount.

20

1 **2013 Actuals vs. 2014 Actuals**

2 London Hydro's gross asset balances increased by \$13,977,395, or 3.4%, between the 2013  
3 and 2014 Actuals. See Table 2-7 below for a breakdown of gross asset balances by function  
4 and major plant account.

5 **Table 2-7 –2013 Actuals vs. 2014 Actuals Gross Assets by Account**

<b>GROSS ASSET VARIANCE ANALYSIS</b>				
<b>2013 ACTUALS vs. 2014 ACTUALS</b>				
	<b>2013</b>	<b>2014</b>	<b>Variance</b>	<b>Variance</b>
	<b>Actual</b>	<b>Actual</b>		
	<b>\$</b>	<b>\$</b>	<b>\$</b>	<b>%</b>
<b>Distribution Plant</b>				
1805 Land - Substations	385,690	385,690	-	0%
1806 / 1612 Land Rights	366,233	383,514	17,281	5%
1808 Buildings - Substations	1,128,336	1,128,336	-	0%
1820 /1610 Substation Equipment	17,123,890	17,396,761	272,871	2%
1830 Poles, Towers & Fixtures	39,738,167	41,662,934	1,924,767	5%
1835 OH Conductors & Devices	55,136,846	58,467,100	3,330,254	6%
1840 UG Conduit	35,698,363	38,211,108	2,512,744	7%
1845 UG Conductor & Devices	101,576,155	96,726,669	(4,849,487)	-5%
1850 Line Transformers	79,632,662	83,540,538	3,907,876	5%
1855 Services (OH & UG)	24,720,934	27,008,301	2,287,367	9%
1860 Meters	25,081,481	25,774,558	693,077	3%
	<b>380,588,758</b>	<b>390,685,509</b>	<b>10,096,751</b>	<b>3%</b>
<b>General Plant</b>				
1908 Buildings & Fixtures	22,091,652	22,780,090	688,438	3%
1910 Leasehold Improvements	-	-	-	
1915 Office Furniture & Equipment	731,859	732,848	990	0%
1930 Transportation Equipment	11,472,907	11,826,499	353,592	3%
1935 Stores Equipment	278,138	273,759	(4,379)	-2%
1940 Tools, Shop & Garage Equipment	1,023,409	1,040,004	16,595	2%
1945 Measurement & Testing Equipment	119,614	202,476	82,862	69%
1950 Power Operated Equipment	931,471	951,281	19,810	2%
1955 Communication Equipment	3,756,098	3,992,791	236,693	6%
1960 Miscellaneous Equipment	-	-	-	
1980 System Supervisory Equipment	2,154,497	2,439,074	284,577	13%
	<b>42,559,643</b>	<b>44,238,822</b>	<b>1,679,179</b>	<b>4%</b>
<b>Information Systems</b>				
1920 Computer - Hardware	3,200,325	3,381,156	180,831	6%
1925 /1611 Computer - Software	28,241,375	32,132,701	3,891,326	14%
	<b>31,441,700</b>	<b>35,513,857</b>	<b>4,072,157</b>	<b>13%</b>
	-	-	-	
<b>Total Gross Balance before Contributed Capital</b>	<b>454,590,101</b>	<b>470,438,188</b>	<b>15,848,087</b>	<b>3%</b>
1995 /2440 Contributions and Grants	(39,262,043)	(41,132,735)	(1,870,692)	5%
<b>Total</b>	<b>415,328,059</b>	<b>429,305,453</b>	<b>13,977,395</b>	<b>3.4%</b>



1 *Distribution Plant: Variance \$10,096,751*

2 *Variance attributable to Additions: \$19,166,621. Variance attributable to Disposals: (\$9,069,870).*

3 In 2014, Actual Distribution Plant assets were higher than 2013 Actual amounts by \$10,096,751.

4 Details regarding this variance are described below:

- 5 • Capital spending for demand driven road relocations throughout the City of London was  
6 \$1,542,380 in 2014, which resulted in increased investments primarily in Poles and  
7 Fixtures and Overhead Conductors and Devices (Accounts 1830 – 1835).
- 8 • Capital spending for Developer Works Projects, such as new residential subdivisions  
9 and condominiums, commercial connections and overhead line expansions, was  
10 \$5,084,680.
- 11 • Capital spending for silicone injection of underground cable and conversions with  
12 silicone injection was \$3,303,086 in 2014, which resulted in increased investments in  
13 Underground Conduits and Underground Conductors and Devices (Accounts 1840 –  
14 1845).
- 15 • Fully-depreciated Underground Conductors and Devices with an original cost of  
16 \$8,793,672 were disposed of in 2014. The majority of this cost (\$8,591,828) represents  
17 direct-buried cable.

18 *1908 Buildings and Fixtures: Variance \$688,438*

19 *Variance attributable to Additions: \$1,123,130. Variance attributable to Disposals: (\$434,692).*

20 The following major projects relating to Buildings and Fixtures occurred in 2014:

- 21 • Second phase of paving in the Administration parking lots
- 22 • Replacement of windows in the Administration building due to broken seals
- 23 • Cafeteria renovation
- 24 • Transfer switch replacement in the Operations building
- 25 • Construction of the smart meter validation lab in the Electric Meter Department

26 Fully-depreciated assets that were removed from the gross asset balance in 2014 were  
27 \$434,692. Most of this pertains to the (previous) paved Operations yard parking lot and the  
28 Administration building roof.

29



1 For more information regarding capital spending for Buildings and Fixtures, refer to Page 113.

2 *1930 Transportation Equipment: Variance \$353,592*

3 *Variance attributable to Additions: \$686,041. Variance attributable to Disposals: (\$332,449).*

4 The following major projects relating to Transportation Equipment occurred in 2014:

- 5 • Purchase of one radial boom derrick (RBD) and one dump truck
- 6 • An increase in small vehicle purchases in 2014 compared to 2013 (individually less
- 7 expensive)

8 Transportation Equipment disposals included the sale of a fully-depreciated flat deck truck, a  
9 dump truck and a van with original costs totalling \$249,379.

10 For more information regarding capital spending for Vehicles and Major Equipment, refer to  
11 Page 107.

12 *1925 /1611 Computer - Software: Variance \$3,891,326*

13 *Variance attributable to Additions: \$4,120,230. Variance attributable to Disposals: (\$228,904).*

14 The following major software projects went live in 2014:

- 15 • CRM Version 7 upgrade - Customer Relations Management Software
- 16 • MyLondonHydro customer portal and Corporate Website
- 17 • Outage Management System
- 18 • Mobile Workforce Deployment Phase 1

19 Fully-depreciated assets that were removed from the gross asset balance in 2014 amounted to  
20 \$228,904.

21 For more information regarding capital spending for Information Services, refer to Page 118.

22

1 **2014 Actuals vs. 2015 Actuals**

2 London Hydro's gross asset balances increased by \$4,538,183, or 1.1%, between the 2014 and  
3 2015 Actuals. See Table 2-8 below for a breakdown of gross asset balances by function and  
4 major plant account.

5 **Table 2-8 –2014 Actuals vs. 2015 Actuals Gross Assets by Account**

<b>GROSS ASSET VARIANCE ANALYSIS</b>				
<b>2014 ACTUALS vs. 2015 ACTUALS</b>				
	<b>2014</b>	<b>2015</b>	<b>Variance</b>	<b>Variance</b>
	<b>Actual</b>	<b>Actual</b>		
	<b>\$</b>	<b>\$</b>	<b>\$</b>	<b>%</b>
<b>Distribution Plant</b>				
1805 Land - Substations	385,690	385,690	-	0%
1806 / 1612 Land Rights	383,514	414,759	31,245	8%
1808 Buildings - Substations	1,128,336	1,128,336	-	0%
1820 /1610 Substation Equipment	17,396,761	17,563,552	166,791	1%
1830 Poles, Towers & Fixtures	41,662,934	43,125,558	1,462,624	4%
1835 OH Conductors & Devices	58,467,100	61,194,389	2,727,289	5%
1840 UG Conduit	38,211,108	43,296,851	5,085,744	13%
1845 UG Conductor & Devices	96,726,669	90,803,781	(5,922,888)	-6%
1850 Line Transformers	83,540,538	89,220,013	5,679,475	7%
1855 Services (OH & UG)	27,008,301	29,459,220	2,450,919	9%
1860 Meters	25,774,558	26,831,646	1,057,088	4%
	<b>390,685,509</b>	<b>403,423,795</b>	<b>12,738,286</b>	<b>3%</b>
<b>General Plant</b>				
1908 Buildings & Fixtures	22,780,090	23,396,955	616,865	3%
1910 Leasehold Improvements	-	-	-	
1915 Office Furniture & Equipment	732,848	520,905	(211,944)	-29%
1930 Transportation Equipment	11,826,499	12,813,264	986,765	8%
1935 Stores Equipment	273,759	267,598	(6,161)	-2%
1940 Tools, Shop & Garage Equipment	1,040,004	941,130	(98,874)	-10%
1945 Measurement & Testing Equipment	202,476	516,606	314,130	155%
1950 Power Operated Equipment	951,281	1,032,283	81,002	9%
1955 Communication Equipment	3,992,791	4,064,185	71,394	2%
1960 Miscellaneous Equipment	-	4,039	4,039	
1980 System Supervisory Equipment	2,439,074	3,385,233	946,159	39%
	<b>44,238,822</b>	<b>46,942,197</b>	<b>2,703,375</b>	<b>6%</b>
<b>Information Systems</b>				
1920 Computer - Hardware	3,381,156	2,523,106	(858,051)	-25%
1925 /1611 Computer - Software	32,132,701	25,875,825	(6,256,876)	-19%
	<b>35,513,857</b>	<b>28,398,931</b>	<b>(7,114,926)</b>	<b>-20%</b>
<b>Total Gross Balance before Contributed Capital</b>	<b>470,438,188</b>	<b>478,764,923</b>	<b>8,326,735</b>	<b>2%</b>
1995 /2440 Contributions and Grants	(41,132,735)	(44,921,286)	(3,788,551)	9%
<b>Total</b>	<b>429,305,453</b>	<b>433,843,637</b>	<b>4,538,183</b>	<b>1.1%</b>

6





1 *Fully-Depreciated Asset Disposals*

2 Prior to 2015, London Hydro had a practice of waiting until the subsequent year (following the  
3 year in which an asset was fully-depreciated) to dispose of the asset and its accumulated  
4 depreciation. In 2015, this practice was updated, and fully-depreciated assets are now disposed  
5 of in the current year. This essentially resulted in the disposing of two years' worth of assets in a  
6 single year.

7 *Distribution Plant: Variance \$12,738,286*

8 *Variance attributable to Additions: \$23,920,783. Variance attributable to Disposals: (\$11,182,497).*

9 In 2015, Actual Distribution Plant assets were higher than 2014 Actual amounts by \$12,738,286.  
10 Details regarding this variance are described below:

- 11 • Capital spending for City of London-driven road relocations was \$1,968,293 in 2015,  
12 which resulted in increased investments primarily in Poles and Fixtures and Overhead  
13 Conductors and Devices (Accounts 1830 – 1835).
- 14 • Increases in Underground Conduits, Underground Conductors and Devices, Line  
15 Transformers, Services and Meters (Accounts 1840 – 1860) are primarily due to new  
16 customer connections and residential developments. Capital spending for these  
17 Developer Works Projects was \$6,017,328 in 2015.
- 18 • Additionally, an increase of \$1,404,237 in Underground Conduit (Account 1840) is a  
19 result of substantial investments in encased duct and maintenance hole structures along  
20 Dufferin Avenue and Simcoe Street.
- 21 • Capital spending for the replacement of depreciated and leaking transformers was  
22 \$825,693 in 2015, which resulted in increased investments in Line Transformers  
23 (Account 1850).
- 24 • Fully-depreciated disposals were \$11,182,497. The majority of this was the disposal of  
25 direct buried cable with an original cost of \$10,629,890.

26 *1908 Buildings and Fixtures: Variance \$616,865*

27 *Variance attributable to Additions: \$673,316. Variance attributable to Disposals: (\$56,452).*

28 The following major projects relating to Buildings and Fixtures occurred in 2015:

- 29 • Relocation of data centre switches, wiring and racks as per distance from electrical  
30 equipment requirements per the Ontario Electrical Code



- 1 • New drive-on hoist for garage; the old hoist could not accommodate newer vehicles
- 2 • HVAC upgrades
- 3 • New fuel inventory system

4 For more information regarding capital spending for Buildings and Fixtures, refer to Page 113.

5 *1930 Transportation Equipment: Variance \$986,765*

6 *Variance attributable to Additions: \$1,150,226. Variance attributable to Disposals: (\$163,461).*

7 Significant additions to Transportation Equipment in 2015 included 3 bucket trucks (\$916,961),  
8 an Electric Meter truck and an EUS Truck (\$185,236) and 2 trailers (\$14,351).

9 Disposals included the sale of a fully-depreciated radial boom derrick (RBD) truck and a trailer  
10 with original costs totalling \$163,461.

11 For more information regarding capital spending for Vehicles and Major Equipment, refer to  
12 Page 107.

13 *1945 Measurement & Testing Equipment: Variance \$314,130*

14 *Variance attributable to Additions: \$316,421. Variance attributable to Disposals: (\$2,290).*

15 The following major projects relating to Measurement and Testing Equipment occurred in 2015:

- 16 • Smart meter validation lab
- 17 • Measurement Canada test console

18 For more information regarding capital spending for Metering, refer to Page 85.

19 *1980 System Supervisory Equipment: Variance \$946,159*

20 *Variance attributable to Additions: \$946,159.*

21 The following major projects relating to System Supervisory Equipment occurred in 2015:

- 22 • Network temperature monitoring and infrastructure
- 23 • New Remote Terminal Unit (RTU) control cabinets
- 24 • Various FIT connections

25 For more information regarding capital spending for Automation, refer to Page 71.



1 *1920 Computer – Hardware: Variance (\$858,051)*

2 *Variance attributable to Additions: \$631,317. Variance attributable to Disposals: (\$1,489,367).*

3 Approximately \$631,317 of additions was capitalized in 2015, covering items such as desktops,  
4 mobile devices and wireless networks.

5 Fully-depreciated assets that were removed from the gross asset balance in 2015 amounted to  
6 \$1,489,367.

7 For more information regarding capital spending for Information Services, refer to Page 118.

8 *1925 /1611 Computer - Software: Variance (\$6,256,876)*

9 *Variance attributable to Additions: \$4,995,403. Variance attributable to Disposals: (\$11,252,279).*

10 The following major software projects went live in 2015:

- 11 • Human Resources Information System (HRIS)
- 12 • Customer Engagement Web Enhancements
- 13 • Field Workforce Automation
- 14 • Interval Data Centre 2
- 15 • Cyber security & disaster recovery

16 Fully-depreciated assets that were removed from the gross asset balance in 2015 amounted to  
17 \$11,252,279. Most of these items related to the billing system, which had a five-year estimated  
18 useful life. The transition to more Cloud-based services is resulting in less capital investment in  
19 Hardware and Software.

20 For more information regarding capital spending for Information Services, refer to Page 118.

21

1 **2015 Actuals vs. 2016 Bridge**

2 London Hydro's gross asset balances are budgeted to increase by \$17,866,469, or 4.1%,  
 3 between the 2015 Actuals and the 2016 Bridge Year. See Table 2-9 below for breakdown of  
 4 gross asset balances by function and major plant account.

5 **Table 2-9 –2015 Actuals vs. 2016 Bridge Year Gross Assets by Account**

<b>GROSS ASSET VARIANCE ANALYSIS</b>				
<b>2015 ACTUALS vs. 2016 BRIDGE</b>				
	<b>2015</b>	<b>2016</b>	<b>Variance</b>	<b>Variance</b>
	<b>Actual</b>	<b>Bridge</b>		
	<b>\$</b>	<b>\$</b>	<b>\$</b>	<b>%</b>
<b>Distribution Plant</b>				
1805 Land - Substations	385,690	385,690	-	0%
1806 / 1612 Land Rights	414,759	414,759	-	0%
1808 Buildings - Substations	1,128,336	1,168,336	40,000	4%
1820 /1610 Substation Equipment	17,563,552	17,679,652	116,100	1%
1830 Poles, Towers & Fixtures	43,125,558	45,079,658	1,954,100	5%
1835 OH Conductors & Devices	61,194,389	64,476,589	3,282,200	5%
1840 UG Conduit	43,296,851	47,849,151	4,552,300	11%
1845 UG Conductor & Devices	90,803,781	90,510,422	(293,359)	0%
1850 Line Transformers	89,220,013	93,490,013	4,270,000	5%
1855 Services (OH & UG)	29,459,220	30,974,120	1,514,900	5%
1860 Meters	26,831,646	27,925,246	1,093,600	4%
	<b>403,423,795</b>	<b>419,953,636</b>	<b>16,529,841</b>	<b>4%</b>
<b>General Plant</b>				
1908 Buildings & Fixtures	23,396,955	24,500,503	1,103,548	5%
1910 Leasehold Improvements	-	-	-	-
1915 Office Furniture & Equipment	520,905	797,931	277,026	53%
1930 Transportation Equipment	12,813,264	13,219,310	406,046	3%
1935 Stores Equipment	267,598	345,540	77,943	29%
1940 Tools, Shop & Garage Equipment	941,130	989,586	48,456	5%
1945 Measurement & Testing Equipment	516,606	726,606	210,000	41%
1950 Power Operated Equipment	1,032,283	1,032,283	-	0%
1955 Communication Equipment	4,064,185	4,834,685	770,500	19%
1960 Miscellaneous Equipment	4,039	4,039	-	0%
1980 System Supervisory Equipment	3,385,233	3,716,233	331,000	10%
	<b>46,942,197</b>	<b>50,166,717</b>	<b>3,224,519</b>	<b>7%</b>
<b>Information Systems</b>				
1920 Computer - Hardware	2,523,106	1,763,237	(759,869)	-30%
1925 /1611 Computer - Software	25,875,825	26,834,803	958,978	4%
	<b>28,398,931</b>	<b>28,598,040</b>	<b>199,109</b>	<b>1%</b>
<b>Total Gross Balance before Contributed Capital</b>	<b>478,764,923</b>	<b>498,718,392</b>	<b>19,953,469</b>	<b>4%</b>
1995 /2440 Contributions and Grants	(44,921,286)	(47,008,286)	(2,087,000)	5%
<b>Total</b>	<b>433,843,637</b>	<b>451,710,106</b>	<b>17,866,469</b>	<b>4.1%</b>



1 *Distribution Plant: Variance \$16,529,841*

2 *Variance attributable to Additions: \$22,720,500. Variance attributable to Disposals: (\$6,190,659).*

3 Distribution Plant assets in the 2016 Bridge Year are projected to be higher than 2015 Actual  
4 amounts by \$16,529,841. Details regarding this variance are described below:

- 5 • Capital spending for City of London-driven road relocations is planned to be \$1,996,000  
6 in 2016, which will result in increased investments primarily in Poles and Fixtures and  
7 Overhead Conductors and Devices (Accounts 1830 – 1835).
- 8 • Capital spending for Developer Works Projects, such as new residential subdivisions  
9 and condominiums, commercial connections and overhead line expansions, is planned  
10 to be \$4,258,000.
- 11 • Capital spending for Main Feeder Conversions, Backup Supply and Civil Structure  
12 Installation is planned to be \$3,982,000 in 2016, and is focused on the downtown core in  
13 preparation for the Nelson TS conversion. This spending results primarily in increased  
14 investments in Poles and Fixtures, Overhead Conductors and Devices and Underground  
15 Conduits (Accounts 1830 – 1840).
- 16 • Regular capital projects for Subdivision Rebuilds account for \$5,102,000 in capital  
17 spending in 2016. This spending results primarily in increased investments in  
18 Underground Conduits, Underground Conductors and Devices, Line Transformers and  
19 Services (Accounts 1840 – 1855).
- 20 • Fully-depreciated asset disposals are planned to be \$6,190,659, which accounts for the  
21 disposal of direct buried cable.

22 *1908 Buildings and Fixtures: Variance \$1,103,548*

23 *Variance attributable to Additions: \$1,160,000. Variance attributable to Disposals: (\$56,452).*

24 The following major projects relating to Buildings and Fixtures are budgeted for 2016:

- 25 • Replacement of elevators and associated control systems
- 26 • Control Room renovations - Phase 2
- 27 • HVAC equipment replacements

28 For more information regarding capital spending for Buildings and Fixtures, refer to Page 113.



1 *1930 Transportation Equipment: Variance \$406,046*

2 *Variance attributable to Additions: \$1,130,000. Variance attributable to Disposals: (\$723,954).*

3 The following major items relating to Transportation Equipment are budgeted for 2016:

- 4 • 4 pickup trucks
- 5 • 5 SUV's
- 6 • 1 dump truck
- 7 • 1 commercial van
- 8 • 1 aerial bucket truck

9 Fully-depreciated assets that are budgeted to be removed from the gross asset balance in 2016  
10 amount to \$723,954 and include items such as one flat deck, one bucket truck, five SUV's, four  
11 pickup trucks and one dump truck.

12 For more information regarding capital spending for Vehicles and Major Equipment, refer to  
13 Page 107.

14 *1955 Communication Equipment: Variance \$770,500*

15 *Variance attributable to Additions: \$770,500.*

16 The majority of the budget for Communication Equipment (\$625,000) pertains to the AMI  
17 Communications Renewal project. More information about this project can be found within the  
18 Metering Section of this Exhibit, Page 85.

19 *1980 System Supervisory Equipment: Variance \$331,000*

20 *Variance attributable to Additions: \$331,000.*

21 The following major projects relating to System Supervisory Equipment are budgeted for 2016:

- 22 • New RTU control cabinets
- 23 • Control centre consoles and digital schematics

24 For more information regarding capital spending for Automation, refer to Page 71.



1 1920 Computer – Hardware: Variance (\$759,869)

2 Variance attributable to Additions: \$323,200. Variance attributable to Disposals: (\$1,083,069).

3 Approximately \$323,200 of additions is budgeted to be capitalized in 2016, covering items such  
4 as desktops, servers and networks.

5 Fully-depreciated assets that are scheduled to be removed from the gross asset balance in  
6 2016 amount to \$1,083,069.

7 Refer to Page 118 within this Exhibit for more information regarding capital spending and capital  
8 projects for Information Technology.

9 1925 /1611 Computer - Software: Variance \$958,978

10 Variance attributable to Additions: \$4,551,800. Variance attributable to Disposals: (\$3,592,822).

11 The following major software projects are scheduled to go live in 2016:

- 12 • Bill print upgrade
- 13 • Builders' Portal and Property Management Portal
- 14 • OMS upgrade
- 15 • Customer engagement website enhancements
- 16 • Mobile Workforce Phase 3
- 17 • Operating software servers and networks
- 18 • Fleet maintenance system
- 19 • Cyber security, disaster recovery, end-point security

20 Fully-depreciated assets that are scheduled to be removed from the gross asset balance in  
21 2016 amount to \$3,592,822. Most of this pertains to billing system enhancements and an IVR  
22 phone system.

23 Refer to Page 118 within this Exhibit for more information regarding Information Technology  
24 capital spending & capital projects.

25

1 **2016 Bridge vs. 2017 Test**

2 London Hydro's gross asset balances are budgeted to increase by \$17,608,903, or 3.9%,  
 3 between the 2016 Bridge Year and the 2017 Test Year. See Table 2-10 below for a breakdown  
 4 of gross asset balances by function and major plant account.

5 **Table 2-10 –2016 Bridge Year vs. 2017 Test Year Gross Assets by Account**

<b>GROSS ASSET VARIANCE ANALYSIS</b>				
<b>2016 BRIDGE vs. 2017 TEST</b>				
	<b>2016</b>	<b>2017</b>	<b>Variance</b>	<b>Variance</b>
	<b>Bridge</b>	<b>Test</b>		
	<b>\$</b>	<b>\$</b>	<b>\$</b>	<b>%</b>
<b>Distribution Plant</b>				
1805 Land - Substations	385,690	385,690	-	0%
1806 / 1612 Land Rights	414,759	414,759	-	0%
1808 Buildings - Substations	1,168,336	1,210,336	42,000	4%
1820 /1610 Substation Equipment	17,679,652	17,794,152	114,500	1%
1830 Poles, Towers & Fixtures	45,079,658	47,273,458	2,193,800	5%
1835 OH Conductors & Devices	64,476,589	67,987,489	3,510,900	5%
1840 UG Conduit	47,849,151	52,171,051	4,321,900	9%
1845 UG Conductor & Devices	90,510,422	92,535,816	2,025,394	2%
1850 Line Transformers	93,490,013	97,784,813	4,294,800	5%
1855 Services (OH & UG)	30,974,120	32,569,920	1,595,800	5%
1860 Meters	27,925,246	29,038,746	1,113,500	4%
	<b>419,953,636</b>	<b>439,166,230</b>	<b>19,212,594</b>	<b>5%</b>
<b>General Plant</b>				
1908 Buildings & Fixtures	24,500,503	23,096,571	(1,403,932)	-6%
1910 Leasehold Improvements	-	-	-	
1915 Office Furniture & Equipment	797,931	860,704	62,773	8%
1930 Transportation Equipment	13,219,310	13,589,831	370,522	3%
1935 Stores Equipment	345,540	234,972	(110,569)	-32%
1940 Tools, Shop & Garage Equipment	989,586	1,020,795	31,209	3%
1945 Measurement & Testing Equipment	726,606	865,590	138,984	19%
1950 Power Operated Equipment	1,032,283	1,106,979	74,696	7%
1955 Communication Equipment	4,834,685	5,582,185	747,500	15%
1960 Miscellaneous Equipment	4,039	4,039	-	0%
1980 System Supervisory Equipment	3,716,233	4,006,818	290,585	8%
	<b>50,166,717</b>	<b>50,368,484</b>	<b>201,767</b>	<b>0%</b>
<b>Information Systems</b>				
1920 Computer - Hardware	1,763,237	632,829	(1,130,408)	-64%
1925 /1611 Computer - Software	26,834,803	28,260,752	1,425,949	5%
	<b>28,598,040</b>	<b>28,893,581</b>	<b>295,541</b>	<b>1%</b>
<b>Total Gross Balance before Contributed Capital</b>	<b>498,718,392</b>	<b>518,428,295</b>	<b>19,709,903</b>	<b>4%</b>
1995 /2440 Contributions and Grants	(47,008,286)	(49,109,286)	(2,101,000)	4%
<b>Total</b>	<b>451,710,106</b>	<b>469,319,009</b>	<b>17,608,903</b>	<b>3.9%</b>





1 *Distribution Plant: Variance \$19,212,594*

2 *Variance attributable to Additions: \$22,717,900. Variance attributable to Disposals: (\$3,505,306).*

3 Distribution Plant assets in the 2017 Test Year are projected to be higher than 2016 Bridge Year  
4 by \$19,212,594. Details regarding this variance are described below:

- 5 • Capital spending for City of London-driven road relocations is budgeted to be  
6 \$2,250,900 in 2017, which will result in increased investments primarily in Poles and  
7 Fixtures and Overhead Conductors and Devices (Accounts 1830 – 1835). The City of  
8 London is following a multi-year plan to meet the City's growing transportation needs and  
9 new developments, which will result in increased capital spending for City-requested  
10 relocations and, therefore, increased investments in the aforementioned assets.
- 11 • Capital spending for Overhead Line Work is budgeted to be \$4,530,000 for 2017, which  
12 will result in increased investments primarily in Poles and Fixtures, Overhead  
13 Conductors and Devices, Line Transformers, and Services (Accounts 1830, 1835, 1850  
14 and 1855). A total of \$3,280,000 of this amount is attributable to Overhead Voltage  
15 Conversions required to convert 13.8 kV overhead load to 27.6 kV and rebuild/convert  
16 all 4.16kV plant within Zones 'A', 'B', & 'C'.
- 17 • Increases in Underground Conduits, Underground Conductors and Devices, Line  
18 Transformers, Services and Meters (Accounts 1840 – 1860) are primarily due to new  
19 customer connections and residential developments. Capital spending for these  
20 Developer Works Projects is budgeted to be \$4,519,100 in 2017.
- 21 • Increases in Underground Conduits and Underground Conductors and Devices are also  
22 attributable to capital spending in 2017 of \$3,375,000 for Main Feeders and \$2,070,000  
23 for Networks. The City of London will be conducting extensive infrastructure  
24 rehabilitation in the downtown core beginning in 2017. In conjunction with the City's  
25 projects, London Hydro will install concrete-encased duct and maintenance hole  
26 systems.
- 27 • Regular capital projects for Subdivision Rebuilds account for \$4,389,000 in Capital  
28 spending. These projects result primarily in increased investments in Underground  
29 Conduits, Underground Conductors and Devices, Line Transformers and Services  
30 (Accounts 1840 – 1855).



- 1       • Disposals of \$3,505,306 include fully-depreciated direct buried cable with an original  
2       cost of \$3,414,144 and fully-depreciated air-insulated switchgear with an original cost of  
3       \$91,161.

4    *1908 Buildings and Fixtures: Variance (\$1,403,932)*

5    *Variance attributable to Additions: \$870,000. Variance attributable to Disposals: (\$2,273,932).*

6    The following major projects relating to Buildings and Fixtures are budgeted for 2017:

- 7       • Paving  
8       • Control Room renovations Phase 3  
9       • HVAC equipment replacements  
10      • Energy savings lighting & controls

11   Fully-depreciated assets that are scheduled to be removed from the gross asset balance in  
12   2017 amount to \$2,273,932. Most of these assets pertain to electrical/mechanical systems in  
13   the Administration building and Stores area.

14   For more information regarding capital spending for Buildings and Fixtures, refer to Page 113.

15   *1930 Transportation Equipment: Variance \$370,522*

16   *Variance attributable to Additions: \$924,000. Variance attributable to Disposals: (\$553,478).*

17   The following major items relating to Transportation Equipment are budgeted for 2017:

- 18      • 4 pickup trucks  
19      • 1 SUV  
20      • 1 commercial van  
21      • 1 double bucket truck  
22      • 2 trailers

23   Fully-depreciated assets that are budgeted to be removed from the gross asset balance in 2017  
24   amount to \$553,478 and include items such as one bucket truck, four SUV's, one pickup truck  
25   and one dump truck.

26   For more information regarding capital spending for Vehicles and Major Equipment, refer to  
27   Page 107.



1 *1955 Communication Equipment: Variance \$747,500*

2 *Variance attributable to Additions: \$747,500.*

3 The majority of the budget for Communication Equipment (\$649,000) pertains to the AMI  
4 Communications Renewal project. More information on this project can be found in the Metering  
5 Section of this Exhibit, Page 85.

6 *1920 Computer – Hardware: Variance (\$1,130,408)*

7 *Variance attributable to Additions: \$297,200. Variance attributable to Disposals: (\$1,427,608).*

8 Approximately \$297,200 of additions is budgeted to be capitalized in 2017, covering items such  
9 as desktops, servers and networks.

10 Fully-depreciated assets that are budgeted to be removed from the gross asset balance in 2017  
11 amount to \$1,427,608.

12 Refer to Page 118 within this Exhibit for more information regarding capital spending and capital  
13 projects for Information Technology.

14 *1925 /1611 Computer - Software: Variance \$1,425,949*

15 *Variance attributable to Additions: \$4,082,697 (including regulatory deferrals). Variance attributable to*  
16 *Disposals: (\$2,656,748).*

17 The following major software projects are scheduled to go live in 2017:

- 18 • ODS upgrade
- 19 • HRIS enhancements
- 20 • Automated billing payments
- 21 • Miscellaneous operating software servers & networks
- 22 • Field timesheet automation
- 23 • Residential customer mobile app
- 24 • C&I optimization apps

25 Additionally, \$419,897 is budgeted to be transferred from the Smart Grid Regulatory Deferral  
26 account into gross assets in 2017.

27 Fully-depreciated assets that are scheduled to be removed from the gross asset balance in  
28 2017 amount to \$2,656,748. Most of these items pertain to the GIS system.



1 Refer to Page 118 within this Exhibit for more information regarding capital spending and capital  
2 projects for Information Technology.

3 **Change in Accumulated Depreciation**

4 Accumulated depreciation increased by \$3,953,376 between the 2013 Board Approved Year  
5 and the 2017 Test Year. See Table 2-11 below for annual accumulated depreciation balances,  
6 broken down by major plant account. Fluctuations by category are as follows:

- 7       • \$9,114,927 increase to accumulated depreciation on Distribution Plant assets  
8       • \$120,333 increase to accumulated depreciation on General Plant assets  
9       • \$766,650 decrease to accumulated depreciation on Information Systems assets  
10       • \$4,136,335 increase (credit) to accumulated depreciation on Contributed Capital

11 Further discussion regarding depreciation and estimated useful lives can be found within Exhibit  
12 4 of this Rate Application, Section 'Depreciation and Amortization Expense', Page 379.



1

**Table 2-11 – Accumulated Depreciation Balances 2013 to 2017**

ACCUMULATED DEPRECIATION BALANCES 2013 TO 2017							
	2013 Actual	2013 Board Approved	2014 Actual	2015 Actual	2016 Bridge	2017 Test	2013 OEB Approved to 2017 Test
	\$	\$	\$	\$	\$	\$	\$
<b>Distribution Plant</b>							
1805 Land - Substations	-	-	-	-	-	-	-
1806 / 1612 Land Rights	180,897	178,584	198,161	215,730	234,445	253,160	74,576
1808 Buildings - Substations	713,458	715,456	724,552	735,645	747,005	758,911	43,455
1820 /1610 Substation Equipment	6,752,604	6,769,195	7,069,017	7,392,247	7,718,198	8,047,617	1,278,422
1830 Poles, Towers & Fixtures	19,132,710	19,164,055	19,735,070	20,372,416	21,056,938	21,787,548	2,623,493
1835 OH Conductors & Devices	22,386,713	20,557,706	23,219,310	24,114,383	25,082,792	26,120,756	5,563,050
1840 UG Conduit	9,483,834	9,537,815	10,010,139	10,597,956	11,298,459	12,079,367	2,541,553
1845 UG Conductor & Devices	54,734,965	60,722,839	49,578,787	42,149,108	39,353,720	39,250,228	(21,472,611)
1850 Line Transformers	30,979,674	28,587,886	32,854,306	34,862,679	37,042,460	39,352,241	10,764,355
1855 Services (OH & UG)	8,049,275	8,206,786	8,590,057	9,181,004	9,835,804	10,530,901	2,324,115
1860 Meters	7,986,510	8,168,764	9,147,072	10,377,857	11,927,391	13,543,285	5,374,521
	160,400,641	162,609,086	161,126,469	159,999,024	164,297,211	171,724,013	9,114,927
<b>General Plant</b>							
1908 Buildings & Fixtures	10,359,435	12,440,217	10,817,099	11,679,716	12,575,948	11,047,245	(1,392,972)
1910 Leasehold Improvements	-	-	-	-	-	-	-
1915 Office Furniture & Equipment	420,900	632,647	430,567	261,650	225,883	270,894	(361,753)
1930 Transportation Equipment	6,290,330	6,336,700	6,663,503	7,254,516	7,424,086	7,821,505	1,484,805
1935 Stores Equipment	261,042	246,114	259,809	259,681	265,052	151,731	(94,383)
1940 Tools, Shop & Garage Equipment	522,561	708,772	532,264	466,399	485,999	487,693	(221,079)
1945 Measurement & Testing Equipment	25,264	(1,517)	42,427	73,712	151,456	239,264	240,781
1950 Power Operated Equipment	434,483	626,751	486,198	530,978	656,884	687,458	60,707
1955 Communication Equipment	875,181	908,656	1,105,729	1,353,714	1,627,712	1,943,759	1,035,103
1960 Miscellaneous Equipment	-	-	-	42	547	1,052	1,052
1980 System Supervisory Equipment	663,896	2,036,216	801,234	963,629	1,177,101	1,404,289	(631,927)
	19,853,091	23,934,556	21,138,831	22,844,038	24,590,668	24,054,889	120,333
<b>Information Systems</b>							
1920 Computer - Hardware	1,236,614	1,885,252	1,929,035	1,399,030	1,063,991	109,433	(1,775,819)
1925 /1611 Computer - Software	14,050,010	16,254,378	19,038,934	12,763,442	14,830,128	17,263,547	1,009,169
	15,286,625	18,139,630	20,967,970	14,162,472	15,894,119	17,372,980	(766,650)
<b>Total Gross Balance before Contributed Capital</b>	<b>195,540,357</b>	<b>204,683,272</b>	<b>203,233,270</b>	<b>197,005,534</b>	<b>204,781,998</b>	<b>213,151,882</b>	<b>8,468,610</b>
1995 /2440 Contributions and Grants	(8,616,349)	(8,565,838)	(9,536,861)	(10,515,283)	(11,582,553)	(12,702,173)	(4,136,335)
	<b>186,924,008</b>	<b>196,117,434</b>	<b>193,696,409</b>	<b>186,490,251</b>	<b>193,199,445</b>	<b>200,449,709</b>	<b>4,332,275</b>

2

3



## 1 **Capital Additions Reconciliation to Capital Spending**

2 In order to provide for a more accurate correlation between capital activities and associated  
3 explanations, the discussions that follow in this Exhibit are directed at capital spending rather  
4 than capital additions.

5 Capital additions are difficult to discuss at a high level due to the following factors:

- 6     ➤ Changes in work-in-progress;
- 7     ➤ One capital project can be capitalized to many different capital asset accounts. For  
8       example, upon completion, one project may be capitalized to various accounts such as  
9       Services, Overhead Conductor and Devices, Underground Conductor and Devices,  
10      Poles, Towers and Fixtures; and
- 11    ➤ Capital additions differ from capital spending in a given year since only projects that are  
12      complete and in service are added to rate base as a capital addition. Projects that are  
13      not complete at the end of the year remain in work-in-progress.

14 Capital spending is less complicated as it simply represents the dollars spent in a given year  
15 without any adjustment for projects that remain in work-in-progress. Capital spending  
16 discussions are based on specific projects rather than on the many fixed asset accounts that  
17 projects are allocated to upon completion. In addition, discussing capital spending makes it  
18 easier to segregate those expenditures that are a result of developer and customer demand  
19 (e.g., the City of London), compared to those that are completed at London Hydro's discretion.

20 Table 2-12 below has been provided to display and reconcile the difference between capital  
21 additions and capital spending due to changes in work-in-progress (WIP). Further, Table 2-13  
22 contains details of annual WIP balances.

23 Variance analysis at a capital expenditure level is completed further in this Exhibit, commencing  
24 on Page 34.

25

1

**Table 2-12 – Reconciliation of Capital Additions to Capital Spending**

<b>RECONCILIATION OF CAPITAL ADDITIONS TO CAPITAL SPENDING 2013 - 2017</b>						
	<b>2013 Actual</b>	<b>2013 Board Approved</b>	<b>2014 Actual</b>	<b>2015 Actual</b>	<b>2016 Bridge</b>	<b>2017 Test</b>
	\$	\$	\$	\$	\$	\$
Net Additions to Fixed Assets	21,772,739	25,153,400	24,651,127	29,237,293	29,800,000	28,092,000
Work-in-progress, beginning of year	(6,707,278)	(10,422,102)	(10,225,904)	(10,653,337)	(12,128,580)	(13,960,580)
Work-in-progress, end of year	10,225,904	10,422,102	10,653,337	12,128,580	13,960,580	16,342,580
	3,518,625	0	427,433	1,475,243	1,832,000	2,382,000
Net Capital Spending	25,291,364	25,153,400	25,078,561	30,712,535	31,632,000	30,474,000

2

3

**Table 2-13 – Work-In-Progress by Project Category 2013 to 2017**

<b>WORK IN PROGRESS 2013 - 2017 SUMMARY BY CATEGORY</b>						
<b>Annual Spending</b>	<b>2013 Actual</b>	<b>2013 Board Approved</b>	<b>2014 Actual</b>	<b>2015 Actual</b>	<b>2016 Bridge</b>	<b>2017 Test</b>
	\$	\$	\$	\$	\$	\$
<b>Infrastructure</b>						
Substation Rebuilds	198,344	482,830	193,303	330,695	330,695	330,695
Subdivision Rebuilds	2,081,005	924,815	1,988,872	966,879	966,879	966,879
Main Feeders	124,541	450,794	694,495	578,267	578,267	578,267
Networks	65,695	619,431	559,587	600,075	600,075	600,075
Overhead Line Work	2,041,407	487,462	481,862	1,209,747	1,209,747	1,209,747
Automation	56,477	482,447	263,476	154,256	154,256	154,256
	4,567,467	3,447,778	4,181,595	3,839,919	3,839,919	3,839,919
<b>Transmission</b>						
Transmission Equipment	-	-	-	1,616,590	3,448,590	5,330,590
	-	-	-	1,616,590	3,448,590	5,330,590
<b>Demand</b>						
City Works Projects	493,457	93,042	1,255,256	1,340,203	1,340,203	1,340,203
Developer Works Projects	695,388	1,610,079	1,432,696	820,709	820,709	820,709
	1,188,846	1,703,121	2,687,953	2,160,912	2,160,912	2,160,912
<b>Metering</b>						
Metering	92,927	12,963	155,024	218,354	218,354	218,354
	92,927	12,963	155,024	218,354	218,354	218,354
<b>Fleet and Facilities</b>						
Vehicles & Major Equipment	116,559	280,613	102,018	-	-	-
Buildings & Fixtures	67,403	357,050	115,676	189,018	189,018	189,018
	183,962	637,663	217,694	189,018	189,018	189,018
<b>Information Systems</b>						
Hardware / Software	40,544	(34,432)	-	-	-	-
Application Development	749,387	1,243,327	458,798	393,851	393,851	893,851
	789,931	1,208,894	458,798	393,851	393,851	893,851
	6,823,132	7,010,419	7,701,063	8,418,645	10,250,645	12,632,645
Inventory Held for Capital Projects	3,402,771	3,411,683	2,952,274	3,709,935	3,709,935	3,709,935
	10,225,904	10,422,102	10,653,337	12,128,580	13,960,580	16,342,580

4



1 **Allowance for Working Capital**

2 London Hydro's working capital allowance has been calculated to be \$37,977,770 for the  
 3 proposed 2017 Test Year and is based on a rate of 8.67%.

4 **Table 2-14 – Summary of Working Capital Allowance**

SUMMARY OF WORKING CAPITAL ALLOWANCE								
	2013 Actual	2013 Board Approved	2014 Actual	2015 Actual	2016 Bridge	2017 Test	2013 Board Approved to 2017 Test	CAGR
	\$	\$	\$	\$	\$	\$	\$	%
Controllable Expenses	31,351,306	32,978,000	33,621,467	35,098,651	37,011,000	38,797,000	5,819,000	4.1%
Cost of Power (COP)	341,135,582	334,431,790	363,384,203	379,936,576	412,074,924	399,239,563	64,807,773	4.5%
Total Controllable Expenses & COP	372,486,887	367,409,790	397,005,671	415,035,227	449,085,924	438,036,563	70,626,773	4.5%
WCA Rate	11.42%	11.42%	11.42%	11.42%	11.42%	8.67%	-2.75%	
<b>Working Capital Allowance (WCA)</b>	<b>42,538,003</b>	<b>41,958,198</b>	<b>45,338,048</b>	<b>47,397,023</b>	<b>51,285,613</b>	<b>37,977,770</b>	<b>(3,980,428)</b>	<b>-2.5%</b>

5

6 On June 3, 2015, the Ontario Energy Board issued a letter regarding "Allowance for Working  
 7 Capital for Electricity Distribution Rate Applications." In this letter, the Board adopted a new  
 8 default value for calculating working capital allowance: 7.5% of the sum of the cost of power and  
 9 operating, maintenance and administration (OM&A) costs.

10 As an alternative, London Hydro has elected to engage the services of Navigant Consulting Ltd.  
 11 to perform a lead-lag study. This alternative was chosen because working capital is a significant  
 12 component of London Hydro's rate base. Navigant's study was completed in March 2016 (using  
 13 2014 data) and calculates working capital as a percentage of OM&A including cost of power to  
 14 be 8.67%. A copy of this study has been provided in Appendix 2-3 – Lead Lag Study.

15 As displayed in Table 2-14, actual results for 2013 working capital allowance were comparable  
 16 to the 2013 Board Approved amount, varying by only 1.38%.

17 The 2017 working capital allowance has decreased \$3,980,428, or 2.5% CAGR, in comparison  
 18 to the 2013 Actuals. This change is a result of the decrease in the percentage rate applied in the  
 19 computation of the working capital allowance from 11.42% to 8.67%, net of increased working  
 20 capital requirements, due to the increased costs associated with controllable expenses and the  
 21 cost of power as displayed below:





Increase in Controllable Expense	\$ 504,507
Increase in Cost of Power	<u>5,618,834</u>
	6,123,341
Decrease in WCA Rate from 11.42% to 8.68%	<u>(10,103,769)</u>
	<u><b>(3,980,428)</b></u>

1  
2 Details regarding the calculation of total controllable expenses, used in the calculation of  
3 working capital, can be found within Exhibit 4, Section 'Operating Expenses', page 17.  
4 Additionally, volume, pricing and rates associated with the calculation of the cost of power for  
5 the proposed 2017 Test Year can be found in Exhibit 6, Tab 1, Schedule 1, Attachment 2.2.

## 6 **Treatment of Stranded Assets Related to Smart Meter Deployment**

7 London Hydro is not seeking recovery for any costs associated with stranded meters in this  
8 Application. All items relating to smart meters were settled in the 2013 Cost of Service Rate  
9 Application. Accordingly, London Hydro has not completed an Appendix 2-S: Stranded Meter  
10 Treatment, for this Cost of Service.

# 1 CAPITAL EXPENDITURES

---

## 2 Planning

3 London Hydro has prepared its first Distribution System Plan (DSP), in accordance with Chapter  
4 5 of the “Filing Requirements for Electricity Transmission and Distribution Applications.” The  
5 DSP has been submitted as a stand-alone document and can also be found in Appendix 2-6.

6 Capital spending information is provided for the 2012-2015 Historical Years, 2016 Bridge Year,  
7 and the 2017 Test Year. The DSP also contains forecasted capital expenditures beyond the  
8 2017 Test Year, for 2018-2021, representing the total planning horizon of the instructed five  
9 years.

10 In Exhibit 2, capital expenditures are discussed at the project category level. In the DSP,  
11 spending has been presented at both the Chapter 5 Investment Categories level (System  
12 Access, System Renewal, System Service, General Plant), and it has also been broken down  
13 further to the project level. Table 2-42, further within this Exhibit, reconciles the total Chapter 5  
14 spending amounts to the total project category spending amounts, in order to demonstrate that  
15 all items listed in the DSP are included within Exhibit 2. London Hydro has assigned all historical  
16 and future projects to the new categories as required by the Board.

17 London Hydro has engaged in regional planning sessions with various entities, such as Hydro  
18 One and neighbouring utilities, in accordance with the Board’s RRFE. London Hydro has  
19 partnered with Hydro One regarding the Nelson TS Upgrade project; more information can be  
20 found on Page 75 within this Exhibit. Other planning sessions, regarding topics such as  
21 Customer Engagement and load forecasting have also occurred. More information on these  
22 planning initiatives can be found in section 3.1 and 3.2 of the DSP.

1 **Required Information**

2 Please refer to the table below for information on information required for Exhibit 2, per Section  
 3 2.2.2.2 of the Chapter 2 Filing Requirements.

<b>REQUIRED INFORMATION</b>	
<b>Requirement</b>	<b>Location</b>
Consolidated DSP	Appendix 2-6
Appendix 2-AB - Capital Expenditure Summary from Chapter 5 Consolidated Distribution System Plan Filing Requirements	2016 Filing Requirements Chapter 2 Appendices (Excel workbook)
Appendix 2-AA - Capital Projects Table	2016 Filing Requirements Chapter 2 Appendices (Excel workbook)
Explanation of Variances	Page 39
Accounting Treatment of Projects Greater than One Year	Page 45
Reconciliation of All Capital Components to Total Capital Budget	Page 45
Details of Any Capital Contributions Made re: CCRA	Page 39
Efficiencies Realized Due to Deployment of Smart Meters and Related Technologies	Page 35
Rate-Funded Activities to Defer Distribution Infrastructure	Page 37

4  
 5 **Efficiencies Realized Due to Deployment of Smart Meters and Related Technologies**

6 The implementation of smart meters has resulted in significant change for London Hydro's  
 7 billing and distribution operations. Some of the key smart meter efficiencies and benefits  
 8 leveraged by London Hydro include the following:

- 9 1) Meter Reading: The one obvious area of operating efficiency realized with wireless  
 10 smart meters is the elimination of meter readers. In addition, human error in reading or  
 11 recording incorrect values by meter readers has been eliminated.
- 12 2) Accuracy: The meter hardware itself is capable of more accurate readings than the  
 13 previous electro-mechanical meters.
- 14 3) Faster replacement: To comply with the MDM/R requirement that no meters could be  
 15 estimated more than 15 days, London Hydro revamped its operational procedures to  
 16 dispatch field workers within hours of either meter failure alarms or lack of response from  
 17 a meter. In the past, it may have taken several months before a failed meter was  
 18 identified and fixed.

- 1       4) Missing Meters: Theft of meters and lost meters are quickly identified and can be found  
2       by triangulating the RF signal. In the past, lost or stolen meters could not be found  
3       easily. However, through detailed wireless reporting, London Hydro is able to monitor  
4       the metering installations and respond to these problems within hours.
- 5       5) System Voltage at the smart meter endpoints is now being reported through alarm  
6       settings and raw reported voltage data. While a voltage management system is yet to be  
7       developed to make full use of the smart meter sensor endpoint data, London Hydro has  
8       developed some basic reports and processes to monitor voltage. These changes have  
9       led to improvements in transformer tap management and phase outages.
- 10      6) Hot Sockets: Smart meters report high temperature conditions also known as “hot  
11      sockets.” These alarms are often present in the case of loose supply or load connections  
12      to the meter base and can result in fires. London Hydro has used these alarms to  
13      proactively detect and remedy potentially dangerous situations that would have  
14      otherwise not been detected.
- 15      7) Customer interaction: When customers call into the Contact Centre regarding high billing  
16      issues, the additional hourly data enables a more informed conversation between the  
17      customer and London Hydro.
- 18      8) Outage data: Smart meter power on / power off signals now send information from the  
19      AMI (Advanced Metering Infrastructure) smart meter system to the OMS (Outage  
20      Management System). This new functionality allows Control Room Operators to detect  
21      and respond to power outages before customers call in to complain and notify London  
22      Hydro.
- 23      9) Collection and customer interaction: Access to hourly data provides informed decision-  
24      making and evidence-based enforcement of collections or unauthorized meter removal  
25      or tampering. If a meter is enabled on a service that is intended to be off for collections,  
26      it can be monitored and alarmed to ensure there is no unauthorized consumption.  
27      Available data can serve as evidence or be made available to determine a bill for the  
28      used electricity.
- 29      10) Smart meters also provide a basis to integrate with thermostat demand response  
30      programs (e.g., OPA Peaksaver Plus) and other home area networking programs to  
31      offer to the customers.

1 The above qualitative benefits and efficiencies have led to financial savings for London Hydro,  
2 but these savings are not yet readily identifiable, as there is not enough data to perform a  
3 thorough quantitative analysis that would provide meaningful results at this time.

#### 4 **Rate-Funded Activities to Defer Distribution Infrastructure**

5 London Hydro's Engineering and Planning team considers non-distribution alternatives at the  
6 planning and design stage when evaluating infrastructure changes. They are guided by a  
7 document referred to as "Engineering Instruction 31 – Asset Management Policy and  
8 Procedures (see DSP Appendix F)". The Director of Network Operations takes Regional  
9 Planning and REG requirements into account when assessing capacity and forecasting  
10 constraints (EI-31, Responsibilities, Step 1, System Service Part 4; EI-31, Procedures, Step 1,  
11 System Access Part 5 and System Service Part 5; EI-31, Procedures, Step 3, CDM). The  
12 Manager of Engineering considers CDM and REG investment alternatives prior to building new  
13 capacity and works with the Senior Director of Energy Management Programs to explore ways  
14 in which CDM initiatives can be used to reduce the need to invest in system assets (EI-31,  
15 Responsibilities, Step 3, Engineering Design Part 1).

16 The planning forecast for the overall supply to London also considers the impact of CDM and  
17 DG (see DSP Section 2.2.4 System Utilization). The forecast indicates that the supply to  
18 London through the seven transformer stations will be sufficient for at least twenty years.  
19 Therefore, London Hydro has not planned for any infrastructure upgrades to increase capacity  
20 at the transformer stations.

21 The long range plans for the downtown core of London include converting the 13.8 kV supply to  
22 27.6 kV. As this conversion takes place, it is necessary to extend new 27.6 kV feeders into  
23 downtown to reliably supply load that was supplied at 13.8 kV. To determine the location and  
24 quantity of feeders required, the planning engineers considered the impact of existing CDM and  
25 DG in the system model by using real-time meter data (see DSP Appendix J). In consultation  
26 with the Senior Director of Energy Management Programs, the planning engineers also  
27 considered how additional CDM and DG might further affect the plans for new feeders, keeping  
28 in mind the need for redundancy to maintain a reliable supply. This evaluation concluded that  
29 the planned extension of feeders into the downtown could not be deferred through incremental  
30 CDM or DG because the primary driver of these feeder extensions is the conversion from 13.8



1 kV to 27.6 kV to eliminate aging infrastructure and the need for adequate redundancy to  
2 maintain a reliable supply to a significant and dense load growth area. While the extension of  
3 the 27.6 kV feeders may facilitate additional DG connections in the downtown core, these  
4 projects are needed to replace aging infrastructure and maintain a reliable supply. Therefore,  
5 London Hydro did not consider making a request for funding in accordance with O.Reg. 330/09.

6

## 1 Analysis of Capital Expenditures

2 Table 2-15 below outlines capital spending for the 2013 Board Approved Year, 2012-2015  
 3 Historical Years, 2016 Bridge Year and the 2017 Test Year. Material variances are further  
 4 discussed below.

5 **Table 2-15 – Capital Spending Summary 2012 – 2017 (before capital contributions)**

CAPITAL SPENDING 2012 - 2017 (before Capital Contributions)									
SUMMARY BY CATEGORY									
Annual Spending	2012 Actual	2013 Actual	2013 Board Approved	2014 Actual	2015 Actual	2016 Bridge	2017 Test	2013 Actuals to 2017 Test	CAGR
	\$	\$	\$	\$	\$	\$	\$	\$	%
Infrastructure	12,827,086	12,494,840	13,447,000	13,250,035	15,069,062	15,824,000	15,214,000	2,719,160	5.0%
Metering	739,835	743,722	648,000	837,612	1,274,040	1,639,000	1,671,000	927,278	22.4%
Fleet and Facilities	2,982,199	2,059,715	2,295,000	2,259,453	2,234,137	3,230,000	2,528,000	468,285	5.3%
Information Systems	5,672,943	6,875,635	6,000,000	4,425,591	5,563,977	4,940,000	4,510,000	(2,365,635)	-10.0%
<b>Regular Capital Spending (at LHI's Discretion)</b>	<b>22,222,063</b>	<b>22,173,913</b>	<b>22,390,000</b>	<b>20,772,690</b>	<b>24,141,215</b>	<b>25,633,000</b>	<b>23,923,000</b>	<b>1,749,087</b>	<b>1.9%</b>
TS Upgrade	-	-	-	-	1,616,590	1,832,000	1,882,000	1,882,000	
Demand	6,337,830	5,294,316	5,463,400	6,627,060	7,985,620	6,254,000	6,770,000	1,475,684	6.3%
<b>Other Capital Spending (Atypical or Demand Driven)</b>	<b>6,337,830</b>	<b>5,294,316</b>	<b>5,463,400</b>	<b>6,627,060</b>	<b>9,602,210</b>	<b>8,086,000</b>	<b>8,652,000</b>	<b>3,357,684</b>	<b>13.1%</b>
Inventory Held for Capital Projects	(250,719)	241,807	-	(450,497)	757,661	-	-	(241,807)	-100.0%
CGAAP to MIFRS Burden Adjustment	(536,620)	-	-	-	-	-	-	-	
	<b>27,772,554</b>	<b>27,710,036</b>	<b>27,853,400</b>	<b>26,949,253</b>	<b>34,501,087</b>	<b>33,719,000</b>	<b>32,575,000</b>	<b>4,864,964</b>	<b>4.1%</b>

6  
 7 London Hydro's capital expenditures are categorized into the following groupings and will be  
 8 discussed further at these levels:

- 9 ➤ Infrastructure
  - 10 A - Substation Rebuild Projects
  - 11 B - Subdivision Rebuild Projects
  - 12 C - Main Feeder Projects
  - 13 F - Network Projects
  - 14 G - Overhead Line Work Projects
  - 15 H - Automation Projects
- 16 ➤ TS Upgrade (CC)
- 17 ➤ Demand
  - 18 D - City Works Projects
  - 19 E - Developer Works Projects
- 20 ➤ Metering (M)



- 1       ➤ Fleet and Facilities
- 2           N    - Vehicles and Major Equipment
- 3           O    - Operating Equipment
- 4           Q    - Office Furniture and Equipment
- 5           R    - Building Improvements/Renovations
  
- 6       ➤ Information Systems
- 7           V    - Infrastructure and Hardware Projects
- 8           W    - Application Development Projects

9       The largest increase in capital spending since the 2013 Actuals is in the area of Infrastructure,  
10       which has increased \$2,719,160 or 5% CAGR. The majority of this increase is related to the  
11       Networks and Main Feeders categories, and is primarily driven by the need to convert the 4.16  
12       kV and 13.8 kV systems to 27.6 kV and the subsequent expansion of the 27.6 kV system.

13       A new grouping in this Application is entitled TS Upgrade, with the first spending occurring in  
14       2015. This grouping refers to capital contributions (intangible asset) paid to Hydro One  
15       regarding the decommissioning of the 13.8kV Substation and the conversion of the Substation  
16       to 27.6kV (Nelson).

17       The capital expenditures for the Demand area have increased by \$1,475,684 or 6.3% CAGR  
18       between the 2013 Actual and the proposed 2017 Test Year. These increases are driven solely  
19       by City Works and Developer Works and are not under the control of London Hydro.

20       Spending for Metering has increased by \$927,728 or 22.4% CAGR between the 2013 Actual  
21       and the proposed 2017 Test Year primarily due to a new AMI Communications Renewal project  
22       and increased equipment costs.

23       Fleet and Facilities spending has fluctuated insignificantly.

24       Information Systems spending is decreasing between the 2013 Actual and the proposed 2017  
25       Test Year by \$2,365,635 or 10.0% CAGR. This decrease is due to the increased reliance on  
26       Cloud Computing, which lessens the need for London Hydro-owned premise-based IT  
27       Infrastructure.





1 “Inventory held for capital projects” represents spending on capital-related inventory items such  
2 as transformers that have been purchased but not yet assigned to a specific capital job.

3 The “CGAAP to MIFRS Burden Adjustment” line refers to the 1576 IFRS-GAAP Transitional  
4 PP&E Amounts that were discussed fully in London Hydro’s 2013 Cost of Service Rate  
5 Application.

6 Note that this capital spending information excludes renewable generation owned by London  
7 Hydro up to and including December 31, 2015.

8 Table 2-16 below further breaks down Capital Spending by Project Category.

9



1

**Table 2-16 – Capital Expenditures 2012 – 2017**

LONDON HYDRO INC. CAPITAL EXPENDITURES - 2012 TO 2017							
	2012	2013	2013 Board	2014	2015	2016	2017
	Actual	Actual	Approved	Actual	Actual	Bridge	Test
	\$	\$	\$	\$	\$	\$	\$
<b>Infrastructure</b>							
<b>Substation Rebuilds</b>							
Relay replacements	25,278	32,040	25,000	110,033	63,787	80,000	80,000
Downtown network supply reinforcement	10,361	-	-	-	-	-	-
Battery bank replacements	15,435	11,427	30,000	11,018	12,065	15,000	15,000
Switchgear modifications	32,636	107,589	120,000	81,590	142,207	-	-
Substation installations/refurbishments	525	183,850	-	(10,000)	-	-	-
Switch replacements	76,362	976	-	56,975	57,918	-	-
Voltage conversion	82,303	53,578	-	89,880	-	-	-
Vault Renewal and RTU Standardization	-	23,722	30,000	126	42,598	30,000	30,000
Other	-	7,570	15,000	-	-	-	-
	<b>242,899</b>	<b>420,752</b>	<b>220,000</b>	<b>339,622</b>	<b>318,575</b>	<b>125,000</b>	<b>125,000</b>
<b>Subdivision Rebuilds</b>							
Silicone Injection of Underground Cable	792,460	1,856,705	1,165,000	2,323,405	2,528,992	1,891,000	2,711,000
Conversions and Rebuilds with Silicone Injection	3,051,901	1,821,492	2,000,000	979,680	709,546	700,000	75,000
Air-Insulated Sectionalized Enclosures	492,255	512,158	480,000	350,100	221,833	246,000	293,000
Replace leaking transformer	1,115,183	1,091,724	1,050,000	570,360	1,493,000	700,000	700,000
Rebuild or Convert Vault Areas	152,397	264,152	385,000	91,029	170,696	166,000	144,000
Underground Conversions	85,744	370,753	468,000	329,213	731,287	1,489,000	556,000
Backup Supply and Fault Indicator Installations	109,326	61,638	40,000	52,886	181,561	90,000	90,000
Miscellaneous Subdivision Projects	33,610	20,456	25,000	22,015	26,322	20,000	20,000
Transformer Returns	-	(444,051)	-	(236,087)	(667,306)	(200,000)	(200,000)
	<b>5,832,875</b>	<b>5,555,027</b>	<b>5,613,000</b>	<b>4,482,600</b>	<b>5,395,930</b>	<b>5,102,000</b>	<b>4,389,000</b>
<b>Main Feeders</b>							
Reinforcements	456,904	575,177	989,000	344,509	153,939	-	-
Extensions & Installations	639,989	447,869	-	2,182	-	-	-
Conversions	2,628	1,545	-	35,415	1,544,346	1,492,000	815,000
Backup Supply & Civil Structure Installations	-	13,447	-	663,895	1,035,484	2,490,000	2,560,000
	<b>1,099,522</b>	<b>1,038,038</b>	<b>989,000</b>	<b>1,046,001</b>	<b>2,733,769</b>	<b>3,982,000</b>	<b>3,375,000</b>
<b>Network</b>							
Replacement of Network Vaults, Maintenance Holes and Transformers	839,431	616,923	530,000	1,324,019	1,537,231	1,000,000	1,020,000
Replacement of Primary/Second Cable	484,417	199,082	340,000	384,082	50,059	380,000	750,000
East End Network	425,361	55,299	120,000	-	-	-	-
Maintenance Hole Cable Rebuilds & Fuse Installs	40,344	243,550	150,000	142,460	539	550,000	300,000
Maintenance Hole Cable Protection	-	-	-	-	387,412	-	-
	<b>1,789,554</b>	<b>1,114,854</b>	<b>1,140,000</b>	<b>1,850,561</b>	<b>1,975,242</b>	<b>1,930,000</b>	<b>2,070,000</b>
<b>Overhead Line Works</b>							
Replacement of Fully Depreciated/Deteriorated Poles and Poles Susceptible to Fire	948,911	509,558	600,000	668,105	495,465	520,000	410,000
Arrestor/Insulator/Other	4,949	80,748	100,000	796,858	950,244	880,000	580,000
Rebuild Fully Depreciated Overhead Areas	2,514,411	814,383	200,000	228,610	316,131	300,000	260,000
Reliability/Outage Mitigation	450	127,350	250,000	296,880	1,655	-	-
Overhead Voltage Conversions	101,092	2,515,522	4,000,000	2,837,901	2,388,036	2,180,000	3,280,000
	<b>3,569,813</b>	<b>4,047,562</b>	<b>5,150,000</b>	<b>4,828,353</b>	<b>4,151,531</b>	<b>3,880,000</b>	<b>4,530,000</b>
<b>Automation</b>							
Recloser Installation	173,245	183,677	195,000	212,822	185,367	275,000	195,000
Remote Terminal Unit Replacements	46,451	66,789	50,000	199,051	189,867	130,000	130,000
Miscellaneous Automation	54,793	41,661	90,000	59,431	30,191	250,000	250,000
SCADA	6,476	26,481	-	163,357	81,115	100,000	100,000
Power Quality	-	-	-	34,991	4,009	50,000	50,000
Miscellaneous Control Room General Plant	11,458	-	-	33,244	3,468	-	-
	<b>292,424</b>	<b>318,608</b>	<b>335,000</b>	<b>702,897</b>	<b>494,015</b>	<b>805,000</b>	<b>725,000</b>
<b>TOTAL INFRASTRUCTURE</b>	<b>12,827,086</b>	<b>12,494,840</b>	<b>13,447,000</b>	<b>13,250,035</b>	<b>15,069,062</b>	<b>15,824,000</b>	<b>15,214,000</b>

2



LONDON HYDRO INC. CAPITAL EXPENDITURES - 2012 TO 2017 (cont'd)							
	2012 Actual	2013 Actual	2013 Board Approved	2014 Actual	2015 Actual	2016 Bridge	2017 Test
	\$	\$	\$	\$	\$	\$	\$
<b>TS Upgrade</b>							
TS Upgrade							
Contribution to TS Upgrade	-	-	-	-	1,616,590	1,832,000	1,882,000
<b>TOTAL TS UPGRADE</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>-</b>	<b>1,616,590</b>	<b>1,832,000</b>	<b>1,882,000</b>
<b>Demand</b>							
<b>City Works</b>							
City of London (Road Authority) Relocations	1,446,613	543,034	805,400	1,542,380	1,968,293	1,996,000	2,250,900
<b>Developer Works</b>							
Developer Expansions & Relocations	400,272	531,758	594,000	254,200	269,752	146,000	340,900
Residential Secondary Service Upgrade	305,886	306,803	325,000	307,721	369,831	340,000	355,000
Single Family Residential Underground	1,333,826	900,487	1,174,000	1,868,778	1,388,376	1,066,000	1,090,200
Multi-Family Residential Underground	393,578	744,736	565,000	616,065	1,400,041	766,000	783,000
Commercial Distribution Services	2,457,653	2,267,498	2,000,000	2,037,915	2,589,329	1,940,000	1,950,000
	<b>4,891,216</b>	<b>4,751,282</b>	<b>4,658,000</b>	<b>5,084,680</b>	<b>6,017,328</b>	<b>4,258,000</b>	<b>4,519,100</b>
<b>TOTAL DEMAND PROJECTS</b>	<b>6,337,830</b>	<b>5,294,316</b>	<b>5,463,400</b>	<b>6,627,060</b>	<b>7,985,620</b>	<b>6,254,000</b>	<b>6,770,000</b>
<b>Metering</b>							
Metering and installations	680,002	633,937	527,000	680,197	895,391	660,000	668,000
Primary metering	56,614	109,785	121,000	112,549	85,368	354,000	354,000
Testing and validation equipment	-	-	-	44,865	293,280	-	-
AMI Communications Renewal	-	-	-	-	-	625,000	649,000
Wholesale metering upgrades	3,220	-	-	-	-	-	-
<b>TOTAL METERING</b>	<b>739,835</b>	<b>743,722</b>	<b>648,000</b>	<b>837,612</b>	<b>1,274,040</b>	<b>1,639,000</b>	<b>1,671,000</b>
<b>Fleet and Facilities</b>							
<b>Vehicles &amp; Major Equipment</b>							
Vehicles and Major Equipment	1,675,405	1,310,236	1,410,000	771,500	1,195,208	1,130,000	1,099,000
	<b>1,675,405</b>	<b>1,310,236</b>	<b>1,410,000</b>	<b>771,500</b>	<b>1,195,208</b>	<b>1,130,000</b>	<b>1,099,000</b>
<b>Operating Equipment</b>							
Stores Equipment	119	5,499	5,000	3,348	65,707	165,000	40,000
Miscellaneous Operating Equipment	168,718	130,517	150,000	192,161	146,759	280,000	280,000
	<b>168,837</b>	<b>136,016</b>	<b>155,000</b>	<b>195,509</b>	<b>212,466</b>	<b>445,000</b>	<b>320,000</b>
<b>Office Furniture &amp; Equipment</b>							
Office Furniture/Equipment	84,536	101,296	80,000	121,041	79,805	455,000	197,000
	<b>84,536</b>	<b>101,296</b>	<b>80,000</b>	<b>121,041</b>	<b>79,805</b>	<b>455,000</b>	<b>197,000</b>
<b>Buildings &amp; Fixtures</b>							
Heating/Venting & A/C	39,931	-	100,000	24,453	73,410	150,000	154,000
Paving	440,753	230,555	250,000	140,550	66,750	345,000	346,000
Improvements/Renovations	247,548	138,560	175,000	896,314	464,798	530,000	360,000
Garage Fixtures	-	-	125,000	-	127,520	-	-
Roofing	10,153	-	-	-	-	-	-
Yard Environmental Controls	-	-	-	-	-	50,000	-
Standby Generator	293,762	75,649	-	-	10,952	50,000	52,000
Uninterrupted Power Supply & Battery Banks	21,275	67,403	-	110,086	3,229	75,000	-
	<b>1,053,422</b>	<b>512,167</b>	<b>650,000</b>	<b>1,171,402</b>	<b>746,658</b>	<b>1,200,000</b>	<b>912,000</b>
<b>TOTAL FLEET AND FACILITIES</b>	<b>2,982,199</b>	<b>2,059,715</b>	<b>2,295,000</b>	<b>2,259,453</b>	<b>2,234,137</b>	<b>3,230,000</b>	<b>2,528,000</b>



LONDON HYDRO INC. CAPITAL EXPENDITURES - 2012 TO 2017 (cont'd)							
	2012 Actual	2013 Actual	2013 Board Approved	2014 Actual	2015 Actual	2016 Bridge	2017 Test
	\$	\$	\$	\$	\$	\$	\$
<b>Information Systems</b>							
<b>Hardware and Software</b>							
Desktop solutions	75,417	75,858	45,000	112,079	136,377	129,000	120,000
Network development	394,167	819,070	200,000	109,615	374,664	195,000	250,000
Servers and storage	641,703	347,304	760,000	127,129	821,405	315,000	220,000
Back up solutions	13,510	23,550	25,000	49,467	38,246	50,000	30,000
Miscellaneous software	50,890	211,109	85,000	200,422	2,023	25,000	25,000
Miscellaneous hardware	1,545	109,812	5,000	18,953	21,428	21,000	15,000
Miscellaneous IT tools	136,622	3,681	5,000	9,289	-	10,000	10,000
Phone system	9,566	28,103	10,000	499,246	2,204	65,000	50,000
Physical plant	10,787	30,230	75,000	-	21,611	-	15,000
Wireless Communication	9,368	98,639	-	-	-	-	-
	<b>1,343,575</b>	<b>1,747,356</b>	<b>1,210,000</b>	<b>1,126,199</b>	<b>1,417,956</b>	<b>810,000</b>	<b>735,000</b>
<b>Application Development</b>							
Customer Information System (CIS)	383,121	874,096	835,000	601,952	406,743	855,000	300,000
CIS retailer requirements	767,734	-	-	-	-	-	-
CIS Customer Relations Management upgrade	-	726,038	525,000	417,044	-	175,000	-
Cyber Security	-	-	-	-	266,760	125,000	50,000
System Foundations	-	-	-	-	250,242	305,000	150,000
Customer Engagement - Residential	-	-	-	539,465	648,647	300,000	825,000
Customer Engagement - Commercial & Industrial	-	-	-	-	8,121	740,000	400,000
CIS regulatory requirements	260,602	266,879	480,000	9,017	304,583	140,000	250,000
Geographic Information System (GIS)	453,662	-	-	-	158,736	40,000	-
Outage Management System (OMS)	707,427	1,194,718	1,500,000	514,796	107,614	350,000	-
Customer Engagement / Web Presentment & TOU	208,782	1,524,585	500,000	45,314	-	-	-
Meter data	1,548,041	4,696	-	229,753	314,117	150,000	400,000
Mobile Workforce (MWFM)	-	518,019	450,000	489,533	781,324	300,000	300,000
Business intelligence	-	19,249	500,000	1,912	150,814	175,000	250,000
Enterprise Resource Planning (ERP)	-	-	-	450,607	748,319	475,000	850,000
	<b>4,329,368</b>	<b>5,128,280</b>	<b>4,790,000</b>	<b>3,299,393</b>	<b>4,146,021</b>	<b>4,130,000</b>	<b>3,775,000</b>
<b>TOTAL INFORMATION SYSTEMS</b>	<b>5,672,943</b>	<b>6,875,635</b>	<b>6,000,000</b>	<b>4,425,591</b>	<b>5,563,977</b>	<b>4,940,000</b>	<b>4,510,000</b>
<b>TOTAL CAPITAL PROJECTS</b>	<b>28,559,893</b>	<b>27,468,229</b>	<b>27,853,400</b>	<b>27,399,750</b>	<b>33,743,426</b>	<b>33,719,000</b>	<b>32,575,000</b>
Inventory Held for Capital Projects	(250,719)	241,807	-	(450,497)	757,661	-	-
CGAAP to MIFRS Burden Adjustment	(536,620)	-	-	-	-	-	-
Less: Capital Contributions	(3,780,997)	(2,418,672)	(2,700,000)	(1,870,692)	(3,788,551)	(2,087,000)	(2,101,000)
<b>NET CAPITAL PROJECTS</b>	<b>23,991,557</b>	<b>25,291,364</b>	<b>25,153,400</b>	<b>25,078,561</b>	<b>30,712,535</b>	<b>31,632,000</b>	<b>30,474,000</b>



## 1 **Capital Projects Longer than One Year**

2 London Hydro has only one project with a life cycle greater than one year: the Nelson  
3 transformer station upgrade (See Page 75 within this Exhibit for more information). Spending  
4 regarding this project remains in Construction Work In Progress (CWIP) until the asset is placed  
5 into service in 2018. At this time, capital expenditures as well as a financing charge (Allowance  
6 for Funds Used During Construction or ``AFUDC``) will be capitalized. The interest rate used for  
7 the AFUDC calculation is based on the quarterly OEB prescribed rates.

## 8 **Reconciliation to Total Capital Budget**

9 The capital expenditures shown below agree with the 2016 and 2017 Capital Plan as approved  
10 by the London Hydro Board of Directors on December 9, 2015. The only exception pertains to  
11 the presentation of transformers returned from the field during a transformer replacement. As  
12 some of these transformers may be refurbished and reused, London Hydro budgets for an  
13 internal cost recovery of these amounts against "Subdivision Rebuilds." This amount is not  
14 listed on the London Hydro Board of Directors Approved Plan since capital expenditures are  
15 presented as gross spending.

16 No capital spending is planned for any non-distribution activities; therefore, an additional  
17 reconciliation is not required.

## 18 **A Comparison between 2013 and 2017**

19 The increase in spending from 2013 to 2017 can be broken down into 3 segments: (1) basic  
20 costs, (2) inflation, and (3) TS Upgrade & Demand spending. The basic costs segment is the  
21 only area of the spending increase that is at London Hydro's regular discretion, so further  
22 discussion will be focused here.

23 Proposed capital spending for the 2017 Test Year is \$2,906,413 or 10.5% higher compared to  
24 actual spending in 2013, after adjusting to remove the effects of inflation. Inflation is estimated  
25 at a rate of 9.0% based on Statistics Canada CPI for Ontario for the years 2013 to 2017,  
26 weighted with London Hydro wage escalation rates.

27 When capital spending in the areas of TS Upgrade and Demand are removed (due to being  
28 atypical or demand-driven), the variance between 2013 inflated spending and 2017 proposed

1 spending, in fact, represents a decrease of \$510,135 or 2.1% (or an annual decrease of 0.5%).  
 2 This outcome demonstrates that although at a category level spending patterns have changed,  
 3 London Hydro's regular discretionary spending at a corporate level has remained relatively  
 4 consistent from 2013 to 2017.


5 Tables 2-17 and 2-18 below further demonstrate the consistency of London Hydro's  
 6 discretionary spending.

7 **Table 2-17 – Impact of Inflation on Capital Spending**

Category	Capital Spending 2013	Add: Inflation @ 9.0%	2013 Inflated Spending	2017 Capital Spending	Change Spending 2017 - Inflated 2013	% Change
<b>Regular Spending (at LHI's Discretion):</b>						
Infrastructure	\$ 12,736,648	\$ 1,146,298	\$ 13,882,946	\$ 15,214,000	\$ 1,331,054	9.6%
Metering	\$ 743,722	\$ 66,935	\$ 810,657	\$ 1,671,000	\$ 860,343	106.1%
Fleet and Facilities	\$ 2,059,715	\$ 185,374	\$ 2,245,089	\$ 2,528,000	\$ 282,911	12.6%
Information Systems	\$ 6,875,635	\$ 618,807	\$ 7,494,443	\$ 4,510,000	\$ (2,984,443)	-39.8%
	\$ 22,415,720	\$ 2,017,415	\$ 24,433,135	\$ 23,923,000	\$ (510,135)	-2.1%
<b>Other Spending (Atypical or Demand-Driven)</b>						
TS Upgrade	\$ -	\$ -	\$ -	\$ 1,882,000	\$ 1,882,000	
Demand	\$ 2,875,644	\$ 258,808	\$ 3,134,452	\$ 4,669,000	\$ 1,534,548	49.0%
	\$ 2,875,644	\$ 258,808	\$ 3,134,452	\$ 6,551,000	\$ 3,416,548	109.0%
	<b>\$ 25,291,364</b>	<b>\$ 2,276,223</b>	<b>\$ 27,567,587</b>	<b>\$ 30,474,000</b>	<b>\$ 2,906,413</b>	<b>10.5%</b>

8

9 **Table 2-18 – LHI's Regular Capital Spending: A Comparison 2013 – 2017**



10



1 **Infrastructure**

2 Forecasted spending for Infrastructure for the proposed 2017 Test Year is \$15,214,000,  
 3 representing an increase of \$2,719,160 or 5.0% CAGR compared to the 2013 Actuals. Table 2-  
 4 19 below further divides Infrastructure spending into various project categories, which are then  
 5 subdivided and discussed further.

6 **Table 2-19 – Infrastructure Capital Spending by Project Category 2012 - 2017**

INFRASTRUCTURE CAPITAL SPENDING 2012 - 2017									
Annual Spending	2012 Actual	2013 Actual	2013 Board Approved	2014 Actual	2015 Actual	2016 Bridge	2017 Test	2013 Actuals to 2017 Test	CAGR
	\$	\$	\$	\$	\$	\$	\$	\$	%
<b>Infrastructure</b>									
Substation Rebuilds	242,899	420,752	220,000	339,622	318,575	125,000	125,000	(295,752)	-26.2%
Subdivision Rebuilds	5,832,875	5,555,027	5,613,000	4,482,600	5,395,930	5,102,000	4,389,000	(1,166,027)	-5.7%
Main Feeders	1,099,522	1,038,038	989,000	1,046,001	2,733,769	3,982,000	3,375,000	2,336,962	34.3%
Networks	1,789,554	1,114,854	1,140,000	1,850,561	1,975,242	1,930,000	2,070,000	955,146	16.7%
Overhead Line Work	3,569,813	4,047,562	5,150,000	4,828,353	4,151,531	3,880,000	4,530,000	482,438	2.9%
Automation	292,424	318,608	335,000	702,897	494,015	805,000	725,000	406,392	22.8%
	<b>12,827,086</b>	<b>12,494,840</b>	<b>13,447,000</b>	<b>13,250,035</b>	<b>15,069,062</b>	<b>15,824,000</b>	<b>15,214,000</b>	<b>2,719,160</b>	<b>5.0%</b>

7

8 Infrastructure related projects result from engineering and planning studies, as well as from  
 9 operational issues. Infrastructure spending is divided into six categories of work: substation  
 10 rebuilds, subdivision rebuilds, main feeders, networks, overhead line work, and automation.  
 11 Each category is described further below.

12



1 **Substation Rebuilds (A)**

2 *Overview*

3 London Hydro has been gradually eliminating 4.16 kV and 13.8 kV substations through voltage  
 4 conversion projects. These conversion projects replace distribution assets at end of life with  
 5 modern equivalents that operate at the standard voltage of 27.6 kV. This higher voltage reduces  
 6 system losses and increases capacity. However, in the interim, the reliability of the 4.16 kV  
 7 system must be sustained; therefore, investment will continue in projects that help to sustain the  
 8 existing substations, including projects that involve the refurbishment of switchgear, relays and  
 9 egress cables, etc. that is required for the safe and reliable operation of the substation. These  
 10 projects also include the replacement of relays, battery banks and communication equipment.

11 *Capital Spending*

12 Forecasted spending for Substation Rebuilds for the proposed 2017 Test Year is \$125,000;  
 13 \$295,752 lower than the 2013 Actuals. Table 2-20 below divides Substation Rebuilds spending  
 14 to the project type.

15 **Table 2-20 – Substation Rebuilds Capital Spending 2012 – 2017**

<b>SUBSTATION REBUILDS CAPITAL SPENDING</b>							
<b>Annual Spending</b>	<b>2012 Actual</b>	<b>2013 Actual</b>	<b>2013 Board Approved</b>	<b>2014 Actual</b>	<b>2015 Actual</b>	<b>2016 Bridge</b>	<b>2017 Test</b>
	\$	\$	\$	\$	\$	\$	\$
Downtown network supply reinforcement	10,361	-	-	-	-	-	-
Substation installations/refurbishments	525	183,850	-	(10,000)	-	-	-
Relay replacements	25,278	32,040	25,000	110,033	63,787	80,000	80,000
Battery bank replacements	15,435	11,427	30,000	11,018	12,065	15,000	15,000
Switchgear modifications	32,636	107,589	120,000	81,590	142,207	-	-
Switch replacements	76,362	976	-	56,975	57,918	-	-
Voltage conversion	82,303	53,578	-	89,880	-	-	-
Vault Renewal and RTU Standardization	-	23,722	30,000	126	42,598	30,000	30,000
Other	-	7,570	15,000	-	-	-	-
<b>Total</b>	<b>242,899</b>	<b>420,752</b>	<b>220,000</b>	<b>339,622</b>	<b>318,575</b>	<b>125,000</b>	<b>125,000</b>
Annual Change		177,852	(200,752)	(81,129)	(21,048)	(193,575)	-

16

17



1 | To reduce costs, when substations are  
2 decommissioned, parts that could be used to  
3 maintain the remaining substations are  
4 salvaged; although, certain components such  
5 as relays or battery banks must be replaced  
6 with new ones. This approach has resulted in a  
7 general decline in the capital spending required  
8 to sustain the remaining substations. In some  
9 areas, a substation may require upgrades to  
10 extend its useful life long enough to allow the  
11 area to be converted, which can result in capital spending on switchgear modifications. For the  
12 Bridge and Test Years, only minor capital investments are required.





1 **Subdivision Rebuilds (B)**

2 *Overview*

3 Project categories relating to underground distribution plant that are planned for 2016 and 2017  
 4 have been selected based on the recommendations of the Asset Sustainment Plan and  
 5 SPOORE analysis (see Appendix G of the Distribution System Plan), which identify assets  
 6 approaching end of life or at risk of failure. The central focus of all these projects is to maintain  
 7 reliability and safety of the distribution grid in a manner that is consistent with the long-term  
 8 planning strategies. Projects include the rehabilitation of underground cable by means of  
 9 silicone injection and/or replacement in underground residential subdivisions, the continuation of  
 10 the replacement of air-insulated switching enclosures, the replacement of leaking padmounted  
 11 transformers, the replacement of dry-type vault transformers inside of buildings, the conversion  
 12 of 4.16 kV and 13.8 kV underground system equipment and other smaller projects outlined  
 13 below.

14 *Capital Spending*

15 Forecasted spending for Subdivision Rebuilds for the proposed 2017 Test Year is \$4,389,000,  
 16 which is \$1,166,027 lower than the 2013 Actuals. Table 2-21 below divides Subdivision  
 17 Rebuilds spending into project type.

18 **Table 2-21 – Subdivision Rebuilds Capital Spending 2012 – 2017**

SUBDIVISION REBUILDS CAPITAL SPENDING							
Annual Spending	2012 Actual	2013 Actual	2013 Board Approved	2014 Actual	2015 Actual	2016 Bridge	2017 Test
	\$	\$	\$	\$	\$	\$	\$
Silicone Injection of Underground Cable	792,460	1,856,705	1,165,000	2,323,405	2,528,992	1,891,000	2,711,000
Conversions and Rebuilds with Silicone Injection	3,051,901	1,821,492	2,000,000	979,680	709,546	700,000	75,000
Air-Insulated Sectionalized Enclosures	492,255	512,158	480,000	350,100	221,833	246,000	293,000
Replace leaking transformer	1,115,183	1,091,724	1,050,000	570,360	1,493,000	700,000	700,000
Rebuild or Convert Vault Areas	152,397	264,152	385,000	91,029	170,696	166,000	144,000
Underground Conversions	85,744	370,753	468,000	329,213	731,287	1,489,000	556,000
Backup Supply and Fault Indicator Installations	109,326	61,638	40,000	52,886	181,561	90,000	90,000
Miscellaneous Subdivision Projects	33,610	20,456	25,000	22,015	26,322	20,000	20,000
Transformer Returns	-	(444,051)	-	(236,087)	(667,306)	(200,000)	(200,000)
<b>Total</b>	<b>5,832,875</b>	<b>5,555,027</b>	<b>5,613,000</b>	<b>4,482,600</b>	<b>5,395,930</b>	<b>5,102,000</b>	<b>4,389,000</b>
Annual Change		(277,847)	57,973	(1,072,427)	913,330	(293,930)	(713,000)


19

20

1 *Silicone Injection of Underground Cable / Conversions and Rebuilds with Silicone Injection*

2 These projects include either the rehabilitation of underground cable through the use of silicone  
3 injection or full cable replacement where injection is not possible. In 2002, London Hydro used  
4 the silicone injection process to rehabilitate several kilometres of underground cable in the  
5 Westmount West subdivision. The project was a great success given that no cable failures have  
6 occurred in that area since that time. The rehabilitation/replacement process has resulted in  
7 approximately 400 km of cable being addressed since 2001 and will result in the planned  
8 completion of 41 km of cable in 2016 and 35 km in 2017. A total of 198 transformers will also be  
9 replaced during 2016 and 2017 as part of this work. Silicone injection technology increases the  
10 lifespan of polymeric cable by adding up to another 40 years of service, and this method is  
11 much more cost effective than replacing cables, especially those that are direct-buried.

12 Six subdivisions were selected for silicone injection work in 2016: Cleardale West (13 km),  
13 Somerset Ridge Phase 1 (6.2 km), Hutton Gate (1.4 km), Sherwood Forest (8.8 km), Somerset  
14 Ridge Phase 2 (7.1 km), and Joklin (1.9 km). Nine subdivisions have been selected for silicone  
15 injection work in 2017: Berkshire Village (0.4 km), White Oaks West (10.8 km), Byron Woods  
16 (4.0 km), Belmont (2.9 km), Waterman Avenue (1.4 km), Whitlow Estates (4.8 km), Huron  
17 Village (4.4 km), Huntington Meadows (4.5 km),  
18 and Glenora Drive (0.8 km). These subdivisions  
19 were selected using the SPOORE analysis,  
20 which measures safety, performance,  
21 operability, outage risk and environmental  
22 impact of the underground cable. The analysis is  
23 based on a multi-year performance window,  
24 which takes into account age and failure rate of  
25 cables and transformers, as well as the  
26 presence of transformer leaks.



27 The rehabilitation project also includes the replacement of 158 single phase padmounted  
28 transformers that have deteriorated, are leaking or do not meet current standards. The new  
29 transformers will be equipped with dual load break switches that provide operational flexibility  
30 and are expected to reduce downtime for customers by allowing more effective restoration and

1 regular maintenance switching. These investments also improve employee safety in eliminating  
2 live front equipment on the system.

### 3 *Air-Insulated Sectionalizing Enclosures*

4 This project involves the replacement of  
5 air-insulated sectionalizing enclosures  
6 (sometimes referred to as switching  
7 enclosures or padmounted switchgear).  
8 In 2006, a report was prepared that  
9 detailed the problems posed by these  
10 enclosures and recommended solutions  
11 for addressing the rash of failures of the  
12 units in service. As presented in the  
13 report, the solution calls for the  
14 replacement or elimination of these units  
15 wherever possible. The replacement



16 units are non-air-insulated and are not prone to the same modes of failure as the air-insulated  
17 units. The program will be entering its twelfth year in 2016 and it is expected to be completed by  
18 2021. This program has proven to be effective by the decrease of in-service failures. As we  
19 address the higher risk units, the probability for failure and customer impact diminishes.

### 20 *Replace Leaking Transformers*

21 This project addresses the problem of transformers that are found to be leaking oil and cannot  
22 be repaired in the field. For both pole-top and padmounted transformers, oil leakage is detected  
23 through DSC inspections or through customer or staff notification. Notwithstanding the fact that  
24 fixing the problem immediately is a requirement of the Ministry of the Environment, fixing it early  
25 avoids a more costly cleanup and potentially lengthy outage in the future.

26 To ensure all transformers (both pole-mounted and padmounted) are inspected every three  
27 years, London Hydro has divided the City into a grid and audits the condition of the transformers  
28 for one-third of the system each year. These audits help identify potentially defective/end-of-life  
29 or leaking transformers for replacement.

1 London Hydro takes its environmental  
2 responsibilities seriously and, therefore,  
3 continues to invest capital dollars in the  
4 identification and removal of these  
5 problematic transformers. This budget item  
6 also includes funding for the replacement of  
7 transformers that have failed in the field or  
8 require immediate replacement, prioritized  
9 according to audit results. The cost to  
10 replace a typical padmounted transformer  
11 ranges from \$7,500 to \$20,000 depending



12 on its type and size. In an effort to reduce some of the transformer costs, London Hydro has a  
13 transformer rebuild program through which transformers removed from service as part of the  
14 4.16 kV and 13.8 kV conversion program are rebuilt for our 27.6kV system. Savings from this  
15 program can reach 75% of the cost of a new transformer depending on the transformer  
16 specifications. On average, London Hydro has been replacing approximately 60-80 units a year.  
17 Spending in this area has been high due to the increased amount of rehabilitation work in  
18 underground subdivisions that has been required outside of the annual DSC inspections.

### 19 *Rebuild or Convert Vault Areas*

20 These projects involve the rebuilding or converting of transformer vaults that are deteriorating,  
21 have reached the end of their useful life and are outside of the DSP conversion plan areas.

22 Transformer vaults are usually located on  
23 customer-owned premises, such as in apartment  
24 building basements, school vaults etc. London  
25 Hydro requires permission from the owner to  
26 upgrade the service and, therefore, engages the  
27 customer in the decision-making process.  
28 Selection information is gathered during DSC  
29 inspections. The transformer vault replacement  
30 projects are also coordinated with the 13.8 kV and  
31 4.16 kV conversion projects when possible.



1 *Underground Conversions*

2 The projects in this area involve the replacement or conversion of the underground systems, as  
3 outlined in the conversion plans. They include replacement of cables, switchgears, padmounted  
4 transformers, transformer vaults and customer-owned substations. These conversions require  
5 very close co-ordination with the overhead line conversions that are outlined later in this  
6 document.

7 Some of the conversions are for 13.8 kV non-network commercial customers in the downtown  
8 core which include supply from existing vaults and maintenance holes. While some civil work  
9 such as ducts or maintenance hole replacement on private property is covered under this  
10 section any work required on the vaults and maintenance holes in the downtown core network  
11 and non-network systems is covered in the Networks Section on page 60.

12 *Backup Supply and Fault Indicator Installations*

13 These projects are targeted at improving  
14 reliability by reducing restoration time. These  
15 projects achieve this goal through the  
16 installation of a looped underground system  
17 versus a radially supplied system, or through  
18 the installation of fault indicators on mini-pad  
19 transformers. The looped underground  
20 system allows crews to isolate a section of  
21 faulted cable to a small area and restore  
22 power to most if not all customers quickly.  
23 The fault indicators allow crews to identify  
24 faulted cables quickly within underground  
25 subdivisions, accelerating power restoration efforts.





## 1 **Main Feeders (C)**

### 2 *Overview*

3 London Hydro has made significant investments in order to increase the available capacity of  
4 our 27.6 kV distribution system. These investments have resulted in desirable loading levels on  
5 our feeders while also improving our reliability performance by reducing the average number of  
6 customers that are connected to a feeder. By maintaining proper loading levels on our feeder  
7 circuits, we ensure that we have sufficient flexibility to accommodate the majority of operating  
8 conditions that occur during peak and non-peak load periods, as well as to handle the natural  
9 system load growth.

10 Currently, London Hydro has energized 50 of the 52 feeder positions that are available at the  
11 Hydro One transformer stations. In 2016 and 2017, we will continue to reinforce our system  
12 capacity by constructing feeder enhancements in parts of the City where reinforcement is  
13 needed or operating flexibility is constrained.

14 London Hydro will also combine plans to integrate the new Nelson 27.6kV transformer station  
15 scheduled for completion in 2018 into immediate projects such as road improvements that are  
16 initiated by the City of London, 27.6kV supplies to the City core, and replacement of aging  
17 infrastructure. By considering all drivers relating to projects in a common geographic area, we  
18 are able to maximize the effectiveness of capital expenditures.

### 19 *Capital Spending*

20 Forecasted spending for Main Feeders for the proposed 2017 Test Year is \$3,375,000;  
21 \$2,336,962 higher than the 2013 Actuals. Table 2-22 below breaks down Main Feeders  
22 spending to the project type.

23

1 **Table 2-22 – Main Feeders Capital Spending 2012 – 2017**

MAIN FEEDERS CAPITAL SPENDING							
Annual Spending	2012 Actual	2013 Actual	2013 Board Approved	2014 Actual	2015 Actual	2016 Bridge	2017 Test
	\$	\$	\$	\$	\$	\$	\$
Reinforcements	456,904	575,177	989,000	344,509	153,939	-	-
Extensions & Installations	639,989	447,869	-	2,182	-	-	-
Conversions	2,628	1,545	-	35,415	1,544,346	1,492,000	815,000
Backup Supply & Civil Structure Installations	-	13,447	-	663,895	1,035,484	2,490,000	2,560,000
<b>Total</b>	<b>1,099,522</b>	<b>1,038,038</b>	<b>989,000</b>	<b>1,046,001</b>	<b>2,733,769</b>	<b>3,982,000</b>	<b>3,375,000</b>
Annual Change		(61,483)	(49,038)	7,962	1,687,768	1,248,231	(607,000)

2  
 3 *Extensions & Installations – 2012-2013*

4 Spending in 2012 was high in this area primarily due to a feeder extension on Wellington Road  
 5 from Scotland Drive to Glanworth Road.

6 Spending in 2013 was high in this area due to main feeder replacements at Maitland Street &  
 7 Nelson Street to King Street & Waterloo Street, which coincided with a major City infrastructure  
 8 and road works project.

9 *Conversions – 2015-2017*

10 A multi-year voltage conversion of 13.8kV loads to 27.6kV will facilitate the removal of aging  
 11 distribution infrastructure, as well as address the long-term strategic plans described in the  
 12 "London Downtown – 13.8kV/27.6kV Nelson TS - 5 Year Plan" report, which recommends the  
 13 conversion of the non-network downtown core to 27.6kV supply. See Appendix J of the DSP for  
 14 additional information.

15 The work proposed for 2016 and 2017 relate to the second and third years of a multi-year  
 16 strategic plan to resupply non-network 13.8kV loads at 27.6kV supply. This work is also  
 17 coordinated with other plans that will address the age and condition of the existing 13.8kV  
 18 Nelson TS supply from Hydro One.

19 Three projects are scheduled for 2016:

- 20 1. William Street (York Street to Central Avenue)
- 21 2. Central Avenue (Adelaide Street to Colborne Street)
- 22 3. South Street Colborne Street to Wellington Road




1 Seven projects are scheduled for 2017:

- 2 1. Queens Avenue (Waterloo Street to Colborne Street)
- 3 2. Waterloo Street (Queens Avenue to Central Avenue)
- 4 3. Princess Avenue (City Hall to Colborne Street)
- 5 4. Pall Mall Street (Richmond Street to Waterloo Street, south to Central Avenue, east to
- 6 Colborne Street)
- 7 5. King Street (Waterloo Street to William Street)
- 8 6. York Street (Burwell Street to Florence Street)
- 9 7. Carling Street (Richmond Street to Talbot Street)

10 The above projects are separated strategically to permit staging of conversion and severing of  
11 13.8kV ties.

12 **Figure 2-1: Five Year 13.8 kV to 27.6 kV Conversion Plan**



13

14 New Main Feeder Ties (component of Conversions above)

15 The initiatives outlined in the "4.16kV Aging Infrastructure System Planning Report (2011)"  
16 require rebuilding and converting all the 4.16kV plant within three specified areas, identified as  
17 Zones 'A', 'B' & 'C'. In addition, the proposed rebuilds replace deteriorating infrastructure,

1 thereby meeting the criteria outlined in the "Asset Sustainment Plan, 2015 - 2029 Report" (see  
2 DSP Appendix G for the Asset Sustainment Plan contained in the Asset Management Plan).

3 In 2015, London Hydro commenced rebuilding and converting the Zone 'B' area. This first year  
4 of Zone 'B' conversion focused on the voltage conversions along Dundas Street and the circuits  
5 supplied off of Dundas Street between Clarke Road and Edmonton Street. For 2016, the first  
6 project will be the second phase of the rebuilding and conversion of Dundas Street between  
7 Third Street and Saskatoon/Second Street and will complete the main feeder tie between Clarke  
8 Road and Saskatoon/Second Streets. This feeder build work will be coordinated with a  
9 neighbouring depreciated overhead area project that is along Dundas Street.

10 The second project consists of an additional 27.6kV tie along Third Street between Dundas  
11 Street and Parkhurst Avenue. The Network Planning Department has identified a need to have  
12 a tie between the 70M8 and 4M12/4M18 feeders in this area of the City to assist with the  
13 backup and reconfiguration of load. Also, a long radial section of the 29F4 4.16kV feeder will be  
14 converted to 27.6kV as part of the Zone 'B' conversion area, improving reliability and providing a  
15 backup supply.

16 Additional projects include installing reclosers/automated switches to help reconfigure the  
17 27.6kV feeders and to offload the 32M4 feeder. This offloading will aid in reliability and help  
18 balance loading and transfer capability.

#### 19 *Backup Supply & Civil Structure Installations*

20 Much of the downtown core electrical system is comprised of vintage 1950's 13.8kV equipment,  
21 maintenance holes and duct systems. The City has created incentives to encourage  
22 construction of multi-residential units in the core. The resulting new development, in turn, places  
23 increased demand on the older electrical system. London Hydro has created the "London  
24 Downtown – the 13.8kV/27.6kV Nelson TS – 5 Year Plan" and the "London Downtown Long  
25 Term 27.6kV Supply and 13.8kV Decommissioning Strategy (2014)" reports to ensure the  
26 coordinated strategic conversion of the 13.8 kV non-network system to a 27.6 kV system to re-  
27 supply existing load, meet projected future demand and rebuild fully-depreciated downtown core  
28 systems with the integration of a new Nelson TS 27.6 kV substation.



1 The backup supply project intends to leverage the only other 27.6kV circuit nearby to back-up  
2 the 26M51 feeder. As well, the 27.6kV-13.8kV stepdown distribution stations (Substation 11 &  
3 Substation 12) that supply the downtown core will be interconnected, thereby providing an  
4 alternative underground backup for what now relies on an overhead circuit as a backup. These  
5 new feeders in the downtown core will increase the adequacy and security of supply to the  
6 downtown by providing additional capacity for growth, the potential to convert aging  
7 infrastructure and, thereby, eliminate lead cable in the core, and provide a much needed backup  
8 for the 26M51 feeder to increase reliability.

9 Approximately one third of the downtown load, including several major customers, is supplied at  
10 27.6kV through the 26M51 feeder via Talbot TS, which is reaching its maximum capacity for  
11 load and includes sections of underground supply cables in a common duct bank without an  
12 alternative supply. Furthermore, the City of London has communicated plans to rebuild Dundas  
13 Street from store-face to store-face for a length of four (4) blocks, which affects a significant  
14 portion of the 26M51 feeder and risks the integrity of supply to customers in the area. This two-  
15 year project will include extensive infrastructure rehabilitation along Dundas Street from  
16 Wellington Road to the Thames River and is scheduled to start in 2017. In conjunction with the  
17 City's projects, London Hydro will replace fully-depreciated assets, which inspections have  
18 deemed require replacing, install concrete-encased duct and maintenance hole systems, and  
19 rebuild and modernize the existing electrical distribution system along Dundas Street. The  
20 installation of this infrastructure will also permit London Hydro to install future main feeder  
21 circuits and provide the City's core with a scalable 27.6 kV supply.

22 Additionally, the City of London will be conducting extensive infrastructure rehabilitation along  
23 the sections of South Street between Colborne Street and Wellington Road in 2016. In  
24 conjunction with the City's projects, London Hydro will install concrete-encased duct and  
25 maintenance hole systems. The installation of this infrastructure will permit London Hydro to  
26 install future main feeder circuits that will originate from the rebuilt Nelson Transformer Station.

27

1 **Networks (F)**

2 *Overview*

3 The Network system supplies customers in the downtown core area and shares common  
4 infrastructure with the 27.6kV system and the non-network 13.8kV system. This system is  
5 comprised of five primary feeders that supply 75 submersible transformers. The transformers  
6 are located in vaults situated below the sidewalks at various locations throughout the area. The  
7 secondaries of the transformers are connected together such that if one transformer or primary  
8 cable fails, the remaining transformers continue to supply the load.

9 Over the past 10 years, a substantial amount of replacement work has been completed on the  
10 transformer fleet. As well, sections of the primary and secondary cable systems have been  
11 replaced. During the replacement of the cables, the system is often reconfigured to eliminate  
12 congestion. Cables are sometimes rerouted in an effort to eliminate situations in which the  
13 failure of one component can affect many. Existing lead-covered cables (PILC) are being  
14 replaced with a non-lead alternative (EPR – ethylene propylene rubber) to improve health and  
15 safety and reduce environmental concerns associated with PILC cables. The end product is a  
16 more robust, safer and environmentally beneficial system, which benefits customers as outage  
17 duration (SAIDI) should be reduced.

18 Another area of focus is ensuring the structural condition of vaults and maintenance holes  
19 (vaults contain transformers, maintenance holes contain cables). In 2012, safety concerns  
20 within the downtown core maintenance vaults resulted in London Hydro engaging a structural  
21 engineering consultant to assess the condition of maintenance holes and vaults in the core  
22 area. In order to obtain an accurate assessment of the condition of the structures, the consultant  
23 inspected one half of all structures including a sampling of the oldest structures in the system.  
24 The resultant report ("Summary Report of Structures Inventory – Maintenance Holes & Network  
25 Transformer Vaults (Phase 1 - 2012)" outlines a priority schedule for replacement/refurbishment  
26 along with projected expenditure levels.

27 The general recommendation, in line with the report, was that London Hydro did not need to  
28 replace vaults when they reach their estimated end of life but rather continue with inspection  
29 protocols to determine if the life of the asset could be safely extended. A five-year inspection  
30 cycle was also recommended for London Hydro civil structures.

1 The DSC does not specify an inspection regime for non-electrical components, but London  
2 Hydro has developed an inspection checklist (as part of the EIAM audit process) that must be  
3 completed by staff when they perform audits on network transformers, which occurs once every  
4 two months on average. The inspection covers the condition of the vault's walls, roof slabs,  
5 access grates, ladders, pumps and lighting system. See Exhibit 4, Section "London Hydro's  
6 Electrical Inspection and Maintenance  
7 Program ("EIAM"), for more information  
8 on these audits.

9 At times, London Hydro would abandon  
10 a vault after removing all the electrical  
11 components while keeping the civil  
12 structure in place. The civil structure  
13 could pose a risk to public safety if it  
14 were allowed to deteriorate; therefore,  
15 even abandoned vaults continue to be  
16 inspected until fully removed.



17 Similar to maintenance hole rebuilds, network transformer vault rebuilds at an existing site are  
18 costly due to the complexity of construction. Most vaults are rebuilt in the same location,  
19 especially when space in the downtown core to construct new vaults is limited. Vault rebuilds,  
20 while maintaining customers' electrical services, require cable reconfigurations or temporary  
21 supply installations, removal of the network transformer, repair and/or rebuilding of parts or the  
22 entire vault and the subsequent installation of the new transformer and associated cables. In  
23 general, vaults house a single network transformer, but some can house up to four  
24 transformers. On occasion, rebuilding a vault may not be necessary as its condition can be  
25 improved by refurbishing it for a lower cost.

26

1 **Figure 2-2 – Image of Corroded Network Transformer & Vault Severe Delamination**



2

3 *Capital Spending*

4 Forecasted spending for Networks for the proposed 2017 Test Year is \$2,070,000; \$955,146  
5 higher than the 2013 Board Approved Year. Table 2-23 below breaks down Networks spending  
6 to the project type.

7 **Table 2-23 – Networks Capital Spending 2012 – 2017**

NETWORKS CAPITAL SPENDING							
Annual Spending	2012 Actual	2013 Actual	2013 Board Approved	2014 Actual	2015 Actual	2016 Bridge	2017 Test
	\$	\$	\$	\$	\$	\$	\$
Replacement of Network Vaults, Maintenance Holes and Transformers	839,431	616,923	530,000	1,324,019	1,537,231	1,000,000	1,020,000
Replacement of Primary/Second Cable	484,417	199,082	340,000	384,082	50,059	380,000	750,000
East End Network	425,361	55,299	120,000	-	-	-	-
Maintenance Hole Cable Rebuilds & Fuse Installs	40,344	243,550	150,000	142,460	539	550,000	300,000
Maintenance Hole Cable Protection	-	-	-	-	387,412	-	-
<b>Total</b>	<b>1,789,554</b>	<b>1,114,854</b>	<b>1,140,000</b>	<b>1,850,561</b>	<b>1,975,242</b>	<b>1,930,000</b>	<b>2,070,000</b>
Annual Change		(674,700)	25,146	735,708	124,680	(45,242)	140,000

8  
9

1 *Replacement of Network Vaults, Maintenance Hole and Transformers*

2 Spending in this area has been at an increased level since 2014, when compared to prior years.  
3 As previously mentioned, in late 2012, London Hydro solicited a civil engineering firm to conduct  
4 inspections of maintenance holes and network transformer vaults. An average yearly capital  
5 expenditure of \$650,000 (civil portion) over the next ten years was recommended by the  
6 consultant, in addition to a larger one-time expenditure in the first year of the plan of \$890,000,  
7 to be used to replace and rehabilitate the assets indicated. Based on the recommendations  
8 given, capital spending on these replacements has been occurring at the escalated level since  
9 that time.

10 *Replacement of Primary / Secondary Cable – 2017*

11 The 13.8kV system, including Nelson TS  
12 13.8kV equipment, is nearing end of life. The  
13 initiatives outlined in the "London Downtown -  
14 13.8kV/27.6kV Nelson TS - 5 Year Plan" require  
15 offloading of the 13.8kV system via conversions  
16 to 27.6kV. To improve operational flexibility and  
17 be able to restore all customers in the event of  
18 a failure on the network system, this project  
19 intends to convert 13.8kV network customers  
20 on Dufferin Avenue from Waterloo Street to  
21 Wellington Street and on Wellington Street from  
22 Waverly Place to Queens Avenue to 27.6 kV.

**Faulted Cable**




23 Reduction of this network load will facilitate the removal of lead cable resulting in increased duct  
24 space available for new 27.6 kV supplies. For greater economic and safety benefits, the new  
25 supply configuration will utilize standard switchable padmounted transformers instead of the  
26 present vault style network transformers by leveraging available above grade options. The six  
27 network transformers that will be reclaimed will be refurbished and used to avoid the purchase  
28 of new network transformers required to address high loads at another customer location and to  
29 replace older units on the system with a value nearly equivalent to the cost of this project.

1 This project directly affects 13 GS>50 customers whose systems will be converted, and  
2 indirectly affects an additional 4,000 low-volume customers in the wider service territory of  
3 Nelson TS.

4 *Maintenance Hole Cable Rebuilds & Fuse Installs*

5 This budget item will cover the installation of cable protecting fuses in the mains of the low  
6 voltage grid. A characteristic of the network supply system is high secondary supply fault  
7 energy, which can lead to detrimental failures. These fuses limit the fault energy during the  
8 failure of the downstream device and decrease the probability of catastrophic failures, which  
9 reduces the impact on public safety and customer outages.

10 Explosions in maintenance holes are low  
11 probability/high impact events. The energy  
12 released in a major maintenance hole  
13 explosion can launch an 80 kg cast-iron  
14 maintenance hole cover 15m or more. Such  
15 explosions are typically caused by the ignition  
16 of combustible gases that accumulate in  
17 maintenance holes due to overheating cable  
18 insulation or to non-London Hydro sources,  
19 such as natural gas leaks and dumped  
20 chemicals. It may also be possible for high-  
21 current arcs to cause maintenance hole  
22 explosions when combustible gases are not  
23 present.



24 To reduce the potential impact of maintenance hole explosions, London Hydro will install  
25 maintenance hole covers designed to provide a controlled release of pressure during  
26 explosions. By latching the maintenance hole cover to the maintenance hole frame and  
27 designing exhaust ports into the bottom of the cover, explosion-limiting maintenance hole  
28 covers lift only a few inches during an explosion and create an air-dam that limits the force of  
29 the explosion. In 2016, London Hydro will install 80 explosion-limiting maintenance hole covers  
30 on a trial basis.





1 *Maintenance Hole Cable Protection - 2015*

2 The purpose of this project was to supply and install temperature current monitoring devices  
3 onto existing secondary network XLPE 600 volt cable. High temperature on secondary network  
4 cables indicates an overload situation, which could lead to a catastrophic failure. These devices  
5 are used at various spot network locations throughout the downtown and provide 24/7  
6 temperature monitoring to the Control Room Operators.

7 As part of this project, a dedicated fibre optic cable was installed from London Hydro facilities to  
8 an off-site secondary location to provide isolation of the SCADA system from the IT Disaster  
9 Recovery system. Previous to this work, both SCADA and IT Disaster Recovery shared one  
10 fibre optic cable, which for security and operational concerns, was not ideal. This project  
11 provided the IT Disaster Recovery system with its own dedicated cable. The existing fibre cable  
12 provided SCADA monitoring for the temperature devices, and reclaimed strands from the  
13 shared cable were re-purposed to provide SCADA communication and control for the downtown  
14 core loop feed system between Substations #10, #11, #12 and switch-gear LC4854 to the  
15 SCADA mainframe.

16

## 1 **Overhead Line Work (G)**

### 2 *Overview*

3 In 2016, London Hydro's overhead distribution system includes approximately 28,000 poles  
4 (roughly 99% of which are made of wood), 7,630 overhead transformers and approximately  
5 1,379 km of primary overhead conductors. London Hydro also has 237 manually operated 27.6  
6 kV loadbreak switches and 161 automated 27.6 kV switches on its overhead system.

7 The budget for overhead lines is driven largely by the Asset Sustainment Plan and the 4.16 kV  
8 Planning Report. The 4.16 kV system largely consists of overhead distribution and is the oldest  
9 of all of the distribution grids within London. Both of these documents recommend the  
10 refurbishment of the aging 4.16 kV distribution system. Portions of the 13.8 kV downtown  
11 system are also approaching end of life and need to be converted to 27.6 kV to accommodate  
12 the voltage conversion of the Nelson TS from 13.8 kV to 27.6 kV.

13 Because they have been found to break under normal use, porcelain insulators have been  
14 identified by an external consultant and our internal engineering staff as a significant safety risk  
15 to the line maintainers who work on these circuits on a regular basis. Through the porcelain  
16 insulator replacement program, London Hydro will continue to replace all insulators on the 27.6  
17 kV system.

18 In recent years, London Hydro has experienced a surge in copper theft, resulting in many of the  
19 ground wires at transformers being cut and stolen. These thefts affect both public and employee  
20 safety, as well as system performance. London Hydro has found that the use of copper-clad steel  
21 wire is effective in preventing this theft. Going forward, copper-clad steel wire will be used for new  
22 installations and replacements/repairs in affected areas. The on-going replacement of stolen  
23 copper ground wires with Copperclad wire is expected to continue at approximately 300 locations  
24 per year for the next several years.

25 Firon in-line switches have proven to have a poor performance record as multiple failures of the  
26 same mode have occurred. A recent audit of the 27.6 kV system identified the remaining Firon  
27 switches on our system (approximately 90). Replacements will be completed in 2016.

28 London Hydro will continue to enhance system protection with respect to outages caused by  
29 lightning, foreign contacts and other defective components by using strategies such as



1 additional insulation, additional lightning arresters, lightning sky wires and protective cover-up  
 2 on new and existing feeders that have been identified as poor performers. This work will be  
 3 done in a prioritized manner.

4 *Capital Spending*

5 Forecasted spending for Overhead Line Work for the proposed 2017 Test Year is \$4,530,000;  
 6 \$482,438 higher than the 2013 Actuals. Table 2-24 below breaks down Overhead Line Work  
 7 spending to the project type.

8 **Table 2-24 – Overhead Line Work Capital Spending 2012 – 2017**

OVERHEAD LINE WORK CAPITAL SPENDING							
Annual Spending	2012 Actual	2013 Actual	2013 Board Approved	2014 Actual	2015 Actual	2016 Bridge	2017 Test
	\$	\$	\$	\$	\$	\$	\$
Replacement of Fully Depreciated/Deteriorated Poles and Poles Susceptible to Fire	948,911	509,558	600,000	668,105	495,465	520,000	410,000
Arrestor/Insulator/Other	4,949	80,748	100,000	796,858	950,244	880,000	580,000
Rebuild Fully Depreciated Overhead Areas	2,514,411	814,383	200,000	228,610	316,131	300,000	260,000
Reliability/Outage Mitigation	450	127,350	250,000	296,880	1,655	-	-
Overhead Voltage Conversions	101,092	2,515,522	4,000,000	2,837,901	2,388,036	2,180,000	3,280,000
<b>Total</b>	<b>3,569,813</b>	<b>4,047,562</b>	<b>5,150,000</b>	<b>4,828,353</b>	<b>4,151,531</b>	<b>3,880,000</b>	<b>4,530,000</b>
Annual Change		477,748	1,102,438	780,792	(676,822)	(271,531)	650,000

9  
 10 *Replacement of Fully-Depreciated/Deteriorating Poles and Poles Susceptible to Fire*

11 London Hydro tests all poles identified as being in poor or fair condition as well as poles that  
 12 have been in-service for over 20 years. The testing involves performing a visual check of the  
 13 pole and its equipment, hammering the pole to listen for hollow sounds (referred to as "sound  
 14 test"), as well as obtaining a core sample from the base of the pole, when required.

15 Decaying and deteriorated poles are always an area of concern with respect to the overhead  
 16 system. London Hydro presently purchases fully treated, pentachlorophenol cedar poles that  
 17 are commonly used in Ontario due to their natural resistance to decay. As part of the ongoing  
 18 condition assessment program, 3,000 to 4,000 poles are tested on an annual basis and, as a  
 19 result, an average of 37 poles is recommended for treatment or replacement. Poles that have  
 20 been identified as being high risk, typically 35 to 40 per year, are scheduled for replacement to  
 21 prevent failure.

1 Pole fires are another area of concern.  
2 Poles fires occur in specific older types  
3 of overhead construction in which  
4 leakage current becomes concentrated  
5 in places where bolts and wood  
6 intersect. This current produces heat,  
7 which results in a fire. Specific areas  
8 with this type of construction are  
9 targeted for refurbishment on a  
10 prioritized basis.

11 Another area designated for  
12 replacement includes plant built more  
13 than 40 years ago and aged materials and  
14 construction techniques that are more prone to failure than those used today. The deficiencies  
15 related to the age of the equipment, some of which is approximately 50 years old may adversely  
16 affect the reliability of customer supply as well as public and employee safety. The rebuild areas  
17 vary in size and complexity of work, resulting in differing budget amounts compared to the  
18 number of areas completed. London Hydro anticipates that by 2020, it will have addressed the  
19 susceptible poles identified and any remaining poles would be replaced under other programs.

20 *Arrestor / Insulator / Other - 2014-2017*

21 In July 2014, an event occurred in which a porcelain insulator broke, causing the 27.6 kV line to fall  
22 onto the underbuilt 4.16 kV circuit, which, in turn, caused considerable damage to related  
23 customers electrical services. As a result of this incident, three measures were implemented to  
24 mitigate possible similar events, based on recommendations from a consultant. Station class  
25 arrestors were installed on 4.16 kV circuit laterals. Secondly, porcelain insulators are being  
26 replaced on overbuilt circuits at different locations so that the mitigation measures cover larger  
27 areas. The third measure involves 27.6 kV voltage conversion of overhead transformers on 4.16  
28 kV laterals that are abandoned, if feasible.



**Failed Porcelain Insulator**



1 An audit identified circuits that share lines of both  
2 voltages, which indicated that approximately 400 poles  
3 are supporting a total of 1,300 porcelain insulators on  
4 27.6 kV. Starting in 2014, the pace of porcelain  
5 insulator replacements was accelerated due to the  
6 risks identified by the consultant, and all porcelain  
7 insulators on the identified shared voltage pole lines  
8 were replaced by the end of 2015. The pace of replacement is continuing in 2016 as the remaining  
9 porcelain insulators (not on shared voltage lines) are replaced over the next five years. The  
10 replacement of Firon switches (approximately 90) and the ongoing replacement of stolen copper  
11 ground wires with Copperclad wire are also covered under this budget item.

#### 12 *Rebuild Fully-Depreciated Overhead Areas*

13 London Hydro has established a set of criteria to be used when prioritizing which fully-depreciated  
14 overhead areas are to be rebuilt. This criteria includes results from infrastructure audit results, pole  
15 testing results, safety issues, system performance, accessibility and reliability.

16 The following 3 areas were fully-depreciated and upgraded in 2012, causing spending in this area  
17 to spike during that year:

18 1. Old East - Phase 2 of 2. This area  
19 (with boundaries of Elias Street,  
20 Dundas Street, Ontario Street and  
21 Burbrook Place) was deemed the  
22 worst depreciated area in terms of  
23 overall condition. During Phase 1  
24 (2011) overhead infrastructure west  
25 of Quebec Street was rebuilt. Phase  
26 2 involved rebuilding all overhead  
27 infrastructure east of Quebec Street.



28 2. Pond Mills - Phase 2 of 2. The area on the southwest corner of Commissioners Road East  
29 and Pond Mills Road was deemed the second worst depreciated area. Converting this area  
30 will also assist with offloading Substation #15, which experienced a failed transformer in



1        2011. During Phase 1 (2011), London Hydro completed the 3-phase loop section and during  
2        Phase 2, we completed the 1-phase loop sections.

3        3. First / Second Street area - Phase 2 of 2. This area (bordered by Oxford Street East,  
4        Spanner Street, First Street and Second Street) was deemed fourth worst depreciated area.  
5        During Phase 1 (2011), we completed First Street and its radial streets. During Phase 2, we  
6        completed Second Street and its radial streets.

7        The rebuild budget fluctuates from year to year based on the actual assessed condition of the  
8        areas and overall budget priorities.

9        *Overhead Voltage Conversions*

10       Starting in 2012, the pace of 4.16 kV conversions has been high as many of these assets are  
11       approaching end of life. The volume of work is expected to be approximately \$2M to \$3M a year  
12       until 2021. To accommodate the Nelson voltage conversion taking place in 2018, the remaining  
13       13.8 kV overhead lines are being converted to 27.6 kV between 2015 and 2020 (final removal of  
14       13.8 kV as expected to take place in 2021). Total spending on voltage conversions is expected  
15       to be approximately \$4.5M from 2017 to 2020.

16



## 1 **Automation (H)**

### 2 *Overview*

3 One of the key elements that will enhance safety and improve reliability is the installation of  
4 automation enabling equipment. By leveraging the existing technologies that are now available,  
5 we can achieve decreased response time based on real time data from the field. Reclosers are  
6 the main technology used by London Hydro, with some minor investments in the remote  
7 communication devices (RTUs: Remote Terminal Unit), fault indicators, line status indicators,  
8 and the central System Control and Data Acquisition (SCADA) system.

9 Reclosers are electrically operated and computer controlled switches that detect faults on lines  
10 and automatically open to remove the faulted portion of line from the system before the entire  
11 feeder is affected. After a brief pause, the recloser will close and check to see if the fault has  
12 been cleared (often the case for animal contacts) and then re-open if the fault is still present.  
13 These devices communicate with other devices and the central SCADA system to help the  
14 system Control Room Operators isolate problem areas and restore power more rapidly.

15 The RTUs allow field devices to communicate with the central SCADA system to transmit  
16 information in real time and allow the Control Room Operators to open or close devices  
17 remotely.

18 Other devices, such as fault indicators and line status indicators, are being used and tested by  
19 London Hydro to assist with locating problems and restoring power more efficiently.

### 20 *Capital Spending*

21 Forecasted spending for Automation for the proposed 2017 Test Year is \$725,000; \$406,392  
22 higher than the 2013 Actuals. Table 2-25 below divides Automation spending to the project type.

23

1 **Table 2-25 – Automation Capital Spending 2012 – 2017**

<b>AUTOMATION CAPITAL SPENDING</b>							
<b>Annual Spending</b>	<b>2012 Actual</b>	<b>2013 Actual</b>	<b>2013 Board Approved</b>	<b>2014 Actual</b>	<b>2015 Actual</b>	<b>2016 Bridge</b>	<b>2017 Test</b>
	\$	\$	\$	\$	\$	\$	\$
Recloser Installation	173,245	183,677	195,000	212,822	185,367	275,000	195,000
Remote Terminal Unit Replacements	46,451	66,789	50,000	199,051	189,867	130,000	130,000
Miscellaneous Automation	54,793	41,661	90,000	59,431	30,191	250,000	250,000
SCADA	6,476	26,481	-	163,357	81,115	100,000	100,000
Power Quality	-	-	-	34,991	4,009	50,000	50,000
Miscellaneous Control Room General Plant	11,458	-	-	33,244	3,468	-	-
<b>Total</b>	<b>292,424</b>	<b>318,608</b>	<b>335,000</b>	<b>702,897</b>	<b>494,015</b>	<b>805,000</b>	<b>725,000</b>
Annual Change		26,184	16,392	384,289	(208,882)	310,985	(80,000)

2  
 3 *Recloser Installation*

4 London Hydro will continue to install  
 5 reclosers on the 27.6 kV system, adding  
 6 approximately three units per year until the  
 7 entire system has been sectionalized into  
 8 groups of approximately 1,000 customers.  
 9 Reclosers improve system reliability by  
 10 minimizing the number of customers affected  
 11 by an outage and reducing the time required  
 12 to restore power.



13 *Remote Terminal Unit Replacements (RTUs)*

14 Many of the field devices that communicate with the central SCADA system route their  
 15 information through communication devices referred to as RTUs. Many of these devices are  
 16 analog transmission, and are now obsolete and are being replaced with faster technology such  
 17 as fibre optics or wireless digital transmission. Starting in 2012, London Hydro began replacing  
 18 the RTUs with modern equivalents and expects to have all RTUs replaced by 2020.

19 *Miscellaneous Automation*

20 Capital spending in 2016 and 2017 is higher than other years due to the budgeted 'Control  
 21 Centre - Consoles and Digital Schematics' project. Since the Control Room was first



1 constructed, many technological changes have occurred; the introduction of personal  
2 computers, SCADA, flat screen displays, and most recently the Outage Management System  
3 (OMS). To accommodate these changes, the Control Room was altered as each change  
4 occurred. This reactive approach has led to a sub-optimal configuration with respect to both  
5 technology integration and workflow processes, which can compromise customer and employee  
6 safety and increase customer outage response time. To reduce these effects and optimize the  
7 operation of the Control Room, a consultant was hired to design an integrated layout and  
8 technology solution. A series of investments will address the consultant's recommendations  
9 over the course of three to five years. These investments will improve and simplify the visibility  
10 of the system for Control Room Operators, provide faster customer outage response, increase  
11 safety of both public and staff and reduce the reliance on paper-based or inefficient processes  
12 and systems.

13 In 2016, the investment will be used to replace operator consoles to enhance ergonomics and to  
14 develop digital schematics, which will eliminate redundant processes associated with wide-area  
15 paper maps.

16 In 2017, the investment will be used to upgrade  
17 the resolution of the display wall cubes to create a  
18 digital canvas suitable for managing wide-area  
19 outages, thus eliminating the redundant recording  
20 of operations in OMS and on the wall paper maps.

## 21 *SCADA*

22 A System Control and Data Acquisition (SCADA)  
23 system is employed to monitor and cache real-  
24 time data from the London Hydro network and  
25 relay that information to Control Room employees  
26 for action. A reliable and secure SCADA system is  
27 required to monitor and control the distribution  
28 system efficiently. This system enables action to  
29 be taken in a more expedient manner in the event  
30 of an outage to minimize customer effect. The





1 SCADA projects in 2016 and 2017 will enhance components of the system that are either  
2 technically obsolete or inefficient to maintain. Specifically, the projects will increase the reliability  
3 of RTUs, modernize communication protocols and media, secure data against cyber threats,  
4 and develop system intelligence tools that enable automation. Cyber security is always a  
5 concern with data communications equipment and some of the projects in this area will enhance  
6 security and the reliability of the SCADA system by replacing the components of the system that  
7 are technically obsolete and introducing system intelligence tools that will enable automation.

8

## 1 TS Upgrade (CC)

### 2 *Overview*


3 Costs in this area pertain to London Hydro's capital contributions paid to Hydro One for the  
4 decommissioning of the 13.8kV transformer station and the upgrade of the transformer station  
5 to 27.6kV. These contributions are recorded as intangible assets and are depreciated over a  
6 useful life of 45 years. The CCRA (Connection and Cost Recovery Agreement) with Hydro One  
7 is for an indefinite life; therefore the contributions are to be amortized over the useful life of the  
8 associated asset, which is based on the 45 year useful life of power transformers (the major  
9 component) in accordance with the OEB's Kinetrics report.

10 The decision to pay Hydro One to convert Nelson TS from 13.8 kV to 27.6 kV was based on a  
11 collaborative approach to long-term supply options for the City of London, conducted by London  
12 Hydro and Hydro One (Ontario Hydro). The planning started in the early 1980's with the  
13 installation of the Talbot TS (near downtown), which provided 27.6 kV supply to the north side of  
14 the downtown core. At that time, 27.6 kV had become the standard distribution voltage for most  
15 of Ontario, including much of the City of London outside the downtown core. The Nelson TS  
16 was one of the oldest transformer stations in London and had several non-standard designs that  
17 made it more vulnerable to some contingencies. The only other 13.8 kV supply point was at  
18 Highbury TS to the east, which was also approaching end of life and in need of replacement.

19 In 1990, London Hydro and Hydro One  
20 agreed that new connections would be  
21 made only to the 27.6 kV supply (if  
22 possible), and existing 13.8 kV load would  
23 be reduced through conversion. With much  
24 of the 13.8 kV distribution system  
25 approaching end of life, conversion of the  
26 13.8 kV load proceeded at a gradual pace.

27 By 1999, the 13.8 kV station at Highbury  
28 TS was decommissioned, which left the  
29 Nelson TS as the sole supply of 13.8 kV  
30 for London's downtown core.

**"Island" of 13.8 kV - Nelson TS as Sole Supply**





1 In 2005/2006, joint planning meetings with Hydro One examined supply options and needs for  
2 the City of London, with the Nelson TS identified as the preferred location for new supply. In  
3 subsequent years, different scenarios were reviewed and issues at the 13.8 kV Nelson TS  
4 surfaced, which made conversion to 27.6 kV more desirable. Between 2009 and 2014, Hydro  
5 One and London Hydro examined the cost and benefits of keeping Nelson at 13.8 kV or  
6 converting it to 27.6 kV.

7 In early 2015, an agreement was reached whereby Hydro One would rebuild Nelson TS at 27.6  
8 kV with London Hydro responsible for only the incremental cost of conversion. The plan  
9 required London Hydro to accelerate some 13.8 kV conversion plans so that Hydro One could  
10 decommission the 13.8 kV supply in 2021. London Hydro has documented this decision-making  
11 process in a report entitled, "London Downtown - 13.8kV/27.6kV – Nelson TS – 5 Year Plan",  
12 which is referred to in DSP Appendix J. In addition, the plan to convert the 13.8 kV distribution  
13 system and accommodate future connections has been documented in the report entitled,  
14 "Downtown Intensification – December 2015," which is also included in DSP Appendix J. These  
15 two reports provide a comprehensive review of the work needed in the downtown core to  
16 continue to provide safe and reliable supply for the foreseeable future.

### 17 *Capital Spending*

18 Forecasted spending in the TS Upgrade category for the proposed 2017 Test Year is  
19 \$1,882,000. This category is new in this Application, with the first spending occurring in 2015.  
20 Table 2-26 below illustrates TS Upgrade spending by year.

21 Projected 2016 and 2017 costs listed here correspond to a predetermined payment schedule  
22 agreed upon with Hydro One in 2015. Borrowing costs are also capitalized here, utilizing the  
23 OEB's prescribed rates to calculate the Allowance for Funds Used During Construction  
24 (AFUDC). Spending in this area will remain in WIP until the completion of the project, which is  
25 estimated to be 2018.

26

Table 2-26 - TS Upgrade Capital Spending 2012 - 2017

TS UPGRADE CAPITAL SPENDING 2012 - 2017									
Annual Spending	2012 Actual	2013 Actual	2013 Board Approved	2014 Actual	2015 Actual	2016 Bridge	2017 Test	2013 Actuals to 2017 Test	CAGR
	\$	\$	\$	\$	\$	\$	\$	\$	%
TS Upgrade									
Contribution to TS Upgrade	-	-	-	-	1,616,590	1,832,000	1,882,000	1,882,000	
	-	-	-	-	1,616,590	1,832,000	1,882,000	1,882,000	

### Connection and Cost Recovery Agreement

Hydro One has estimated the Avoided Cost Work to be \$30.6 million. This amount represents the total cost of work that would have had to be performed by Hydro One to replace portions of its facilities that have reached end of life at its sole expense if London Hydro had not requested that Hydro One upgrade the Nelson facilities.

Hydro One has estimated the Engineering and Construction costs of the facility upgrade to be \$38.9 million. This amount represents the total cost of equipment, labour and materials at Hydro One's standard rates plus their standard overheads, as well as interest during construction using Hydro One's capitalization rate in effect during the construction period.

London Hydro must pay a Facilities Upgrade Contribution which represents the difference between the Engineering & Construction costs of Hydro One Work and the Avoided Cost Work.

### Calculation of estimated capital contribution

Estimate of Hydro One Work Total = \$38.9 million (see details below)

- T5/T6 Commissioning (new TS) = \$34.1 million
- T3/T4 Decommissioning (old TS) = \$2.9 million
- Line Connection Pool Work = \$1.2 million
- Network Customer Allocated Work = \$0.7 million

Estimate of Avoided Cost Work = \$30.6 million

Total Facilities Upgrade Contribution = \$38.9M - \$30.6M = \$8.3 million (to be paid in milestone payments as set out below)

- \$6.85 million is for T5/T6 DESN work
- \$1.45 million is for decommissioning of T3/T4 DESN



Progress Payment No.	Payment Milestone Date	Total Payment Required (plus HST)
1	June 15, 2015	\$1,600,000 plus HST in the amount of \$208,000*
2	March 15, 2016	\$1,750,000 plus HST in the amount of \$227,500*
3	March 15, 2017	\$1,750,000 plus HST in the amount of \$227,500*
4	March 15, 2018	\$1,750,000 plus HST in the amount of \$227,500*
5	Earlier of March 15, 2021 or 3 months prior to the date scheduled by Hydro One to commence decommissioning of the T3/T4 DESN***	\$1,450,000 plus HST in the amount of \$188,500**

1

2 *True-up dates and potential true-up payments*

3 True-up of T5/T6 DESN work

4 The “Ready for Service Date” is the date upon which all of the Hydro One work, other than the  
5 decommissioning of T3/T4 DESN, has been completed and is scheduled in the CCRA to be  
6 December 15, 2016. The first scheduled true-up date will occur within 180 calendar days after  
7 this “Ready for Service Date”. This is noted in the CCRA as the “First Reconciliation Date”. Any  
8 difference between the Actual Facilities Upgrade Contribution for T5/T6 DESN and the  
9 Estimated Facilities Upgrade Contribution for T5/T6 DESN will result in either a credit or an  
10 invoice to be paid within 30 days after issuance.

11 True-up of T3/T4 DESN decommissioning work

12 Once Hydro One has completed the T5/T6 DESN work, they will commence the  
13 decommissioning of the T3/T4 DESN. The completion date of the decommissioning work is  
14 dependent on the T5/T6 DESN work and transfer of London Hydro’s load from T3/T4 to the  
15 T5/T6. This Transfer Deadline is outlined in the CCRA as no later than December 15, 2023.  
16 According to the CCRA, London Hydro will make its best efforts to transfer the load by  
17 December 31, 2020 or within two years following the “Ready for Service Date” outlined above  
18 The second scheduled true-up date will occur within 180 calendar days after the completion of  
19 the decommissioning. This is noted in the CCRA as the “Second Reconciliation Date”. Any  
20 difference between the Actual Facilities Upgrade Contribution for the T3/T4 Decommissioning  
21 Work and the Estimated Facilities Upgrade Contribution for the T3/T4 Decommissioning work  
22 will result in either a credit or an invoice to be paid within 30 days after issuance.

23 Discussion of London Hydro’s other CCRA’s with Hydro One can be found further within this  
24 Exhibit, Appendix 2-4, “New Policy Options for the Funding of Capital”.



1 **Demand**

2 Forecasted spending for Demand for the proposed 2017 Test Year is \$4,669,000 (after capital  
 3 contributions), an increase of \$1,793,356 or 12.9% CAGR compared to the 2013 Actuals. Table  
 4 2-27 below breaks down Demand spending into two project categories: City Works and  
 5 Developer Works. The Developer Works project category is then broken down and discussed  
 6 further.

7 Note that Demand projects are not undertaken at the discretion of London Hydro and are  
 8 initiated by the City of London or various developers within London.

9 **Table 2-27 – Demand Capital Spending by Project Category 2012 – 2017**

<b>DEMAND CAPITAL SPENDING 2012 - 2017</b>									
<b>Annual Spending</b>	<b>2012 Actual</b>	<b>2013 Actual</b>	<b>2013 Board Approved</b>	<b>2014 Actual</b>	<b>2015 Actual</b>	<b>2016 Bridge</b>	<b>2017 Test</b>	<b>2013 Actuals to 2017 Test</b>	<b>CAGR</b>
	\$	\$	\$	\$	\$	\$	\$	\$	%
<b>Demand</b>									
City Works Projects	1,446,613	543,034	805,400	1,542,380	1,968,293	1,996,000	2,250,900	1,707,866	42.7%
Developer Works Projects	4,891,216	4,751,282	4,658,000	5,084,680	6,017,328	4,258,000	4,519,100	(232,182)	-1.2%
	<u>6,337,830</u>	<u>5,294,316</u>	<u>5,463,400</u>	<u>6,627,060</u>	<u>7,985,620</u>	<u>6,254,000</u>	<u>6,770,000</u>	<u>1,475,684</u>	<u>6.3%</u>
Capital Contributions	(3,780,997)	(2,418,672)	(2,700,000)	(1,870,692)	(3,788,551)	(2,087,000)	(2,101,000)	317,672	-3.5%
	<u>2,556,833</u>	<u>2,875,644</u>	<u>2,763,400</u>	<u>4,756,368</u>	<u>4,197,069</u>	<u>4,167,000</u>	<u>4,669,000</u>	<u>1,793,356</u>	<u>12.9%</u>

10

11

1 **City Works (D) & Developer Works (E)**

2 *Overview*

3 City and Developer Works are externally driven and are predominantly growth-related. For the  
4 City Works programs, costs are based on previous expenditure patterns and any projects that  
5 have been identified by the City at the time of budgeting. To estimate the amount of funding  
6 required for servicing new residential housing developments, five year averages were calculated  
7 and balanced against Canada Mortgage and Housing Corporation's (CMHC's) forecast for the  
8 London area.

9 London Hydro has an obligation to perform these activities once the external party has met the  
10 requirements as outlined in London Hydro's Conditions of Service (COS) document. A majority  
11 of projects are either fully or partially recoverable, through either capital recoveries or capital  
12 contributions. The level of capital contributions set out in the COS document are prescribed by  
13 various acts and regulations, including the OEB's Distribution System Code, Ontario's *Public*  
14 *Service Works on Highways Act* and joint use agreements with other utilities such as Bell  
15 Canada and Rogers Cable.

16 Descriptions of the expansions and relocations for 2016 and 2017 are provided in the detailed  
17 project sheets of the DSP, Appendix G. It is noted that this area of spending is dictated by  
18 external influences and is therefore difficult to estimate due to its dependency on factors such  
19 as economic conditions and provincial and federal government funded initiatives.

20 *Capital Spending - City Works*

21 Forecasted spending for City Works Projects for the proposed 2017 Test Year is \$2,250,900;  
22 \$1,707,866 higher than the 2013 Actuals. Table 2-28 below depicts budgeted spending for City  
23 Works projects on an annual basis.

24





1 **Table 2-28 – City Works Projects Capital Spending 2012 – 2017**

<b>CITY WORKS PROJECTS CAPITAL SPENDING</b>							
<b>Annual Spending</b>	<b>2012 Actual</b>	<b>2013 Actual</b>	<b>2013 Board Approved</b>	<b>2014 Actual</b>	<b>2015 Actual</b>	<b>2016 Bridge</b>	<b>2017 Test</b>
	\$	\$	\$	\$	\$	\$	\$
City Road Authority Relocates	1,446,613	543,034	805,400	1,542,380	1,968,293	1,996,000	2,250,900
<b>Total</b>	<b>1,446,613</b>	<b>543,034</b>	<b>805,400</b>	<b>1,542,380</b>	<b>1,968,293</b>	<b>1,996,000</b>	<b>2,250,900</b>
Annual Change		(903,579)	262,366	999,345	425,913	27,707	254,900

2  
 3 This project category involves the relocation of London Hydro infrastructure located on the road  
 4 allowance. These relocations are initiated by the Road Authority (City of London) and are  
 5 necessary in order to accommodate planned modifications to the roadway. The terms and  
 6 conditions under which these relocations occur are specified in the Public Service Works on  
 7 Highways Act enacted by the Provincial Government.

8 Spending in the last several years has fluctuated depending on the projects that were identified  
 9 by the City of London as being required. London Hydro works closely with the City of London to  
 10 determine which of their projects will affect its infrastructure. When London Hydro's budget was  
 11 developed, the City had not defined all of its projects for 2016; therefore, the annual  
 12 expenditures were estimated based on a combination of known projects and base historical  
 13 spending.

14 The City of London has a number of multi-year plans that were created to meet the City's  
 15 growing transportation needs and new developments. Working in collaboration with the City and  
 16 other utilities, London Hydro relocates infrastructure assets in advance of the City's related  
 17 projects, typically one to two years in advance.

18 The 2016 and 2017 budgets for this area are higher than in previous years. These increased  
 19 expenditures are attributed to aggressive City plans, which are outlined in the "2030  
 20 Transportation Master Plan - Smart Moves (May 2013)," "London Rapid Transit (SHIFT)," and  
 21 "2014 Transportation Development Charge Background Study, City of London (May 2014)."  
 22 One example of this anticipated work relates to a City project that proposes to widen a roadway,  
 23 which includes a train rail underpass widening as well the diversion of train tracks. London

1 Hydro has four major 27.6kV circuits in direct conflict with the proposed work and, therefore,  
 2 relocation of this plant is contributing to the highest budgeted project within this section.

3 *Capital Spending – Developer Works*

4 Forecasted spending for Developer Works for the proposed 2017 Test Year is \$4,519,100;  
 5 \$232,182 lower than the 2013 Actuals. Table 2-29 below breaks down Developer Works  
 6 spending to the project type, excluding the impact of contributed capital.

7 **Table 2-29 – Developer Works Capital Spending 2012 – 2017**

DEVELOPER WORKS CAPITAL SPENDING							
Annual Spending	2012 Actual	2013 Actual	2013 Board Approved	2014 Actual	2015 Actual	2016 Bridge	2017 Test
	\$	\$	\$	\$	\$	\$	\$
Developer Expansions & Relocations	400,272	531,758	594,000	254,200	269,752	146,000	340,900
Residential Secondary Service Upgrade	305,886	306,803	325,000	307,721	369,831	340,000	355,000
Single Family Residential Underground	1,333,826	900,487	1,174,000	1,868,778	1,388,376	1,066,000	1,090,200
Multi-Family Residential Underground	393,578	744,736	565,000	616,065	1,400,041	766,000	783,000
Commercial Distribution Services	2,457,653	2,267,498	2,000,000	2,037,915	2,589,329	1,940,000	1,950,000
<b>Total</b>	<b>4,891,216</b>	<b>4,751,282</b>	<b>4,658,000</b>	<b>5,084,680</b>	<b>6,017,328</b>	<b>4,258,000</b>	<b>4,519,100</b>
Annual Change		(139,934)	(93,282)	333,399	932,647	(1,759,328)	261,100


8  
 9 *Residential Underground (Single Family and Multi-Family)*

10 This item involves the installation of single family and multi-housing (primarily townhouses and  
 11 condominiums) residential underground distribution systems to provide service as needed to  
 12 developers. From a budgeting perspective, the annual expenditures are estimated based on a  
 13 number of factors including past history, City of London development forecasts, market reviews  
 14 (including Canada Mortgage and Housing Corporation), and customer inquiries. This  
 15 information is updated each year (with the exception of 2016 and 2017, which are being  
 16 updated simultaneously due to it being a COS year) and the forecasts and budgets are adjusted  
 17 accordingly.

18 Market conditions can create large fluctuations in these expenditures from year to year. This  
 19 section will contain many different projects of varying magnitude depending on developer  
 20 requirements.

1 The London Hydro Conditions of Service document details how capital contributions are  
 2 assessed for these installations.

3 **Figure 2-3: Residential Growth Areas**




4  
 5 *Commercial Distribution Services*

6 This category covers the installation and/or modification of electrical equipment that is used in  
 7 supplying commercial (including apartments) and industrial customer installations as well as  
 8 work associated with upgrading existing installations.

9 From a budgeting perspective, the annual expenditures in this area are estimated based on a  
 10 number of factors including past history, City of London development forecasts, market reviews  
 11 and customer inquiries. This information is updated each year, (with the exception of 2016 and  
 12 2017 which are being updated simultaneously due to it being a COS year) and the forecasts  
 13 and budgets are adjusted accordingly.

1 The London Hydro Conditions of Service document details how capital contributions are  
 2 assessed for these installations.

3 **Figure 2-4: Commercial Growth Areas**



4

5

1 **Metering (M)**

2 *Overview*

3 London Hydro's Metering function involves four key service areas within two divisions: the  
4 Electric Meter (EM) Department and the Meter Database Management (MDM) Department. The  
5 Electric Meter Department is associated with the physical assets and communications while the  
6 Meter Database Management Department is responsible for information systems and data  
7 flows.

8 **Figure 2-5 – Scope of Metering Services**



9

10 The Ontario Energy Board (OEB) in its “Report of the Board Supplemental Report on Smart  
11 Grid” (EB-2011-0004 February 11, 2013) has expressed an expectation that

12 “...smart grid investments are considered integral to all utility investment and  
13 that planning for smart grid development and implementation by electricity  
14 distributors and transmitters will be an essential part of the broader network  
15 investment planning exercise.”

16 *and*

17 “As metering infrastructure is renewed and replaced over time, distributors  
18 must explore mechanisms that facilitate “real-time” data access and  
19 “behind the meter” services and applications for the purpose of providing  
20 customers with the ability to make decisions affecting their electricity  
21 costs.”

1 London Hydro's capital work program continues to align closely with and fulfill these directives  
2 for the benefit of its customers and business success.

3 *Electric Metering Department*

4 Spending increases of recent years and in forecasted future budgets reflect three major cost  
5 drivers: 1) regulatory requirements, environment stewardship and safety 2) technology  
6 obsolescence and 3) new services and customer engagement initiatives.

7 Measurement Canada (MC) and the Ontario Energy Board (OEB) have mandated changes to  
8 metering architecture and equipment including:

- 9 1) Smart meter program and requirements for the Advanced Metering Infrastructure  
10 systems (OEB)
- 11 2) Replacement of all 2.5-element metering with Measurement Canada compliant 3-  
12 element metering (MC)
- 13 3) Replacement of meters with MIST interval meters on any installation that was  
14 forecasted by London Hydro to have an average monthly peak demand during a  
15 calendar year of over 50kW (OEB).
- 16 4) Adoption of new mandatory pre-sample and compliance requirements for installed  
17 smart meters (MC); and
- 18 5) Support requirements for distributed generation, such as FIT and microFIT (primarily  
19 solar) installations (OEB).

20 Responding to environmental and safety drivers, London Hydro has initiated a multi-year  
21 program to replace all 24 installed oil-filled transformer metering units with new primary  
22 metering oil-free units. This multi-year plan deals with the most critically assessed units  
23 according to economic prudence and resource restrictions.

24 London Hydro is one of a very few LDC's to have its own facility for testing, maintenance and  
25 re-certification of smart meters to MC standards. This facility features 'in-house' designed test  
26 benches that automate routine procedures, thereby saving time and costs.

27 *Communications and Radio Licensing*

28 Since 2012, London Hydro has maintained a wireless communications network to support the  
29 smart meter deployment associated with TOU billing as mandated by the OEB. Despite



1 acceptable overall network service since its implementation, the associated AMI and RNI  
2 technologies are now considered obsolete and, therefore, have reached the end of their useful  
3 lives.

4 Beyond the obsolescence issue, studies conducted by IBM have shown that the current network  
5 is actually overloaded for meeting current service demands. Tuning efforts have been  
6 somewhat successful at squeezing out some performance improvements, but, certainly, this  
7 network will not be able to handle the traffic demands that the new meters, faster data  
8 acquisition rates and new “behind-the meter” services will require.

9 The communications network and technology, including expanded wireless bandwidth and radio  
10 licensing, needs to be replaced.

11 Finally, London Hydro has made a new communications connectivity option available to its  
12 Commercial and Industrial (C&I) customers that will utilize their existing internet connections to  
13 eliminate the need for dedicated telephone lines to each of their existing meters.

#### 14 *Meter Database Management Department*

15 The remaining two activities of Figure 2-5, ‘Data Systems’ and ‘Applications’ (support and  
16 development) are the responsibility of the Meter Database Management Department. Neither of  
17 these two business areas existed prior to the smart meter implementation.

#### 18 *Data Systems*

19 Initially, data arriving at London Hydro’s offices was simply parsed by small custom applications  
20 running on London Hydro servers and passed on through the provided MDM/R application for  
21 data handling. Meter data from each 24-hour period was required to be forwarded to the MDM/R  
22 the following morning. Errors and omissions would be flagged by the IESO MDM/R system and  
23 electronically relayed back to London Hydro for manual resolution. These errors and omissions  
24 were, in turn, forwarded to the MDM/R for consolidation into a complete record of that period.  
25 Meters that were off-line had to be repaired within 15 days and billing for that meter was not  
26 permitted until the problems were corrected.

27 This arrangement quickly proved to be inefficient and prone to network congestion and timing  
28 errors as the many unlinked applications of the processing chain often fell out of  
29 synchronization. Furthermore, if customers wanted access to their data with reasonable



1 response times, it became clear that the meter data would have to be processed and stored  
2 locally.

3 Obsolete and unsupportable access databases have been replaced with company standard  
4 SAP functionality.

5 An Operational Data Store (ODS) has been implemented to be not only the one source of smart  
6 meter consumption data but also other operational data. It is anticipated that eventually a  
7 myriad of other meter status and alarm data (currently not transmitted from the meter) and  
8 customer-provided 'behind-the-meter' data will be included.

9 Adjunct applications have been implemented to automate data validation and corrective routines  
10 prescribed by the OEB for billing and MDM/R uses.

11 The Meter Data Management Group handled over a half-million (500,000) data exceptions in  
12 2013, which ensured accurate and timely billing for our customers. This requirement gave rise  
13 to several improvement projects that redefined and automated the data processing paths for  
14 customer and MDM/R purposes. Similarly, due to the complexity of the smart meter network,  
15 many isolated access databases used for meter management had to be upgraded and  
16 integrated into the London Hydro enterprise systems.


17 Figure 2-6 illustrates the evolution of the data management processes and work flow  
18 accomplished to achieve an efficient and responsive meter data validation and store.

19



1


**Figure 2-6 – Meter Data Management Evolution**



2

3 Investment in new IT system functionality that supports metering business processes continues  
 4 to be made. Obsolete and unsupported Access databases have been replaced with company  
 5 standard SAP functionality. These new systems allow for inventory tracking and bar coding,  
 6 improving inventory management and enabling London Hydro to fully support the ISO9001:2008  
 7 quality system and MC's SS-06 compliance sample meteorology requirements.

8 **Figure 2-7 – Introduction of Remote Mobile Workforce Management System**



9

1 *Applications*

2 A detailed discussion of Application Development can be found further within this Exhibit, (Page  
3 133).

4 *Capital Spending*

5 Table 2-30 presents Metering capital spending for the years 2013 through 2015 and the planned  
6 budgets for the 2016 Bridge Year and the 2017 Test Year.

7 **Table 2-30 – Metering Capital Spending by Project Category 2012 - 2017**

<b>METERING CAPITAL SPENDING</b>								
	2013 Actual	2013 Board Approved	2014 Actual	2015 Actual	2016 Bridge	2017 Test	2013 Actuals to 2017 Test	CAGR
<i>Annual Spending</i>	\$	\$	\$	\$	\$	\$	\$	%
Metering and installations	633,937	527,000	680,197	895,391	660,000	668,000	34,063	1.3%
Primary metering	109,785	121,000	112,549	85,368	354,000	354,000	244,215	34.0%
Testing and validation equipment	-	-	44,865	293,280	-	-	-	
AMI Communications Renewal	-	-	-	-	625,000	649,000	649,000	
Wholesale metering upgrades	-	-	-	-	-	-	-	
<b>Total</b>	<b>743,722</b>	<b>648,000</b>	<b>837,612</b>	<b>1,274,040</b>	<b>1,639,000</b>	<b>1,671,000</b>	<b>927,278</b>	<b>22.4%</b>
Annual Change	3,886	(95,722)	93,890	436,428	364,960	32,000		

8  
9 *Metering and Installations*

10 Capital spending in connection with customer metering equipment relates to the installation and  
11 replacement of Measurement Canada approved electricity revenue metering devices. This cost  
12 includes items such as electric meters, meter adapter bases, transformers, test blocks,  
13 communication equipment (e.g., modems) and wiring.

14 Metering equipment and related assets typically have a long service life (25 years for meters  
15 themselves) and the capital budget reflects a relatively stable expenditure pattern from year to  
16 year as there is an opportunity to level required workload and resources.

17 It should be noted that these costs are higher than equivalent pre-smart meter era costs due to:

- 18
- increased equipment costs;
  - greater systems complexity and support services needed (increased troubleshooting and  
19 change management effort; and  
20

- 1       • new required automation of routine tasks through specific tools or new data systems,  
2           which, in turn, are required to offset greater volumes of work effort introduced.

3 Ongoing spending each year is incurred as new services are created and old services are  
4 replaced or removed. The new electronic meters are now more expensive than electro-  
5 mechanical meters. For example, an electro-mechanical single phase meter cost \$37.50 in  
6 2003, but today's electronic counterpart costs \$150. Similarly, a single-phase kWh bidirectional  
7 meter cost \$187.00 in 2003, but now a meter for such an installation costs closer to \$800.00  
8 due to the communications technology required to meet the billing and utility settlement  
9 requirements.

10 In addition, process improvements have been made to the installation and testing of the meters  
11 to help ensure metering and ultimately billing accuracy. Improvements involve accuracy testing  
12 of the meter, instrumentation transformers and installation, which is required whenever London  
13 Hydro exchanges a meter, whenever the customer does maintenance and needs access to the  
14 CT/PT compartment, or for any wiring change that affects the meter.

15 Accomplishments

16 In 2013, the following results were achieved:


- 17       ➤ The meter sealing shop received 'ISO 9001:2008 Measurement' Canada accreditation.  
18       ➤ In addition to meeting internal workload, the department re-certified and sealed over  
19       1,600 external client meters.  
20       ➤ Over 500 new meters were installed, over 1,200 meters were replaced and over 3,700  
21       metering installations were inspected and tested.  
22       ➤ In support of electrical contractors' requirements for new installations, over 140 back-  
23       plates were created.

24 The Electric Meter Department has seen increases in meter sealing and replacement of meters  
25 with expired seals (See Figure 2-8 below).

26

1

**Figure 2-8 – Meter Sealing Regulated Work Levels**



2

3 Metering installations for FIT, microFIT and other distributed generation

4 London Hydro supports the IESO administered programs for renewal distributed generation  
5 such as FIT and microFIT. In London, a number of these programs have bidirectional interval  
6 metering in place to support billing and settlements business functions. Initially these programs  
7 were supported by manual meter reading and billing processes. As volumes have increased,  
8 automated cellular based meter reading has been considered to read meters remotely and  
9 assist integrating with London Hydro's information systems. For the larger FIT installations, the  
10 metering has been linked with protection and control functionality as well as with power quality  
11 monitoring and measurement.

12 *Primary Metering*

13 Program to replace aging primary metering tanks

14 London Hydro has a program to replace all 24 installed oil-filled transformer metering units over  
15 time through removal or replacement with new primary metering units. Oil field units that are  
16 recovered from the field are returned to London Hydro and, pending inspection results, they are  
17 used as safety stock or scrapped.

18 The installed list of meters is reviewed annually to identify a prioritized list of tanks for  
19 replacement through planned maintenance. A site visit is made to the locations and a visual  
20 inspection is performed. Replacements are planned and scheduled by London Hydro's

1 Engineering Department and coordinated with the customer and the customer's electrical  
2 contractors.

3 London Hydro plans to replace three units each year with the expectation that by 2022, these  
4 oil-filled units will be fully removed from service. Units planned for replacement are prioritized by  
5 urgency based on condition and other factors such as lack of spare units or the ability to  
6 perform the work concurrent with customer service changes or customer-planned shutdowns.

7 The metering units are regularly inspected through a metering test, inspection and installation  
8 verification process.

9 **Figure 2-9 - Primary Metering Examples**



11 Program to replace 2.5-element metering with 3-element metering

12 London Hydro has a program to replace all 2.5-element metering with Measurement Canada  
13 compliant 3-element metering. Effective April 1, 2003, Measurement Canada stated that all  
14 new/reconstruction of existing 3-phase 4-wire wye configured metering installations shall use  
15 metering that is compliant with Blondel's theorem, such as 3-element metering. This work is  
16 being completed on an opportunity basis through the upgrade of services in conjunction with  
17 customer switchgear upgrades and London Hydro network voltage conversions.

1 Program to replace GS>50 demand meters with Interval communicating meters  
 2 On May 21, 2014 the OEB issued a Notice of Amendment to the Distribution System Code  
 3 (Board File No.: EB-2013-0311). Starting on August 21, 2014, distributors were required to  
 4 install MIST interval metering on any installation that was forecasted to have an average  
 5 monthly peak demand during a calendar year of over 50kW.

6 Existing installations were to be migrated out within six years of the Notice. In response, London  
 7 Hydro had several options, the best of which required further evaluation of the existing smart  
 8 meter system to determine if it could handle this requirement. London Hydro submitted and was  
 9 granted an exemption to delay installation until the end of 2015 to allow for further technology  
 10 evaluations.

11 At the time of the analysis, London Hydro had over 1,000 meters that would need to be changed  
 12 out. Many would be changed in due course as part of their Measurement Canada seal life.  
 13 However the OEB's target requirement for conversion completion meant that several hundred  
 14 meters would be stranded assets and need to be removed prior to their completed seal life. New  
 15 meters would have to be purchased rather than being re-tested and re-deployed for existing  
 16 meters. This result represents additional workload for the Electric Meter Department related to  
 17 the technology evaluation and selection as well as additional costs related to the meter  
 18 replacement.

19 **Figure 2-10 – GS>50 Proposed Meter Replacement Schedule**

Billing Class Meters GS>50 EG>50_DISN is GS>50kw Distribution (non-interval)			
Seal Expiry Year	# of Meters Due	2020 Replacement Goal	Additional Workload
2014	143	143	
2015	95	130	35
2016	279	279	
2017	37	131	94
2018	78	131	53
2019	8	131	123
2020	135	135	0
2021	73		
2022	67		
2023	128		
2024	37		
<b>Total</b>	<b>1080</b>	<b>1080</b>	<b>305</b>



1 Wholesale Metering Points

2 With the market opening in 2002, wholesale market participants, including London Hydro, were  
3 charged with the responsibility of upgrading all their wholesale meter points to IESO compliant  
4 standards within specified time lines. This new responsibility required significant resource  
5 commitments – mainly financial. London Hydro managed this effort through its ongoing  
6 relationship with Hydro One – which serves as the transmitter, legacy wholesale meter service  
7 provider and contracted meter service provider.

8 Seven physical locations involve London Hydro wholesale metering; all but one directly involves  
9 a Hydro One-owned transformer station. These locations include Buchanan TS, Highbury TS,  
10 Clarke TS, Talbot TS, Wonderland TS, Nelson TS, and Highway 4 PME.

11 Given the scope, financial state, labour commitment, resource availability and other limitations,  
12 including IESO compliance timelines, these specific, significant projects have been planned,  
13 committed and completed over a period of eight years. The last significant project was  
14 completed in 2011; No future wholesale metering capital projects are foreseeable at this time.

15 *Testing and Validation Equipment*


16 Significant annual cost avoidance has been achieved with the smart meter Validation Test  
17 Bench and the Measurement Canada (MC) calibration test bench. These in-house designed  
18 and built tools have allowed for the automation of smart meter troubleshooting, calibration and  
19 certification to MC standards. These tools have saved an estimated \$40,000 in avoided  
20 associated labour costs for London Hydro's own meter needs and have also generated a  
21 revenue stream of approximately \$25,000 per year by providing these services to external  
22 clients. Additional savings can be realized from the quick turnaround times involved in sealing  
23 our own meters; that is, we do not need to endure long wait times involved in sending them out  
24 to external sealing houses. This benefit is important because we must comply with test-time  
25 requirements for sample meters and the quick turnaround time that results from sealing in-  
26 house translates to needing fewer in stock meters.

27 *Measurement Canada Certification Effort*

28 The majority of the smart meters were installed in 2009-2010 with some installed in 2011-2012.  
29 The meters were accounted for with a 15-year amortization and thus are expected to be fully-  
30 depreciated in 2024-2025. However, the useful life of the meter is influenced by several other  
31 factors, including technological obsolescence and Measurement Canada seal period expiry.

1

Figure 2-11 – Meters Due for Re-verification



2

3 The smart meters deployed at London Hydro have a Measurement Canada 10-Year seal life  
 4 and must be re-verified prior to this seal expiry period. The requirement to install all the meters  
 5 at essentially one time to meet the TOU schedule will lead to equally intense re-certification  
 6 efforts. In the past, groups of meters would be re-verified annually to level this workload.

7 The wide range of meter communications firmware in the network only complicates and  
 8 compounds the re-certification process, creating an enormous challenge to achieve all re-  
 9 certifications on schedule. To help meet this challenge, an additional new test console for day-  
 10 to-day work capacity and backup for reliability was required for the meter shop's accreditation  
 11 and sealing business.

12 The London Hydro Smart Meter Validation Test Bench

13 Soon after the initial implementation of smart meters, several technology problems and  
 14 challenges emerged.

15 Firstly, the meters are part of a complex IT system that consists of the hardware and firmware  
 16 within the meters, as well as the AMCC, AMRC systems for collecting and making the data  
 17 available. Troubleshooting the problem of missing meter data became much more complicated  
 18 with many more branches of potential failure causes to assess.



1 Many unforeseen meter issues relate to the meter vendor not performing comprehensive quality  
2 assurance and firmware validation prior to release of its products. In most cases, the vendor did  
3 not provide 'last-time-buy' or 'end-of-life' notifications related to specific meter types. As a result,  
4 new firmware versions with defects could be unknowingly introduced into service at the  
5 customers' location, causing unnecessary interruption and rework.

6 In order to troubleshoot these types of defects, a skillset is required that includes  
7 software/hardware and firmware design and troubleshooting as well as radio frequency  
8 propagation and interference analysis. This broad skillset has driven the Electric Meter  
9 Department from their core electrical expertise into these new areas that have taken time to  
10 learn.

11 Additionally, the fact that these new firmware versions continually change has meant that over  
12 91 different hardware/firmware communications systems are currently interoperating within the  
13 mesh-like network at London Hydro. This situation has added an increased level of complexity  
14 that required additional meter management activities, such ensuring firmware upgrades had  
15 forward and backward compatibility and that the end-to-end system reliability was not  
16 compromised.

17 The key to addressing the significant workload increase and service problems identified above  
18 was to design and build an automated smart meter validation bench, which London Hydro did.  
19 The purpose of the meter test bench is to mitigate the many issues identified above and provide  
20 a controlled environment to identify and prevent potential issues from being introduced into our  
21 production network. The benefit of the validation bench is that with it we can use automation to  
22 perform many routine tests and thus help to offset the increased manual effort and cost created  
23 by the complexity of smart meters.

24 This test lab provides pre-deployment testing to ensure that new meter-related technology is  
25 evaluated and verified before being introduced into the customer domain. The lab itself is a  
26 place for staff to have operational rehearsals, thus providing a method of developing operational  
27 procedures and processes in a safe internal environment. The lab addresses ongoing  
28 challenges inherent in backwards compatibility to help ensure that new systems work with  
29 existing investments.

30

1

**Figure 2-12 – Automated Meter Test Bench Design**



2

3 Some examples of technical issues found through the use of the validation bench include

4 1) Identifying inaccuracies in the meter measurements versus communicated values

5 2) Coordinating meter to thermostat time display differences

6 3) Identifying faulty meter transmissions resulting in false power outage messages

7 4) Identifying faulty meter transmissions having an impact on communications  
8 system performance

9 5) Testing new meters and communications technology and configurations

10 6) Validating dependable and reliable voltage measurement capability

11 7) Validating power Failure Alarms for use with the AMI-OMS systems


12 8) Introducing and rehearsing operational procedures regarding meter encryption

13 9) Validating AMI functionality in the presence of simulated power quality conditions

14

1

**Figure 2-13 – Automated Voltage Threshold Validation Testing**



2

3 Investment in metrology test console to support compliance sampling

4 The building of the Measurement Canada calibration test bench was also a key piece of post-  
 5 smart meter deployment work. Electromechanical meters are electrically inductive as they are  
 6 basically small motors. On the other hand, smart meters are electrically capacitive as they are  
 7 basically small computers. The electrical load the meters consume is called the burden. In order  
 8 to accommodate the capacitive burden of the smart meters, the testing console required a full  
 9 upgrade and re-calibration, which represented a major project for the Electric Meter Department  
 10 in 2013. This work involved meter technicians and our Quality Management System team.

11 *AMI Communications Renewal*

12 Since 2012, London Hydro has maintained a wireless communications network to support the  
 13 smart meter deployment associated with TOU billing as mandated by the OEB. At the time of  
 14 implementation, this technology was rather new with limited technical options and vendor  
 15 offerings. Despite these limitations, a network was built and has provided satisfactory service.

16 Additionally, the anticipated demand for increased wireless capacity to support near real time  
 17 data and “behind the meter” initiatives are driving the need for a replacement communications  
 18 network and technology that provide significantly increased capacity. Studies have shown that  
 19 the current network is overloaded with current demands and cannot handle the traffic demands



1 that the new meters, faster data acquisition rates and new “behind the meter” services will  
2 generate.

3 London Hydro has taken steps to secure additional wireless bandwidth (30 MHz of utility-only  
4 Radio Frequency (RF) spectrum) while study and consultation with industry experts has  
5 determined the best approach to dealing with obsolescence issues related to the unlicensed 5.8  
6 GHz BelAir system and the Wireless Backhaul Network (WBN).

7 The costs of the new communications systems and radio licensing are encompassed in a multi-  
8 phase AMI renewal project budgeted at \$625,000 in 2016 and \$649,000 in 2017.

9 Looking forward, several IT systems will need to be refreshed to maintain the existing operating  
10 performance levels and to accommodate growth in data volume. Projects include refreshes to  
11 AMCC systems, ODS and MV90 systems as a result of new vendor versions and related  
12 software requirements. In addition, new capabilities, such as having Home Area Network  
13 integration support, allow for automatically managing the support for the Peaksaver Plus  
14 program. The support for the Peaksaver Plus program was initially handled with a manual  
15 process. As the volume of enrolled participants increases, an automated solution is required as  
16 the manual process does not scale and would become excessively costly.


17 Purchasing communication equipment (e.g., modems and IVP testing equipment) in order to  
18 support TCP/IP metering conversions has also added to increased costs in this budget period.

19 Meter data is communicated to London Hydro offices by wireless radio frequency  
20 communications. The network utilizes ‘Sensus’ supplied equipment for the ‘Head End’ IT  
21 information systems and the communication modules within the electric meter.

22 The smart meter system installed in London Hydro’s service territory currently has over 153,000  
23 metering endpoints for residential and small commercial (GS<50kW) with installations both  
24 inside and outdoors. Nine base stations are located throughout the city. At a programmed  
25 interval (typically set to two hours), the meter wakes up and transmits the last 11 hours of data.  
26 In Figure 2-14 below, the RIS (Receive Interval Success) curves illustrate the performance of  
27 the smart meter data collection system. Ideally, the system will collect all the reads completely  
28 (100%) and quickly (within a few hours). The top line on the left side of the figure shows how  
29 close to 100% the system receives. The RIS as a percentage of the total number of expected  
30 reads. Each meter is expected to have 24 reads (one for every hour in the day). The curved

1 section on the right of the graph shows how quickly the reads are coming into the system. A  
 2 steep slope indicates the reads are coming in quickly, a gradual slope indicates the reads are  
 3 delayed. The difference between the current day's performance (green) and a best day's  
 4 performance (red) is shown with black shading. The graph is linked to the minimum regulated  
 5 system requirements of having no less than 98% of the reads delivered to the Ontario MDM/R  
 6 by 5:00am each day. London Hydro is meeting these regulated requirements through active  
 7 management and monitoring of the system.

8 **Figure 2-14 – Smart Meter System Performance**



9  
 10  
 11 Program to replace customer telephone metering with internet TCP/IP  
 12 Today, London Hydro is using the internet to connect to meters at several customer locations. In  
 13 the longer term, it is expected that internet-connected meters will be the typical installation and  
 14 legacy phone lines will be rarely used for meter data, if at all.

15 London Hydro will offer the following options for interval-style revenue metering:

- 16 1) TCP/IP VPN internet connected meters (hard wired or cellular),
- 17 2) Dedicated telephone lines,
- 18 3) Shared telephone lines, or
- 19 4) Cellular-based communications.



1 The Internet has proven to be a viable alternative communication system to telephone lines.  
2 Today approximately 690 interval-metered accounts are being read by phone lines through  
3 London Hydro's MV90 system. These phone lines are provided by customers at an assumed  
4 rate of \$50 per month per line or approximately \$415,000 per year. If a customer has an  
5 available internet connection, London Hydro can enable these cost reductions for the customer.

6 To enable TCP/IP communication, the customer's meter is connected to a London Hydro  
7 specified VPN (Virtual Private Network) Router. The router is configured by London Hydro to  
8 establish an IPSec VPN tunnel to London Hydro's firewall, encrypting all meter communication.  
9 If required, London Hydro can configure third party access to the meter at an additional cost.


10 The internet connection eliminates many problems encountered using the Plain Old Telephone  
11 Service (POTS) lines as well as cost implications for London Hydro. As customers take  
12 advantage of Voice-Over-IP (VOIP) systems or end-of-life fax lines, MV90 often calls  
13 disconnected lines. A variety of conditions lead to non-communication with the meter.  
14 Sometimes the customer is unaware that the phone line is for a London Hydro meter and then  
15 inadvertently cancels the phone line. Communication can also be lost due to busy phone lines  
16 or unanswered phone lines. Customers can change their phone system within their company or  
17 change service providers who are unaware that a connection must be provided for the London  
18 Hydro meter. Customers who upgrade their phone systems to VOIP introduce problems due to  
19 the fact that this system has different call quality characteristics. In some instances the  
20 customer's service provider can change the phone switching system without informing the  
21 customer. Shared phone lines can interfere with other devices (such as a fax machine) if the  
22 line sharing device is not set up properly.

### 23 Hydro One meter communications

24 London Hydro presently reads eight Hydro One meters via TCP/IP. These meters represent the  
25 total number of Hydro One meters that affect the London Hydro service territory. The meters are  
26 located at the Clarke TS M2 main and alternate, the Wonderland TS main and alternate, the  
27 Highbury TS main and alternate and the Buchanan TS main and alternate. The main and  
28 alternate meters that affect the Buchanan Delivery Point presently require communication  
29 through a cellular modem (which is on a 2G network) as Hydro One is using a Hydro One  
30 owned virtual private network (VPN) for wholesale metering.

1 Enhancements to AMI communications  
2 As shown in Figure 2-15, the smart meter system installed in 2009 and augmented in 2011 is  
3 overloaded from a network capacity point of view. To accommodate future growth and the ability  
4 to operate the network effectively, additional capacity is required in the network.

5 **Figure 2-15 – Smart Meter Tower Overloading**



6  
7 Adding capacity, in essence, means adding bandwidth and this, in turn, means adding more  
8 licensed RF Radio spectrum. This requirement is due to anticipated additional smart meter base  
9 stations. These base stations could either be co-located at existing sites or, due to radio  
10 propagation drivers, located at new radio station sites.


11 London Hydro has secured the use of 30MHz of 1.8GHz band spectrum for utility applications.  
12 Potential applications for this asset include smart-grid, remote workforce management, and  
13 machine-to-machine and Industrial Internet-of-Things connectivity for energy management.  
14 While the Electric Meter Department has risen to the challenge of operating the smart meter  
15 Vendor RF metering systems, an enhanced and focused skillset is needed to address these  
16 future challenges.

17 In the fall of 2014, London Hydro engaged IBM in a consulting role to recommend  
18 considerations for technological and business options for the expansion and development of the  
19 London Hydro Wireless Networks. A main consideration was that London Hydro qualifies for

1 30MHz of utility-only RF spectrum, which is deemed not only a valuable future investment in a  
2 very limited resource but as an essential need as well.

3 London Hydro submitted an application to Industry Canada to obtain the licence and was  
4 granted all 30MHz of spectrum pending further application. This spectrum is currently used by  
5 Hydro One, THESL, Powerstream, BC Hydro, Manitoba Hydro, and Hydro Quebec. From a  
6 technology perspective, WiMax Radio Technology is available that uses this radio spectrum.

7 **Figure 2-16 – RF Network Realization Planning**



9 This radio renewal program is expected to address some existing concerns regarding smart  
10 metering supply management, such as existing vendor supply management issues for meters  
11 and communications, competition limited by communications sourcing and limited RF  
12 Bandwidth C&I meters and future applications. London Hydro expects to benefit from new  
13 capabilities that are progressive and responsive by working with AMI technology innovation  
14 partners.

15 In addition to the growth and wireless spectrum issues discussed above, London Hydro needs  
16 to plan for 'end-of-life' RNI technology and obsolescence of the WBN. While the risk has been  
17 mitigated by buying spares on the secondary market, the need to plan to replace the network is  
18 becoming more urgent each year.



1 The two key technological issues involved are 1) the obsolescence of the unlicensed 5.8GHz  
2 BelAir system and 2) the Wireless Backhaul Network (WBN).

3 In pursuit and selection of the appropriate technology, evaluations will be required to consider  
4 present and future needs. Further, the identification of the application use cases and the  
5 opportunities for developing new networks to service these applications are essential.

6 A pilot project with the following applications should consider, but not necessarily limited to the  
7 following:

- 8 1) Replacement of obsolete Wireless Backhaul Radio system
- 9 2) AMI for GS>50 interval metering requirements and need for open standards and  
10 interoperability
- 11 3) Monitoring underground cabling for temperature, power flow and video
- 12 4) Monitoring distribution system re-closer and coordination, and large solar control  
13 (FITs)
- 14 5) Two way customer energy management and Internet of Things Applications
- 15 6) Nomadic services (Mobile Workforce)

16 In addition, the potential network architectures that could support these applications include,  
17 one or combination of, but not necessarily limited to:

- 18 1) 1.8-1.83 GHz utility-only licensed spectrum
- 19 2) 902-928 MHz ISM Band unlicensed spectrum for Internet of Things and/or mesh  
20 connectivity
- 21 3) Optical/Copper networks – Leased or owned
- 22 4) Cellular network(s) (e.g., Custom APN or UPNS)
- 23 5) RF/Microwave links/extensions (i.e. Licensed or Unlicensed)
- 24 6) Vehicle Area Networks (VAN)
- 25 7) Home Area Networks (HAN)

26



1 **Fleet and Facilities**

2 Forecasted spending for Fleet and Facilities for the proposed 2017 Test Year is \$2,528,000, an  
 3 increase of \$468,285 or 5.3% CAGR compared to the 2013 Actuals. Table 2-31 below divides  
 4 Fleet and Facilities spending into four major project categories. Project categories are then  
 5 broken down and discussed further.

6 **Table 2-31 – Fleet and Facilities Capital Spending by Project Category 2012 - 2017**

FLEET AND FACILITIES CAPITAL SPENDING 2012 - 2017									
Annual Spending	2012 Actual	2013 Actual	2013 Board Approved	2014 Actual	2015 Actual	2016 Bridge	2017 Test	2013 Actuals to 2017 Test	CAGR
	\$	\$	\$	\$	\$	\$	\$	\$	%
<b>Fleet and Facilities</b>									
Vehicles & Major Equipment	1,675,405	1,310,236	1,410,000	771,500	1,195,208	1,130,000	1,099,000	(211,236)	-4.3%
Operating Equipment	168,837	136,016	155,000	195,509	212,466	445,000	320,000	183,984	23.8%
Office Furniture & Equipment	84,536	101,296	80,000	121,041	79,805	455,000	197,000	95,704	18.1%
Buildings & Fixtures	1,053,422	512,167	650,000	1,171,402	746,658	1,200,000	912,000	399,833	15.5%
	<b>2,982,199</b>	<b>2,059,715</b>	<b>2,295,000</b>	<b>2,259,453</b>	<b>2,234,137</b>	<b>3,230,000</b>	<b>2,528,000</b>	<b>468,285</b>	<b>5.3%</b>

7  
8



1 **Vehicles and Major Equipment (N)**

2 *Overview*

3 London Hydro's Fleet Department manages the maintenance, repair, licensing and inspection  
 4 requirements to ensure that the vehicles, trailers and specialty-powered equipment required to  
 5 build, maintain and provide prompt outage response are available when needed and that they  
 6 operate in a safe, efficient manner. London Hydro's rolling stock assets consist of 149 vehicles,  
 7 trailers and specialty-powered equipment to operate, maintain, and construct the distribution  
 8 system.

9 *Capital Spending*

10 Forecasted spending for Vehicles and Major Equipment for the proposed 2017 Test Year is  
 11 \$1,099,000; \$211,236 lower than the 2013 Actuals. Table 2-32 below breaks down Vehicles and  
 12 Major Equipment spending to the specific types of equipment.

13 **Table 2-32 – Vehicles and Major Equipment Capital Spending 2012 - 2017**

<b>VEHICLES &amp; MAJOR EQUIPMENT CAPITAL SPENDING</b>							
<b>Annual Spending</b>	<b>2012 Actual</b>	<b>2013 Actual</b>	<b>2013 Board Approved</b>	<b>2014 Actual</b>	<b>2015 Actual</b>	<b>2016 Bridge</b>	<b>2017 Test</b>
	\$	\$	\$	\$	\$	\$	\$
Vehicles and Major Equipment	1,675,405	1,310,236	1,410,000	771,500	1,195,208	1,130,000	1,099,000
<b>Total</b>	<b>1,675,405</b>	<b>1,310,236</b>	<b>1,410,000</b>	<b>771,500</b>	<b>1,195,208</b>	<b>1,130,000</b>	<b>1,099,000</b>
Annual Change		(365,168)	99,764	(538,736)	423,707	(65,208)	(31,000)

14

15 In 2013, an extensive review of all Fleet processes was conducted, including the operating life  
 16 of all London Hydro vehicles. When a vehicle comes due for replacement, an overall  
 17 assessment of the vehicle's mileage, engine hours, repair history and future intended usage is  
 18 performed. If the life of a vehicle can be extended based on this pre-determined criteria, the  
 19 vehicle will also be inspected in relation to any applicable government regulations to ensure it  
 20 will still meet requirements if it is to remain in service. London Hydro also uses the E3 Fleet  
 21 Economic Life model as part of the replacement evaluation. E3 Fleet is a Canada-wide program  
 22 that helps public and private sector organizations reduce the carbon footprint of their vehicle  
 23 fleets. The E3 Fleet information and tools help companies increase fuel efficiency in the fleet,  
 24 reduce harmful emissions, manage expenses, and incorporate new technologies or fuels.

1 Finally, the Department using the vehicle  
2 is consulted to determine whether the  
3 vehicle still performs as required or if  
4 replacement with a vehicle that has newer  
5 or enhanced features would provide  
6 enhanced safety or work efficiencies. This  
7 assessment may result in the vehicle  
8 replacement being deferred to the next  
9 budget year when the vehicle would be  
10 assessed again to see if replacement is  
11 necessary. While this deferral extends the



12 vehicle beyond the fully-depreciated life cost, it also results in savings related to avoiding  
13 purchasing a new vehicle. From 2013 to 2015, ten out of fifteen vehicles that were budgeted to  
14 be replaced were kept in service using the abovementioned review process. More information  
15 regarding fleet replacements, the E3 model, and rolling stock of fleet can be found within the  
16 DSP, Appendix 2-6 to this Exhibit.

17 The following major items relating to vehicles and major equipment are budgeted for 2016:

- 18 • 4 pickup trucks
- 19 • 5 SUV's
- 20 • 1 dump truck
- 21 • 1 commercial van
- 22 • 1 aerial bucket truck

23 The following major items relating to vehicles and major equipment are budgeted for 2017:

- 24 • 4 pickup trucks
- 25 • 1 SUV
- 26 • 1 commercial van
- 27 • 1 double bucket truck
- 28 • 2 trailers

29

1 **Operating Equipment (0)**

2 *Overview*

3 Operating equipment includes specialty tools, test equipment or large material items, such as  
4 outdoor transformer storage racks or specialty ergonomic battery operated tools, required by the  
5 various Operations Departments to perform their duties. As technology improves and tools and  
6 testing methods are required to change, enhanced testing equipment and tools are needed to  
7 increase efficiency improve ergonomics and help staff provide service to our customers more  
8 quickly.

9 *Capital Spending*

10 Forecasted spending for Operating Equipment for the proposed 2017 Test Year is \$320,000;  
11 \$183,984 higher than the 2013 Actuals. Table 2-33 below illustrates spending on Operating  
12 Equipment from 2012 to 2017.

13 **Table 2-33 – Operating Equipment Capital Spending 2012 – 2017**

<b>OPERATING EQUIPMENT CAPITAL SPENDING</b>							
<b>Annual Spending</b>	<b>2012 Actual</b>	<b>2013 Actual</b>	<b>2013 Board Approved</b>	<b>2014 Actual</b>	<b>2015 Actual</b>	<b>2016 Bridge</b>	<b>2017 Test</b>
	\$	\$	\$	\$	\$	\$	\$
Stores Equipment	119	5,499	5,000	3,348	65,707	165,000	40,000
Miscellaneous Operating Equipment	168,718	130,517	150,000	192,161	146,759	280,000	280,000
<b>Total</b>	<b>168,837</b>	<b>136,016</b>	<b>155,000</b>	<b>195,509</b>	<b>212,466</b>	<b>445,000</b>	<b>320,000</b>
Annual Change		(32,821)	18,984	59,493	16,957	232,534	(125,000)

14

15 *Stores Equipment – 2016*

- 16
- 17 • Yard storage racks – the storage yard at 111 Horton Street is not large enough to house  
18 all the required transformers and equipment at grade level. The Materials Management  
19 Department utilizes racking to increase the storage capacity, thereby avoiding procuring  
20 offsite storage space and associated costs.
  - 21 • Material Handling Equipment – assisted material lifting and handling equipment will be  
22 purchased, such as hydraulic lift tables, as recommended in an ergonomics review, to  
reduce injuries to staff when handling heavy items in Materials Management.

1 *Miscellaneous Operating Equipment – 2016*

- 2 • Cable Testing and Fault Locating – with the change in cable types and installation  
3 methods, especially in the downtown core, the current cable fault testing and locating  
4 equipment is undersized and hinders proper testing or fault locating. As a result,  
5 energized cables could quickly fail, extended outages during fault locating could occur or  
6 system capacity could be jeopardized while a cable is out of service. A new Time  
7 Domain Reflectometer (TDR), suitable for the London Hydro underground system, will  
8 be purchased to address these issues.
- 9 • Smart meter test and analyzing equipment – items such as spectrum or cross phase  
10 analyzers are scheduled to be purchased in 2016 and 2017 as part of an overall project  
11 in the Electric Meter Department to help in the processing of meters and service orders.
- 12 • Safety Equipment – Equipment such as specialized lead handling and construction tools,  
13 road work zone safety signs and barricades and specialized personal protective  
14 equipment.

15 *Stores Equipment – 2017*

- 16 • The existing material handling equipment, such as hydraulic pump carts, requires  
17 extensive repairs; it is less expensive to replace this equipment than it is to repair it.

18 *Miscellaneous Operating Equipment – 2017*

- 19 • Based on historical trends and age of existing tools and test equipment in various  
20 Operations Departments, the tools and equipment will need to be replaced or more  
21 innovative test equipment will need to be purchased.

22



1 **Office Furniture and Equipment (Q)**

2 *Overview*

3 Office furniture and equipment includes items such as workstations, cubicles, desks, chairs, and  
 4 building security devices such as card access equipment and cameras. Many sections of the  
 5 London Hydro office have furniture and equipment dating back to a major building renovation  
 6 and expansion completed in 1987, and, in addition to being worn out, this furniture and  
 7 equipment do not meet current requirements for ergonomics and accommodating individual  
 8 employees' requirements. Additionally, building security devices have become obsolete with  
 9 technology changes and need to be replaced on an on-going basis.

10 *Capital Spending*

11 Forecasted spending for Office Furniture and Equipment for the proposed 2017 Test Year is  
 12 \$197,000; \$95,704 higher than the 2013 Actuals. Table 2-34 below illustrates Office Furniture  
 13 and Equipment spending on an annual basis from 2012 to 2017.

14 **Table 2-34 – Office Furniture and Equipment Capital Spending 2012 – 2017**

<b>OFFICE FURNITURE &amp; EQUIPMENT CAPITAL SPENDING</b>							
<b>Annual Spending</b>	<b>2012 Actual</b>	<b>2013 Actual</b>	<b>2013 Board Approved</b>	<b>2014 Actual</b>	<b>2015 Actual</b>	<b>2016 Bridge</b>	<b>2017 Test</b>
	\$	\$	\$	\$	\$	\$	\$
Office Furniture/Equipment	84,536	101,296	80,000	121,041	79,805	455,000	197,000
<b>Total</b>	<b>84,536</b>	<b>101,296</b>	<b>80,000</b>	<b>121,041</b>	<b>79,805</b>	<b>455,000</b>	<b>197,000</b>
Annual Change		16,760	(21,296)	19,745	(41,236)	375,195	(258,000)

16 *Furniture*

17 Replacement of London Hydro's modular furniture began in 2016. The current Steelcase  
 18 furniture is over 30 years old, is fully-depreciated, is outdated and needs constant repairs. The  
 19 electrical components are malfunctioning and are no longer safe. Replacement of all  
 20 workstations has been budgeted over the next five years beginning in 2016. Additionally,  
 21 adjustable desks/workstations will be purchased in 2016 and 2017 to address the ergonomic  
 22 needs and, therefore, the health of our staff as identified by London Hydro's Ergonomic  
 23 Committee. The ergonomic furniture is adding \$150,000 in cost in 2016 and \$61,000 in cost in



1 2017 to the budget. Providing employees with proper work areas will improve attendance,  
2 productivity, and assist with recruitment and retention.

3 *Security System*

4 London Hydro repairs and replaces components of the Security System (Card Access, CCTV  
5 cameras etc.) every year. In 2016, London Hydro will replace the card access system that was  
6 installed in 1999. This system is outdated and parts and service are very difficult to procure. The  
7 new system will cost approximately \$150,000 and will ensure London Hydro's Security program  
8 meets industry standards, keeping our resources (especially employees) safe and able to  
9 function without unnecessary interruptions or inconvenience. Each year, a few security cameras  
10 and digital video recorders (DVRs) are replaced as they become obsolete. No other significant  
11 security projects are expected in the next 5 years.

12





1 **Buildings and Fixtures (R)**

2 *Overview*

3 London Hydro owns four major buildings located at 111 Horton Street and 41 municipal  
4 substations, both outdoor metalclad and building style, located throughout the City of London.  
5 These buildings and substations were built at various times dating back to 1912 with the newest  
6 main building being built in 1987. The main buildings are situated on 11 acres of land leased  
7 from the City of London and are valued at approximately \$12.8 million. The buildings require  
8 ongoing upgrading and major component replacements in order to maintain their value and  
9 functionality.

10 In 2013, the City of London (our landlord) began discussions about the possibility of acquiring a  
11 portion of the building space and land located at 111 Horton Street. Due to this possibility, only  
12 the following items were completed in 2014: minimum maintenance and repairs; capital projects  
13 that were not affected by the possible acquisitions; and capital projects that were necessary due  
14 to safety or efficiency of operations. This uncertainty regarding the land acquisition has  
15 subsided; therefore, 2015 and 2016 budgets were restored to previous levels and building  
16 repairs, maintenance and capital budgets were reallocated to catch up from 2014.

17 *Capital Spending*

18 Forecasted spending for Buildings and Fixtures for the proposed 2017 Test Year is \$912,000;  
19 \$399,833 higher than the 2013 Actuals. Table 2-35 below breaks down Buildings and Fixtures  
20 spending to the specific project type.

21

1 **Table 2-35 – Buildings and Fixtures Capital Spending 2012 – 2017**

<b>BUILDINGS &amp; FIXTURES CAPITAL SPENDING</b>							
<b>Annual Spending</b>	<b>2012 Actual</b>	<b>2013 Actual</b>	<b>2013 Board Approved</b>	<b>2014 Actual</b>	<b>2015 Actual</b>	<b>2016 Bridge</b>	<b>2017 Test</b>
	\$	\$	\$	\$	\$	\$	\$
Heating/Venting & A/C	39,931	-	100,000	24,453	73,410	150,000	154,000
Paving	440,753	230,555	250,000	140,550	66,750	345,000	346,000
Improvements/Renovations	247,548	138,560	175,000	896,314	464,798	530,000	360,000
Garage Fixtures	-	-	125,000	-	127,520	-	-
Roofing	10,153	-	-	-	-	-	-
Yard Environmental Controls	-	-	-	-	-	50,000	-
Standby Generator	293,762	75,649	-	-	10,952	50,000	52,000
Uninterrupted Power Supply & Battery Banks	21,275	67,403	-	110,086	3,229	75,000	-
<b>Total</b>	<b>1,053,422</b>	<b>512,167</b>	<b>650,000</b>	<b>1,171,402</b>	<b>746,658</b>	<b>1,200,000</b>	<b>912,000</b>
Annual Change		(541,255)	137,833	659,235	(424,744)	453,342	(288,000)

2  
3 *Paving*

4 Paving expenditures in 2012 and 2013 related to the vehicle and equipment parking and staging  
 5 area, originally paved with asphalt in 1968, in the Operations yard. For safety and operational  
 6 efficiencies, this area was redeveloped with new pole lighting, security camera coverage and  
 7 asphalt replacement. In 2013, the Facilities Department began a project to replace the asphalt  
 8 over 5 years. Some areas had been delayed due to the previously mentioned property  
 9 uncertainty, however all areas are now scheduled to be completed by 2018. This grouping  
 10 includes paving at London Hydro-owned substations.

11 *Improvements/Renovations – 2014*

12 Spending in Improvements/Renovations during 2014 was higher than normal due to the  
 13 following significant items:

- 14 • Smart Meter Lab (related to smart meter validation bench, discussed in Metering  
 15 section, Page 96)
- 16 • Replacement of windows in the Operations and Administration buildings
- 17 • Replacement of data cable wiring in the Administration building
- 18 • Cafeteria renovations – to meet health code standards as well as provide a more  
 19 comfortable environment for employees to gather for breaks and informal meetings,  
 20 including those with customers, rather than leaving the office to attend local coffee shops  
 21 and restaurants; no renovations had been done since 1987; impact to corporate culture

1

**Figure 2-17 – Smart Meter Lab Infrastructure**



2

3

**Figure 2-18 – 2014 Cafeteria Renovations (Before and After)**



4

5 *Garage Fixtures – 2015*

6 In 2015, the Fleet Department obtained a new hoist for the garage. The existing in-floor hoists,  
7 installed in 1982, were at end of life and becoming increasingly difficult to repair. They also were  
8 not suitable for some of the newer, larger vehicles. The new hoist is portable and can be  
9 configured to lift different trucks of various sizes and weights.

1 *Buildings and Fixtures – 2016*

2 Budgeted capital expenditures for Buildings and Fixtures in 2016 are higher than normal, due to  
3 the following significant scheduled projects:

- 4 • Energy saving lighting and controls – London Hydro is updating lighting and controls that  
5 are at end of life and using more efficient replacements to reduce operating costs.
- 6 • New HVAC equipment – London Hydro’s aging buildings require replacement of major  
7 components of the HVAC system. Heating and cooling is controlled by a building  
8 automation system commissioned in 2010; however, many heat pumps are original to  
9 the building (some close to 40 years old) and they have outlived their life expectancy.  
10 Until now, the Facilities Department had been replacing heat pumps only when they  
11 required major repair. Beginning in 2016, and for a period of five years, Facilities will  
12 replace all aging heat pumps to reduce energy usage.
- 13 • Yard paving (discussed above)
- 14 • Control Room building upgrades (related to Control Room improvements discussed in  
15 the Automation section above (page 71))
- 16 • Elevator control system replacements – London Hydro will replace the two main  
17 passenger elevators, which are original to the building (1987). In the past two years, a  
18 number of safety incidents have occurred as a result of elevator malfunction, and these  
19 incidents have resulted in at least two injuries and a number of near misses. These  
20 elevators have surpassed their end of useful life. The safety standards when these  
21 elevators were installed allowed for a six inch misalignment with the floor (creating a  
22 serious trip/fall hazard); current standards allow for only a few millimeters, thereby  
23 reducing the hazard. New elevators will meet the new, higher standard and are more  
24 energy efficient.
- 25 • UPS battery replacements – the batteries in the main uninterruptable power supply  
26 (UPS) for the Data Centre are scheduled to be changed in 2016. The Control Centre  
27 UPS batteries changed in 2012 and the Engineering building batteries are scheduled for  
28 replacement in 2019. These battery banks need to be replaced every five years to  
29 ensure they can supply critical loads until the standby generator is activated.
- 30 • Interior Renovations – London Hydro’s office space has never undergone a major  
31 renovation. Until recently, renovations were small, and areas were pieced together to

1 accommodate small changes in staffing or department realignments. Beginning in 2016,  
2 with the assistance of office space consultants, the Facilities Department has begun a  
3 five-year plan to completely renovate most office areas in the facility, in order to provide  
4 most employees with natural light, better heating/cooling, improved working environment  
5 and to better utilize space.

6 *Buildings and Fixtures – 2017*

7 The following significant building improvement projects are scheduled to take place in 2017:

- 8 • Energy saving lighting and controls (discussed above)
- 9 • New HVAC equipment (discussed above)
- 10 • Yard paving (discussed above)
- 11 • Engineering building UPS batteries (discussed above)
- 12 • Control Room building upgrades (related to control room improvements discussed in  
13 Automation above)
- 14 • Stand-by power and electrical projects – In order to address critical loads as technology  
15 equipment is modified or added, increasing demands are placed on the UPS and  
16 standby generator systems. This budget item is for a review of loading and any  
17 modifications or additions required to increase the capacity of the standby power  
18 systems. This review is scheduled to be completed on a five-year cycle.
- 19 • Facility environmental upgrades – The existing storm water protection system does not  
20 cover the entire transformer storage area, which could pose an environmental threat.  
21 This item will extend coverage to a transformer storage area to protect the river in the  
22 case of an accidental oil spill.

23



1 **Information Systems**

2 Forecasted spending for Information Systems for the proposed 2017 Test Year is \$4,510,000, a  
 3 decrease of \$2,365,635 or -10.0% CAGR compared to the 2013 Actuals. Table 2-36 below  
 4 divides Information Systems spending into the two project categories. Project categories are  
 5 then broken down and discussed further.

6 **Table 2-36 – Information Systems Capital Spending by Project Category 2012 - 2017**

INFORMATION SYSTEMS CAPITAL SPENDING 2012 - 2017									
Annual Spending	2012 Actual	2013 Actual	2013 Board Approved	2014 Actual	2015 Actual	2016 Bridge	2017 Test	2013 Actuals to 2017 Test	CAGR
	\$	\$	\$	\$	\$	\$	\$	\$	%
<b>Information Systems</b>									
Hardware / Software	1,343,575	1,747,356	1,210,000	1,126,199	1,417,956	810,000	735,000	(1,012,356)	-19.5%
Application Development	4,329,368	5,128,280	4,790,000	3,299,393	4,146,021	4,130,000	3,775,000	(1,353,280)	-7.4%
	<b>5,672,943</b>	<b>6,875,635</b>	<b>6,000,000</b>	<b>4,425,591</b>	<b>5,563,977</b>	<b>4,940,000</b>	<b>4,510,000</b>	<b>(2,365,635)</b>	<b>-10.0%</b>

7  
 8 Capital expenditures for Information Technology (IT) are divided into two categories:  
 9 Infrastructure and Application Development (AD). Infrastructure designated budget items are  
 10 those incurred in the general provision of IT assets and services across all or multiple business  
 11 units of London Hydro. The AD budget captures the budget items that exist for specific  
 12 initiatives or for the dedicated purposes of a single business unit.

13 For the management of the annual capital budgets and their alignment with the London Hydro  
 14 IT strategy, London Hydro typically tracks the budgets within the key goals of sustainment,  
 15 enhancements and new systems.

16

1 **Hardware and Software (V)**

2 *Overview*

3 In 2013, London Hydro’s IT strategy was concentrated on building an agile and scalable  
4 “internal Cloud” infrastructure that efficiently and cost effectively supports mission critical  
5 business applications. The core of this strategy focused on consolidated storage, server  
6 virtualization and standardization, high availability and high performance.

7 The Consolidated Networked Storage project will help us supply the required storage capacity  
8 with fewer physical resources, such as using shared disks on the network. This initiative is also  
9 an essential enabler for server virtualization.

10 Server virtualization enables consolidation of multiple physical servers used for sharing  
11 workload. London Hydro continues to virtualize its premise-based server environment and  
12 currently has 47 physical servers, 193 virtual servers and 78 new Cloud-based instances. With  
13 this “internal Cloud” strategy, London Hydro has avoided purchasing over 100 physical  
14 machines to meet its business needs.

15

**Figure 2-19: Server Counts**

Item	2013	2016
Number of Physical Servers	63	47
Number of Virtual Servers	125	193
Number of Amazon Virtual Machines	0	16
Number of Google Virtual Machines	0	62
Number of Smart Phones	100	185

16 Although London Hydro continues to build, harden and secure the “internal Cloud” environment,  
17 it has also adopted the new “Cloud strategy”.

18 Currently, London Hydro has a number of business systems deployed in the Cloud and, as a  
19 result, internet availability has become more critical and bandwidth requirements have  
20 increased. As bandwidth increases, a range of network traffic - storage read/write blocks, files,


1 voice, video, multimedia, etc. – must share a single network. Advances in smart devices and  
 2 mobility are driving new ways to connect with employees and customers and include more  
 3 unstructured data as part of the content.

4 The mobile workforce project and operations initiatives, such as Automatic Vehicle Location  
 5 (AVL), all rely on mobile devices to capture pictures and videos as part of the verification and  
 6 evidence requirements of new programs.

7 Customer Service is testing new ways of communicating with customers, such as web chatting.  
 8 This increase in rich media communications drives the need for additional bandwidth as well as  
 9 additional storage for premise-based systems.

10 Figure 2-20 highlights some of the major infrastructure changes implemented since 2013.

11 **Figure 2-20: Infrastructure Changes Since 2013**



12  
 13



1


**Figure 2-21: New Features**

Ref #	Audience	Description
1	London Hydro Employees	New premise Wi-Fi solution
2	All Customers	Network Optimization to achieve ISP redundancy for all applications
3	All Customers	Cloud platform for Infrastructure as a Service (IaaS), Platform as a Service (PaaS) and Software as a Service (SaaS)
4	London Hydro Employees	Support for increased number of mobile devices
5	Operations	Connected vehicles
6	London Hydro Employees	New phone system
7	Metering	TCP/IP connected meters

2 In addition to what is depicted above (Figure 2-21), the following timeline (Figure 2-22) and the  
 3 following accomplishments section cover all major initiatives within the IT Infrastructure  
 4 environment at London Hydro.

5

**Figure 2-22: Infrastructure Initiatives**



6

7 To continue to support its business needs efficiently and effectively, London Hydro's strategic  
 8 goals for the infrastructure can be summarized as follows:

- 1           ● Continue to enable server consolidation including support of virtualized infrastructure
- 2           ● Expand capacity to meet rapidly increasing requirements (e.g. documents, voice and
- 3           data, videos, multi-media rich content) by utilizing:
- 4                     1. Cloud technologies, resources and services when business case
- 5                     supports them
- 6                     2. High performance storage
- 7                     3. Increased bandwidth
- 8                     4. Investments in archiving technologies
- 9           ● Provide an enhanced platform for faster and more efficient replication and backup of
- 10           system images and enterprise data and for improved disaster recovery
- 11           ● Support London Hydro's high availability and disaster recovery strategy by providing
- 12           redundancy at all levels of the storage area network, infrastructure, networking and
- 13           devices that support the virtualization and the automatic failover of services
- 14           ● Provide management tools to monitor and automate common housekeeping
- 15           activities
- 16           ● Minimize ongoing operational costs associated with maintenance, product
- 17           integration, operational support and process documentation
- 18           ● Minimize risk-based business costs associated with downtime of services during the
- 19           migration and ongoing operations

20   The following elements have contributed to increasing the reliability of the core infrastructure,  
21   increasing the mean-time-between failures (MTBF), reducing the mean-time-to-recover (MTTR)  
22   and improving the resiliency of the core infrastructure:

- 23           ● Implementing virtualization has allowed London Hydro to move towards self-
- 24           insurance on server hardware maintenance
- 25           ● Improving disaster recovery and business continuity posture through virtualization
- 26           and system replication
- 27           ● Aligning software licensing and support with application lifecycles to reduce costs
- 28           ● Migrating selected customer-facing systems to the Cloud infrastructure to enhance
- 29           availability and accessibility

1 Due to obsolescence, London Hydro has historically been required to replace hardware based  
2 on a five-year life cycle, making the choice of on-premise ownership or Cloud-based service  
3 offering neutral over this timeframe. London Hydro has a goal of keeping vendor supplied  
4 systems current or within one version of their current offering to assure reliability and vendor  
5 support.

### 6 *Capital Spending*

7 Forecasted spending for Hardware/Software for the proposed 2017 Test Year is \$735,000;  
8 \$916,739 lower than the 2013 Actuals, an overall decrease of 56%. Table 2-37 below divides  
9 Hardware/Software spending to the more detailed level.

10 Capital cost savings have been realized through:

- 11 • Infrastructure standardization and consolidation efforts by creating opportunities to  
12 leverage Ministry of Government Services (MGS) Vendor of Record agreements.
- 13 • Opting for Cloud-based services and systems, which have reduced hardware  
14 investments at London Hydro's premises.

15 Capital cost increases have resulted from:

- 16 • Network refresh of on-premise facilities and devices (switches, cabling, routers,  
17 servers)
- 18 • Expanded rollout of mobile devices for field work (harden laptops and cellular  
19 devices)
- 20 • New software acquisitions and associated licence costs
- 21 • Purchase strategy of printers (previously leased) and new capability implementations  
22 such as site wide Wi-Fi, requiring additional hardware

23

1 **Table 2-37 –Hardware and Software Capital Spending 2012 – 2017**

<b>HARDWARE / SOFTWARE CAPITAL SPENDING</b>							
<b>Annual Spending</b>	<b>2012 Actual</b>	<b>2013 Actual</b>	<b>2013 Board Approved</b>	<b>2014 Actual</b>	<b>2015 Actual</b>	<b>2016 Bridge</b>	<b>2017 Test</b>
	\$	\$	\$	\$	\$	\$	\$
Desktop solutions	75,417	75,858	45,000	112,079	136,377	129,000	120,000
Network development	394,167	819,070	200,000	109,615	374,664	195,000	250,000
Servers and storage	641,703	347,304	760,000	127,129	821,405	315,000	220,000
Back up solutions	13,510	23,550	25,000	49,467	38,246	50,000	30,000
Miscellaneous software	50,890	211,109	85,000	200,422	2,023	25,000	25,000
Miscellaneous hardware	1,545	109,812	5,000	18,953	21,428	21,000	15,000
Miscellaneous IT tools	136,622	3,681	5,000	9,289	-	10,000	10,000
Phone system	9,566	28,103	10,000	499,246	2,204	65,000	50,000
Physical plant	10,787	30,230	75,000	-	21,611	-	15,000
Wireless Communication	9,368	98,639	-	-	-	-	-
<b>Total</b>	<b>1,343,575</b>	<b>1,747,356</b>	<b>1,210,000</b>	<b>1,126,199</b>	<b>1,417,956</b>	<b>810,000</b>	<b>735,000</b>
Annual Change		403,781	(537,356)	(621,157)	291,758	(607,956)	(75,000)

2  
3 *Network Development*

4 New Premise Wi-Fi Solution (2013)

5 With increased needs to support mobile workers and access to mobile applications, London  
 6 Hydro made investments to expand its very limited premise based Wi-Fi coverage to ubiquitous  
 7 voice and data grade 802.11n wireless coverage at London Hydro’s buildings located at 111  
 8 Horton Street and in the yard for all employees and guests.

9 By providing ubiquitous coverage for the London Hydro buildings and yard, London Hydro has  
 10 achieved the following benefits for employees, guests and customers:

- 11 • Provided complete Wi-Fi coverage and roaming capability for knowledge workers  
 12 who are often engaged in group meetings and conferences and are away from their  
 13 office but still connected via smart devices
- 14 • Provided a better Wi-Fi experience to partners and guests when visiting London  
 15 Hydro for meetings, collaborations and project activities
- 16 • Provided a better Wi-Fi experience for employees when bringing their personal Wi-Fi  
 17 devices to work and positioning London Hydro for “bring your own device” in the  
 18 future
- 19 • Improved baseline support capabilities for the health, safety and security of  
 20 employees on London Hydro premises.



1 Introduction of the Second ISP (LargNet) (2013)

2 Considering London Hydro's Cloud strategy and the number of Cloud-based services used by  
3 London Hydro, it quickly became evident that London Hydro needed to strengthen its WAN  
4 design and introduce redundancy with internet service providers.

5 In late 2012, London Hydro established a fibre connection between London Hydro's primary  
6 location at 111 Horton and an off-site secondary site. This connectivity provided capability for  
7 enhanced Disaster Recovery and it also delivered a route to connect to the LargNet point of  
8 presence in downtown London in order to gain secondary connection to the internet.

9 London Hydro selected the local provider LargNet as a cost effective solution for establishing  
10 this second connection to the internet and finalized the connectivity in 2013.

11 As London Hydro continues working to enhance Disaster Recovery readiness, its LargNet  
12 connection is going to be its connection of choice for supplying additional bandwidth at low cost.

13 WAN Design Optimization (2015)

14 As London Hydro embraces its Cloud and mobility strategy, the needs for internet bandwidth,  
15 availability and reliability continue to increase. Following few provider outages experienced in  
16 past years, London Hydro introduced secondary WAN connection and continues to work on  
17 hardening its network design to provide full failover for all applications. Since the cost of  
18 bandwidth has decreased, London Hydro was successful in increasing bandwidth availability  
19 without increasing expenditures.

20 Technical Evaluations of Web Chat and Post Call Survey Features (2016)

21 To further enhance communication channels with customers, London Hydro is planning to  
22 complete technical evaluations of "chat" and "post call survey" functionality. Both features will be  
23 configured and tested in house. The goal of these technical evaluations is to better understand  
24 deployment needs as well as develop necessary business processes required to support  
25 additional communication channels in the future.

26 *Servers and Storage*

27 SAN Refresh (2015)

28 Consolidated Networked Storage involves supplying the required storage capacity with fewer  
29 physical resources such as using shared disks on the network or a Storage Area Network  
30 (SAN). Fewer physical storage resources mean less hardware to purchase, less physical

1 complexity to manage, and less space requirement. Consolidated networked storage is also an  
2 essential enabler of server virtualization. When servers provide storage from a common pool,  
3 utilization is optimized. No storage is wasted in inaccessible silos. A single storage management  
4 toolset makes monitoring and tuning storage easier for the system administrators and speeds  
5 servicing requests for storage for both production and project activities.

6 The storage requirement is depicted in Figure 2-23 below. The two largest single storage  
7 consumers are ODS and SAP. The 'Corporate' allocation, while in total is large, serves over 200  
8 virtual machines, supporting such business applications such as GIS, JDE, HR ADP, Bill Print,  
9 Backups, Files Shares, EBT, Prime Infrastructure, Street Sweeper, Infrastructure monitoring  
10 tools and SCADA Web.


11 Historically, the rate of storage growth has been about 20% to 30% per year. Data storage  
12 usage is typically about 10% for the application code itself while the other 90% relates to  
13 transactional data created by each application. With this ratio and considering the efforts to  
14 increase customer engagement and (increases in frequency of) real time metering, the  
15 expectation is that these growth rates will be maintained or may likely increase. To address this  
16 growth, London Hydro refreshed the storage system in 2015. As part of this refresh, London  
17 Hydro selected new technology, fully scalable, with additional storage in order to meet the  
18 growth needs forecasted for next five years.

19 With a growing shift to Cloud computing and its attendant data storage schema, the storage  
20 growth scenario has shifted somewhat. While growth rates remain unchanged, the bulk of this  
21 growth is expected to occur in the Cloud, while very little capacity growth will be required on  
22 premise (also as depicted in Figure 2-23). Where Cloud storage growth is due to a move of an  
23 existing data store from on-premise capacity, the resulting freed up on-premise capacity will be  
24 re-allocated to remaining on-premise systems, thereby deferring real (additional hardware)  
25 increases in this capacity.

26

1

**Figure 2-23: SAN Storage Growth**



2

3 *Miscellaneous Software*

4 Google Apps for Business (2013)

5 Based on a Business Impact Analysis (BIA) review conducted in the fall of 2012, email services  
 6 were identified as a critical service that must be available immediately in the event of a disaster  
 7 to facilitate communications and recovery efforts with staff, customers, partners, utility field  
 8 workers, utility partners, City Councillors and the media.

9 Prior to adopting Google Apps for Business, London Hydro maintained its own on-premise  
 10 Microsoft Exchange 2010 mail service (email).

11 The environment was complex and costly to protect and operate. The on-premise solution,  
 12 although important to daily operations, was not core to the business and it was limited in the  
 13 available features and capabilities. It was determined that commercially available offerings from  
 14 industry leaders, such as Microsoft and Google, provided a feature-rich set of functionalities that  
 15 can be delivered anywhere, anytime to any device securely from the Cloud.

16 With the increased number of mobile devices and the need to support an increasing mobile  
 17 workforce, it was determined that a Cloud-based SaaS (Software as a Service) solution would  
 18 address disaster recovery and user needs. London Hydro investigated different options and

1 selected Google Apps for Business as both cost effective and the solution that best addresses  
2 the user expectations.

3 The summary of benefits includes enhanced disaster recovery, reduced IT operational costs,  
4 consistency with the IT strategy and enhanced end user productivity gains.

5 *Miscellaneous Hardware*

6 Printer Refresh (2013)

7 In 2013, London Hydro refreshed its fleet of Multi-functional Device (MFD) units. With this  
8 refresh, London Hydro achieved the following objectives:

- 9
- 10 ● Improved print quality
  - 11 ● Reduced operating costs when compared to leased units
  - 12 ● Reduced the number of colour devices by increasing the number of monochrome  
13 devices
  - 14 ● Provided features for scanning to Google
  - 15 ● Eliminated most fax boards and analog lines by embracing a Cloud-based fax  
16 solution that supports sending and receiving faxes from any device, from any  
location at a significantly lower cost than the cost of maintaining analog lines

17 Digital Signage (2015)

18 Digital signage can be thought of as the electronic version of the old cork 'Employee Bulletin  
19 Board.' At London Hydro, a dedicated computer system displays current information of  
20 relevance to its employees on a collection of computer monitors. These monitors are centrally  
21 driven by a single source computer for easy administration and quick management of content.  
22 The monitors are large, looking very much like flat screen televisions and are strategically  
23 distributed throughout the company headquarters and Operations areas. They are mounted on  
24 walls in areas of high employee traffic.


25 The purpose of digital signage is to share information with employees. London Hydro made  
26 investments to expand the number of media displays in various locations at 111 Horton used for  
27 sharing of corporate communications and business specific content (PMO news, health and  
28 safety updates, etc.).



1 This solution leveraged investments made in the past and added additional displays in  
2 designated areas while centralizing content management and simplifying IT operations and  
3 maintenance activities.

4 Examples of these digital monitors are shown in Figure 2-24.

5 **Figure 2-24: Typical Digital Signage Stations**



6  
7 *Phone System*

8 Phone System and Call Centre Application Refresh (2014, 2015)

9 As part of the phone system lifecycle management, London Hydro replaced its old Mitel  
10 telephony infrastructure with Cisco based technology. Project objectives concentrated not only  
11 on replacement of legacy infrastructure but also on introducing new features and capabilities for  
12 customers and employees.

13 London Hydro has leveraged its investments in wired and wireless networks. London Hydro's  
14 technology refresh has further integrated its new telephone infrastructure in order to provide  
15 better support to customers by providing rich media communication channels, additional call  
16 centre features, and additional options for supporting our growing mobile workforce while  
17 reducing total cost of ownership and operational risks related to a very complex multi-vendor  
18 environment.


19 This refresh has also provided capabilities for a virtual call centre in the future.

1 Session Initiated Protocol (SIP) Connectivity Enhancements (2016)

2 London Hydro will be updating its infrastructure by introducing SIP connectivity to its Public  
 3 Service Telephone Network (PSTN). The main objectives of this change are to:

- 4 • Reduce operating costs
- 5 • Enable voice channel scalability (both increase and decrease) and improve  
6 monitoring
- 7 • Quicken provisioning times
- 8 • Improve PSTN connectivity and technology diversity
- 9 • Position London Hydro for enhanced disaster recovery (DR)
- 10 • Prepare for hosted or Cloud telephony, contact centre or virtual contact centre (VCC)

11 **Figure 2-27: Migrating from Dedicated Phone Lines to Internet Based Communications**



12

13 Computer Telephony Integration (CTI) (2017)

14 With the integration of the CRM system and the contact centre application, agents can place,  
 15 receive and transfer customer interactions with full, real-time access to customer data, and  
 16 thereby improve monitoring and enhance customer service without switching between screens.  
 17 This improvement will also automatically record call details in CRM for future reference. While



1 doing so, the call centre application will also forward the customer details (such as customer  
2 account number, phone number from where the call is being placed, queue name etc.) so the  
3 Customer Service Representative (CSR) has enough information about the customer before  
4 accepting the customer's call. The term called "Screen Pop" is used to refer to the process,  
5 which results in the CSR receiving the caller's history and information before answering the call.  
6 This integration system not only reduces the call wait time for the customer but also improves  
7 the customer interaction experience.

8 Hosted Telephony and Call Centre (2017)

9 The increasing availability of commercial Cloud-based telephony and call centre solutions has  
10 given London Hydro an opportunity to refresh its infrastructure and position for a future virtual  
11 call centre.


12 While most businesses are attracted to Cloud-based solutions solely for the cost savings, there  
13 is a broad set of additional benefits to consider in terms of disaster recovery and business  
14 continuity planning.

15 London Hydro refreshed its legacy telephony and call centre solution in 2014 with a long term  
16 goal of achieving diversity and redundancy to support the corporate objective of enhanced  
17 customer engagement. With a browser-based call centre agent application and provision for  
18 Session Initiation Protocol (SIP) trunking, London Hydro's voice infrastructure will be prepared  
19 to support the Virtual Call Centre concept and be able to provide a more robust disaster  
20 recovery and business continuity strategy as the application will be accessible anywhere and on  
21 any device as long as internet connection is available.

22

1

Figure 2-25: IVR Call Flow and Hosted Telephony Evolution



2

3

Figure 2-26: Legend of the Numbered Items in Figure 2-25

Item #	Feature	Benefit
1	Call-in capacity increased to handle larger call volumes especially in cases of major outages	Concurrent calls capacity raised from 115 up to 1000 before a customer would get a busy signal
2	Automation of caller ID to improve inbound message handling and added capability for 'outbound' broadcast of messages	Simpler process and reduced customer efforts to identify issues and receive updates
3	Implemented "soft" technology	Staff no longer bound to 'fixed' workstations and can work from any where
4	Consolidated multi vendor environment into one - Cisco	Unified communications capability gives more options for call handling
5	Added peak demand overflow capacity with external vendor	Engage additional CSR 'on-demand' resources during peak periods such as student 'move in/out' times
6	Increased customer choice of how they interact with the utility	Customer chooses the method of communication that meets their preference or current needs

4


5

1 **Application Development (W)**

2 *Overview*

3 The trend of the combined budgets for Infrastructure and Application Development, including  
4 the subsets mentioned, is presented below in Table 2-38. In each budget year, the focus of the  
5 IT strategy for each of the key goals is determined by the business needs, and those needs  
6 define and evolve into specific projects for implementation and, eventually, the capital budget.

7 **Table 2-38: IT Capital Spend Profile**



8  
9 As noted in the last London Hydro rate filing, the focus of the IT projects until 2013 was to build  
10 a solid, reliable “back end office” for the management of business data and business process  
11 support. This effort was dictated by the provincial mandated move to smart metering and TOU  
12 rate billing.

13 During the 2013 to 2017 period, the focus switched to front end or customer facing systems,  
14 applications and services such as MyLondonHydro, the Builders’ and Property Management  
15 Portals, IDC and Event Assist. London Hydro continues to develop its Metering Department  
16 capabilities, such as expanded RNI wireless services, to provide greater customer  
17 communications, such as real time outage notifications and up to the last hour consumption  
18 data (limited to select customers) for meaningful cause and effect data displays.



1 London Hydro's key technology focus areas for next 3 to 5 years are to

- 2           • Continue to focus on developing ground-breaking features to engage customers in a  
3 meaningful manner
- 4           • Continue to focus on Cloud technologies – Continue the migration of old systems  
5 and the building of new systems using the Cloud platform
- 6           • Continue to build an Outage Management System that enhances response agility  
7 and information availability
- 8           • Continue to build a foundation for Enterprise Resource Planning (“ERP”)  
9 implementation as per the Ernst & Young (E&Y) “Evaluation of JDE Upgrade and  
10 Deployment Options” (refer to Exhibit 4, Appendix 4-1)
- 11          • Start building Business Intelligence capability to realize the value of smart metering  
12 and OMS/GIS data
- 13          • Optimize current solutions through standard software upgrades that provide  
14 enhanced functionality
- 15          • Continue to focus on remaining compliant with regulatory requirements

16 However, as noted in the section above regarding life cycles, the completion of a capital project  
17 is not the end of the work or capital expenditures for that item, service or function. Whether it is  
18 an Infrastructure or Application Development solution that has been implemented, it must be  
19 recognized that the completed system/application/function does not go on indefinitely but has a  
20 specific life (cycle) that cannot be sustained forever even with the best operational support.

21 Significant increases in network bandwidth usage from Cloud-based applications and the  
22 computing requirements from additional local systems have raised costs in these areas to the  
23 point where optimization efforts are warranted and cost effective. Therefore, Application Load  
24 Balancing and WAN Optimizer tools and processes will be implemented in an effort to maximize  
25 the efficiency of existing resources to reduce these impacts as much as possible and avoid  
26 costs associated with additional purchases that would be required without optimization.

27

1 *Capital Spending*

2 Forecasted spending for Application Development for the proposed 2017 Test Year is  
 3 \$3,775,000; \$1,353,280 lower than the 2013 Actuals. Table 2-39 below divides Application  
 4 Development spending to the specific project type.

5 **Table 2-39 – Application Development Capital Spending 2012 - 2017**

APPLICATION DEVELOPMENT CAPITAL SPENDING							
Annual Spending	2012 Actual	2013 Actual	2013 Board Approved	2014 Actual	2015 Actual	2016 Bridge	2017 Test
	\$	\$	\$	\$	\$	\$	\$
Customer Information System (CIS)	383,121	874,096	835,000	601,952	406,743	855,000	300,000
CIS retailer requirements	767,734	-	-	-	-	-	-
CIS Customer Relations Management upgrade	-	726,038	525,000	417,044	-	175,000	-
Cyber Security	-	-	-	-	266,760	125,000	50,000
System Foundations	-	-	-	-	250,242	305,000	150,000
Customer Engagement - Residential	-	-	-	539,465	648,647	300,000	825,000
Customer Engagement - Commercial & Industrial	-	-	-	-	8,121	740,000	400,000
CIS regulatory requirements	260,602	266,879	480,000	9,017	304,583	140,000	250,000
Geographic Information System (GIS)	453,662	-	-	-	158,736	40,000	-
Outage Management System (OMS)	707,427	1,194,718	1,500,000	514,796	107,614	350,000	-
Customer Engagement / Web Presentment & TOU	208,782	1,524,585	500,000	45,314	-	-	-
Meter data	1,548,041	4,696	-	229,753	314,117	150,000	400,000
Mobile Workforce (MWFM)	-	518,019	450,000	489,533	781,324	300,000	300,000
Business intelligence	-	19,249	500,000	1,912	150,814	175,000	250,000
Enterprise Resource Planning (ERP)	-	-	-	450,607	748,319	475,000	850,000
<b>Total</b>	<b>4,329,368</b>	<b>5,128,280</b>	<b>4,790,000</b>	<b>3,299,393</b>	<b>4,146,021</b>	<b>4,130,000</b>	<b>3,775,000</b>
Annual Change		798,912	(338,280)	(1,828,887)	846,628	(16,021)	(355,000)

6  
 7 *Support to IT projects for Interval Data Center customer facing applications*

8 As electricity prices continue to rise and become more volatile (HOEP, Global Adjustment),  
 9 having a customer facing application that can enable a collaborative conversation about energy  
 10 use between London Hydro and the customer has proven valuable.

11 London Hydro has found that there is additional value in meter data beyond the business  
 12 process of bill creation for its customers. Meter data is valuable for the internal operations of its  
 13 customers to understand their electricity consumption and demand characteristics. ‘Value-  
 14 added’ applications can extract data from the ODS and make it available for business use to  
 15 better manage the consumption and operating costs.

16 London Hydro has created the ‘Interval Data Center’ application and has made it available to all  
 17 interval metered London Hydro customers. This application was developed by London Hydro

1 with the input from a cross-section of customers to ensure that the features and usability met  
 2 their needs. For example, having a mobile tool that could be accessed from a cell phone was a  
 3 key feature for providing meter and energy data at the customers' finger tips.


4 Based on the Green Button platform and standards, London Hydro customers can access data  
 5 and aggregate not only from any property within London Hydro's service area but from any  
 6 property served by an LDC also employing the Green Button platform.

7 Figure 2-28 illustrates the Interval Data Center's main data screen.

8 Customers are able to use this data directly or delegate 3<sup>rd</sup> parties to use the application on their  
 9 behalf. Providing customers with access to their own data has empowered them and has also  
 10 reduced the increasing number of requests received by London Hydro for such data. As a  
 11 result, London Hydro has been able to reduce the amount of manual effort required to create  
 12 individual responses to each enquiry.

13

**Figure 2-28: Interval Data Center MyAccount tool**




14

15 One example of an IDC application was created for the Thames Valley District School Board.  
 16 The Interval Data Center became the single energy management dashboard for 162 schools  
 17 across 7 utilities and the underlying data source was provided from the Green Button standard.  
 18 The application allowed the school board to get a single view of all their facilities without paying



1 for 3<sup>RD</sup> party aggregation services. In addition, initiatives are also planned for the creation of  
 2 new applications to support AMI data (i.e. Voltage, Alarms, and Power Quality).

3 **Figure 2-29: London Area School Board Green Button Use Case**




4  
 5 Other data sources from the meters are currently being integrated into London Hydro's business  
 6 systems. The availability of voltage, outage and power quality alarms are becoming new  
 7 sources of business value that London Hydro can use to enhance internal operation and  
 8 customer value. The outage map website is another example.

9 Another example of internal monitoring is the metering anomaly and reporting protocol tool as  
 10 shown in Figure 2-30. This tool sets voltage thresholds for meters and can identify meter  
 11 failures, phase outages, voltage spikes, incorrectly set transformer taps, seasonal voltages and  
 12 tampering situations. The tool provides a Quality System Technician operator with all the  
 13 required information in one screen and allows for tracking and disposition status to keep track of  
 14 issues. The tool was developed internally and has found many system and equipment issues  
 15 that have been corrected proactively without the customers' awareness.

16

1

Figure 2-30: Smart Meter Voltage Monitoring Application



2

### 3 Capital Spending Cost Drivers

4 Capital spending related to Application Development fluctuates from year to year as a result of  
5 the following factors:

- 6 • Life cycle of enterprise systems (e.g. CIS, GIS) require regular investments for  
7 patches, upgrades and enhancements to activate new functionality delivered by the  
8 vendor (e.g. EBT, BI)
- 9 • Variable demand for regulatory requirements from the OEB and Measurement  
10 Canada
- 11 • Adjustments to project plans based on the capacity/capability and business priorities  
12 (e.g. OMS, ODS, MDMR, Customer Self Service)

13 Capital cost avoidance has been realized through the:

- 14 • Reduced use of professional external services as more internal labour can be  
15 directed to capital projects
- 16 • Increased employment of SaaS Cloud-based applications

17

1 Capital costs have increased through:

- 2
- 3 ● Increased IT landscape architecture and complexity
    - 4 ○ System capacity and increased performance requirements
    - 5 ○ Increase in the number of new systems, interfaces and integration
    - 6 ○ Increase in data volumes to be managed and distributed
  - 7 ● New system licences (e.g. OMS, mobile work force management, new HR system, mobile devices)

8 Additional infrastructure projects related to phone system enhancements include:

- 9
- 10 ● CTI integration
  - 11 ● Strategy development for Cloud-based contact centre and phone system solution

12 Other infrastructure projects planned for 2017 include:

- 13
- 14 ● SAN growth to accommodate additional Virtual Desktop Infrastructure (VDI) deployments
  - 15 ● SAN fabric lifecycle refresh
    - 16 ○ The hardware that connects workstations and servers to storage devices in a SAN is referred to as a "fabric." The SAN fabric enables any-server-to-any-storage device connectivity through the use of *Fibre Channel* switching technology
  - 17 ● Network refresh strategy including Networking components in DR site
  - 18 ● Migration to Windows 10 OS for end users

21

1 2016 Plan - IT Capital Projects

2 **Table 2-40: 2016 IT Capital Project Plan**

Project Description	Budget	Rationale / Benefits
<b>Regulatory &amp; Sustainment</b>		
Enhanced Disaster Recovery	\$125,000	Increased system reliability for critical systems like CIS, OMS etc.
Security System Upgrades	\$75,000	Enhance cyber security
Automated System Monitoring and Alerts	\$80,000	Reduced system downtime
SAP Personas/ECC EhP7 Upgrade	\$150,000	Maintain currency of SAP platform
Infrastructure Upgrades - Application Enhancements	\$100,000	Accommodate infrastructure upgrades within existing applications
Regulatory Changes	\$140,000	OEB mandated changes
End Point Security Initiatives	\$50,000	Provides comprehensive threat protection and data security
Specialized Systems Upgrades	\$100,000	Incorporate custom made applications into enterprise level platforms and
Bill Print Refresh	\$555,000	Replace obsolete bill print system
OMS Upgrade	\$350,000	Maintain currency of OMS for vendor support
<b>Sub-total Regulatory and Sustainment</b>	<b>\$1,725,000</b>	
<b>Enhancements</b>		
Customer Engagement Solutions	\$300,000	Customer engagement tools (e.g. proactive alerts, outage map)
Mobile Workforce phase 3	\$300,000	Automate Service Orders (EUS, Collections and Construction depts)
Commercial & Industrial Apps	\$300,000	Customer engagement tools for commercial & industrial customers
SAP Business Process Improvement	\$150,000	Automation of AP Collection email, Service Order processing
Mobile Link Enhancement	\$40,000	Tool to conduct field inspection/Audits by operations
Green Button	\$150,000	Design and Implement new features for green button standard
Customer Relationship Management (E/O)	\$175,000	To enable CRM for operations and CDM groups
<b>Sub-total Enhancements</b>	<b>\$1,415,000</b>	
<b>New Systems</b>		
Builders' Portal	\$240,000	Manage order tracking and notifications for builders
New Property Management Portal	\$200,000	Host existing property management portal on supported platform
Learning Management System	\$150,000	Enterprise level training to improve skills / reduce compliance risks
Fleet Maintenance System	\$225,000	Improve LH fleet management (uptime, efficiency, useful life)
Analytics Systems Phase 1	\$175,000	Data analytics - interval & smart meter with grid connectivity and billing data
<b>Sub-total New Systems</b>	<b>\$990,000</b>	
<b>Infrastructure</b>		
	\$810,000	Asset refresh, enhanced backup capability, system upgrades as part of life cycle management
<b>Sub-total Infrastructure</b>	<b>\$810,000</b>	
<b>2016 Total Capital Budget</b>	<b>\$4,940,000</b>	

3  
4 2016 Regulatory & Sustainment Projects

5 Enhanced Disaster Recovery (DR)

6 London Hydro has a large portfolio of IT systems that are integral to the effective operation of  
7 the business. Many of these systems are highly integrated and not only exchange data  
8 regularly, but also ensure that the correct data is exchanged only when interim processing steps  
9 are completed successfully in proper sequence. In the event of a disaster, whether of a natural  
10 source (e.g., fire) or not (e.g., cyber-attack), it is essential that the IT Department is able to  
11 return these systems to a reliable, accurate operating state as quickly as possible in either the  
12 IT centre or the DR facility.



1 The IT Department will design, test and implement a comprehensive DR plan that spans all  
2 systems and clearly indicates not only the proper procedure for the return to service of an  
3 individual system but also the proper order of the return of all systems and to confirm that a  
4 normalized state of service is achieved.

#### 5 Security System Upgrades

6 Cyber-attacks on utility systems have increased in frequency, and it is critical for London Hydro  
7 to safeguard its systems in the event of such an attack.

8 This project will implement and enhance security for London Hydro's IT systems, including  
9 performing a security audit, virtual firewall enablement and upgrades. These measures are  
10 necessary to make sure London Hydro systems are secure and protected from malicious  
11 targets.

12 With improved cyber security, London Hydro reduces the risk of exposure to malicious attacks  
13 that could compromise customer data privacy, operational efficiency and reliability.

14 Refer to Exhibit 4, Table 4-27 "Number of Daily Attempted Intrusions Chart" for information  
15 regarding quantities of cyber-attacks.

#### 16 Automated System Monitoring and Alerts

17 This project will provide automated enterprise system level monitoring and alerts that will lead to  
18 early detection of system performance issues and enable quicker and more proactive resolution.  
19 This enhanced system monitoring will increase uptime of London Hydro's systems by reducing  
20 resolution time.

21 The purpose of this project is to upgrade and incorporate custom-made applications into  
22 enterprise level platforms and systems. As part of the overall IT strategy, London Hydro will  
23 move a number of discrete IT applications to enterprise systems to facilitate the reduction of  
24 internal infrastructure usage. This project will cover the implementation of integration  
25 technologies to manage on-premise and Cloud communications, thereby setting the groundwork  
26 for later migration of major enterprise systems. Many small, discrete systems are maintained on  
27 obsolete platforms and need to be upgraded. This project will address these applications with  
28 the aim of moving them to the supported platforms. With the move of these discrete applications  
29 into enterprise-wide systems, London Hydro reduces the manual effort required for  
30 maintenance, thereby improving system efficiencies and reliability.



1 SAP Persona/ECC EhP7 Upgrade

2 This project involves deploying the latest SAP enhancement package P7 and upgrading SAP  
3 personas to version 3 to maintain eligibility for vendor support of this product suite and to follow  
4 the IT strategy of maintaining vendor software at the current or “current -1” level. This upgrade  
5 to the core SAP system will introduce new billing and AMI-related features delivered by SAP to  
6 reduce London Hydro’s need to maintain custom coding. As part of this upgrade, SAP’s user  
7 interface framework will also be deployed, simplifying and optimizing business processes  
8 through custom screen layouts as well as reducing the support burden by moving to a web-  
9 based primary interface. This enhancement will reduce the manual effort required to maintain  
10 custom code and thereby increase efficiency. Efficiency also increases due to the ease of use of  
11 the user interface framework.

12 Infrastructure Upgrades - Application Enhancements

13 The purpose of this two-year project is to implement changes to applications due to  
14 infrastructure upgrades. London Hydro has embraced virtualization and Cloud technologies and  
15 most of London Hydro’s applications have already been migrated to these platforms. As part of  
16 this initiative, London Hydro will be focusing on enhancing overall resiliency of applications  
17 within virtualized and Cloud environments. London Hydro will also pursue a data prevention loss  
18 strategy and implement various tools to ensure London Hydro’s applications are further  
19 safeguarded and to keep up with platform upgrades. These upgrades will reduce the risk of  
20 system obsolescence and ensure London Hydro’s IT infrastructure aligns with the latest  
21 technologies, thereby increasing system reliability and efficiency.

22 Regulatory Changes

23 Throughout the course of a year, regulatory changes with low to high complexity can occur with  
24 deadlines for implementation within the same year. This project represents a container for such  
25 changes and is completed year to year to address ongoing regulatory changes. Examples of  
26 regulatory changes include system changes to accommodate fixed distribution rates and debt  
27 reduction. With these changes, London Hydro will ensure regulatory compliance and, in doing  
28 so, will enhance customer value since many of the regulatory changes relate to improvements  
29 for customers. The twice yearly rate changes to the RPP electricity commodity prices are  
30 implemented under this project. It is further anticipated that project work will be required  
31 regarding the collection of additional data associated with each smart meter for inclusion into



1 the 'Distribution and Commodity Rates' as described in the "Smart Meter Entity (SME) EB-2015-  
2 0297 document (effective Jan, 1 2017).

### 3 Endpoint Security Initiatives

4 As London Hydro continues to develop and deploy mobile applications across departments, the  
5 need for endpoint security that provides comprehensive threat protection increases.

6 The purpose of this project is to design and implement endpoint security initiatives.

7 This initiative ensures robust cyber security to guard against possible data breaches. Data  
8 security is required to protect users and corporate information across every device and  
9 application. With robust end-point security in place, London Hydro ensures minimal exposure to  
10 security breaches and thereby increases both the reliability and efficiency of the mobility  
11 platform.

### 12 Specialized System Upgrades

13 A variety of discrete specialized systems within London Hydro's IT landscape are maintained on  
14 obsolete or near-obsolete platforms. In order to provide continued support for the business  
15 processes managed using the functionality of these systems, we need to upgrade and/or  
16 replace the capabilities provided. This project will better align these systems with our core  
17 enterprise systems support and Cloud strategy.

18 To enable the long-term support of the corresponding business processes, this project will  
19 include the implementation of integration technologies to manage 'on-premise' and Cloud  
20 communications, thereby setting some of the groundwork for later migration of major enterprise  
21 systems.

### 22 Bill Print Refresh

23 London Hydro's current bill print system is a custom solution built on Oracle reports and custom  
24 PL/SQL code. The version being used is outdated and no longer supported by Oracle. This  
25 system is also limited in terms of allowing modifications to existing invoice layouts, putting  
26 London Hydro at a risk of not being compliant with certain OEB regulations.

27 This project will deliver a replacement solution that will provide required business functionality  
28 and address risks associated with the current legacy systems, including:

- 1       • Provide a robust, scalable and fully functional bill printing and customer communication
- 2       solution
- 3       • Implement a full-featured solution that meets current and future business requirements,
- 4       is vendor supported and uses industry standard technology components
- 5       • Implement a solution with multi-site disaster recovery capabilities

6 The solution for a new bill print service is consistent with London Hydro's IT Strategy of moving  
7 from fixed cost on-premise solutions to variable cost Cloud-based, Software as a Service  
8 (SaaS) solutions. Customer invoicing data would reside in Canadian data centres with this  
9 solution.

10 Changes are needed in London Hydro's bill printing and presentment solution for the following  
11 reasons:

- 12       • The current tool is functionally deficient and inflexible for modifying invoice document
- 13       layouts
- 14       • The current bill printing solution is not supported by a resilient and geographically
- 15       diverse disaster recovery platform
- 16       • London Hydro needs to create a platform to support and maintain high levels of
- 17       customer service in the short and long term
- 18       • London Hydro wants to enhance its brand by being able to communicate with specific
- 19       customer groups
- 20       • The current solution is not aligned with London Hydro strategic objective of maximizing
- 21       the benefits of Cloud-based solutions

22 The following summary features are required in the selected solution, and they are expected to  
23 provide the following benefits: address validation, archiving, disaster recovery, document  
24 handling, document inserts, grouping and sorting, interfaces, mail handling, monitoring,  
25 reporting, multiple formats, process capacity, security, QR codes and targeted communications.

26 With the availability of these new features, London Hydro can deliver enhanced customer value.

## 27 OMS Upgrade

28 The purpose of this project is to upgrade the Outage Management System (OMS) to its latest  
29 version and remove dependencies on an unsupported platform. London Hydro went live with  
30 OMS in early 2013; since then, OMS has been the backbone of operations. OMS has provided





1 ease of use and effectiveness in the Control Room since its inception; however, OMS has  
2 recently experienced unplanned downtimes arising from platform obsolescence. London Hydro  
3 needs to complete the OMS upgrade as soon as possible to avoid any further downtimes and to  
4 increase the system reliability. With the implementation of the latest version, London Hydro  
5 aligns with its strategy of maintaining vendor software inventory to either *current* or "*current-1*"  
6 versions to ensure critical system reliability, which is integral to the safety of field crews.

#### 7 *2016 Enhancement Projects*

##### 8 Customer Engagement Solutions

9 This project is designed to increase Customer Engagement (CE), value and satisfaction through  
10 the addition of enhanced features on London Hydro's customer portal. This project will further  
11 enhance the customer-facing website, MyLondonHydro, with improved customer engagement  
12 features such as fully automated "move in/move out" capability, additional notification choices,  
13 outage restoration confirmation and improved website performance.

##### 14 Mobile Workforce Phase 3

15 The purpose of this project is to implement a Mobile Workforce system for the EUS,  
16 Construction and Collection Departments. This project is a continuation of the Mobile Workforce  
17 project that started in 2014. This phase will involve further automating field work completion by  
18 EUS, Collections and Construction Departments. The scope will be expanded to include  
19 features such as Utility Work Protection Code (UWPC), access to safety documents, automation  
20 of collection orders, trouble orders, etc. The use of mobile workforce increases efficiency by  
21 providing a single source of information related to service order completion that is available to  
22 all parties in real time. Having a single source of information available to all parties in real time  
23 eliminates the misunderstandings that can result from multiple versions of hard copies being  
24 used by different parties; also the convenience of having immediate access to safe work  
25 practices will support worker and public safety. In terms of interoperability, this project will  
26 enable seamless integration between workforce management system and London Hydro's ERP  
27 systems.

##### 28 Commercial & Industrial Apps

29 With this project, London Hydro will continue to develop a number of customer engagement  
30 offerings for its commercial customers, delivering significant value to a traditionally underserved

1 customer class. Responding to customer requests, London Hydro will provide advanced  
2 solutions to improve energy forecasts and facilitate energy conservation. These solutions will  
3 provide proactive information and actionable insights for commercial customers to identify areas  
4 of improvement of their operations, while optimizing their energy consumption. A number of  
5 successful use cases, presented in Exhibit 4, Appendix 4-2, have already been developed in  
6 consultation with commercial customers, helping them save costs related to energy  
7 consumption.

8 Some of the upcoming features for the Interval Data Centre (IDC):

- 9 ● Enhance how we track users in IDC; improve engagement (IDC Site Analytics  
10 Enhancement)
- 11 ● Improve data download capabilities of IDC and User Options (Data Download for All  
12 Channels > 6 Months Enhancement)
- 13 ● Enhance interface to increase usability by showing customers what data is available for  
14 each meter (Meter Data Availability Indication Feature)
- 15 ● Add a Help Feature to IDC
- 16 ● Create broader offering (and enhancement) of the Financial Report tool
- 17 ● Enhance customer energy notifications
- 18 ● Improve annotation engine (enhancing user energy accountability)

19 SAP Business Process Improvements

20 These enhancements projects aim to continue leveraging the value of the SAP investments by  
21 enabling new business processes or enhancing and optimizing existing business processes  
22 using the technology available in the existing system. This project comprises several sub-  
23 projects addressing specific objectives on a per-department basis.

24 These SAP enhancements will support all departments that use SAP and increase both  
25 efficiency and system reliability by enabling new business processes and enhancing existing  
26 processes.

27 Mobile Link Enhancements

28 The objective of this project is to enhance the Mobile Link product to conduct field  
29 inspections/audits by Operations Departments. In 2015, the Field Sketch system was replaced  
30 with the Mobile Link product as a way of automating and streamlining these processes for “in-



1 field” inspections and audits of distribution assets. With this project, the Mobile Link product will  
2 be enhanced to include added fields to support more accurate and detailed inspection and audit  
3 information. The more accurate and detailed field audits and asset information will increase  
4 efficiency in asset planning and reliability. More detailed and accurate field inspections will result  
5 in more timely replacement of assets that may be at risk of posing a safety threat or harm to the  
6 environment. The cyber security and data privacy related to affected systems/platforms will be  
7 maintained or enhanced.

#### 8 Green Button

9 This project aims to provide additional functionality for customers using the Green Button  
10 Standard and thereby enhance customer value. London Hydro has championed the Green  
11 Button initiative across North America and has been at the forefront in the development of the  
12 standard. Under this initiative, London Hydro will continue to develop applications that will take  
13 advantage of the Green Button platform and continue to provide support to third party vendors  
14 for developing customer-focused applications to help customers reduce their energy  
15 consumption.

#### 16 Customer Relationship Management - Process Improvements (E/O)

17 The purpose of this project is to facilitate Customer Relationship Management (CRM) for  
18 Operations and Engineering groups. This project is a follow up to CRM implementation in 2014.  
19 Using CRM, Operations and Engineering groups will be able to capture customer interactions,  
20 including history, times and details of subject matter in order to better serve customers during  
21 subsequent interactions. Efficiency will be increased related to the recording of customer  
22 interactions using the CRM system in the Engineering, Metering and Operations Departments.  
23 Customer value is enhanced as any person at London Hydro taking a call will be able to see the  
24 call history of the caller and thereby facilitate service and/or problem resolution. Interoperability  
25 is enhanced as all departments will be working with the same information related to customer  
26 interactions.

#### 27 *2016 New Systems Projects*

##### 28 Builders’ Portal

29 The purpose of this project is to design and implement a web-based portal that will allow  
30 builders to manage and track service requests and receive update notifications regarding their



1 construction projects. This project stems from customer feedback that was received upon the  
2 success of the Property Management Portal application and will function in a similar manner.  
3 This service enhancement is a direct result of London Hydro's response to customers' (builders')  
4 requests to provide an online way to request service and track the progress of those requests.  
5 Using this portal, customers/builders will be able to set up alerts to receive notifications for any  
6 updates to their service request in real time. This self-help portal will enhance service to builders  
7 by providing them with a simpler method for requesting services and for checking the status of  
8 their requests. This self-service functionality is expected, as in the case of the property  
9 management portal, to eliminate a significant number of repeat phone enquiries by builders to  
10 the Customer Service Department, freeing CSR staff to address other issues that are not as  
11 easily automated.

#### 12 New Property Management Portal

13 This project will replace the current Property Management Portal to provide greater functionality  
14 to the customer and reduce the internal support requirements of London Hydro IT staff.


15 This portal will be re-hosted within the London Hydro's Customer Engagement website, which  
16 will require a significant rewrite of the supporting code, and this project provides an excellent  
17 opportunity to add new and enhanced functionality requested in customer feedback and  
18 surveys.

19 Improved value for property managers will be realized since enhancements will be responding  
20 to their requests. By integrating the property management function into London Hydro's  
21 Customer Engagement website, support efforts will be reduced since the IT Department will no  
22 longer be required to maintain these two as separate systems.

23

1


Figure 2-31: Dashboard View from the Property Management Portal



2

3

Figure 2-32: Map from the Property Management Portal



4

1 Learning Management System

2 London Hydro will implement a Learning Management System (LMS), which is an industry best  
3 practice, to improve skills, reduce compliance risks and enable training management at an  
4 enterprise level. The implementation of a LMS will simplify the tracking and scheduling of  
5 training and thereby create efficiencies and reduce the risk of non-compliance. By automating  
6 the tracking and scheduling of training, London Hydro ensures that no employee “falls through  
7 the cracks” and misses safety-related training.

8 Fleet Maintenance System

9 This project will enable the fleet maintenance functionality of the JD Edwards System. This  
10 capability will increase uptime, efficiency and the overall useful life of London Hydro's fleet of  
11 vehicles. This automated system will replace the current manual processes, including the  
12 tracking and scheduling of Preventive Maintenance (PM), thus reducing the likelihood of  
13 unexpected vehicle breakdowns. Fewer breakdowns equates to more vehicles being available  
14 to effect repairs such as service outages and downed lines. Vehicles that are up-to-date in  
15 terms of PM are safer to operate.

16 Analytics System Phase 1

17 The overall project objective is to deliver a platform that provides the base capabilities to  
18 support all current and future data analysis and retrieval objectives with guaranteed integrity in a  
19 cost-effective manner. This project involves the consolidation of data, reporting tools, queries  
20 and reports from all of London Hydro's systems (operational and financial) in an effort to  
21 streamline information gathering. This system will provide efficiencies by removing  
22 redundancies and providing more timely and accurate information to support decision-making.

23 The first phase of the Analytics Systems Implementation project will enable more effective use  
24 of interval and smart meter data in conjunction with grid connectivity and billing data using "big  
25 data" technologies. This functionality will support improved distribution system planning  
26 processes and enable the development of analytical processes that can provide more context to  
27 customers with respect to their individual energy usage.

28 This increased efficiency will allow more effective use of interval and smart meter data.  
29 Customers will have access to more detailed data regarding their energy usage, improving



1 customer value. This project involves leveraging the interoperability of London Hydro's systems  
 2 to enhance analytic processes.

3 *2017 Plan - IT Capital Projects*

4 **Table 2-41: 2017 IT Capital Project Plan**

Project Description	Budget	Rationale / Benefits
<b>Regulatory &amp; Sustainment</b>		
Oracle Upgrade	\$100,000	Implement changes to existing applications due to Oracle upgrades
Security System Upgrades	\$50,000	Enhanced cyber security
HRIS Enhancements	\$150,000	Implement deferred HRIS features
Infrastructure Upgrades - Application Enhancements	\$50,000	Accommodate infrastructure upgrades within existing applications
Regulatory Changes	\$250,000	OEB mandated changes
ODS Upgrade	\$250,000	Upgrade ODS to mitigate obsolescence risk
<b>Sub-total Regulatory and Sustainment</b>	<b>\$850,000</b>	
<b>Enhancements</b>		
Customer Engagement Solutions	\$425,000	New customer engagement features (proactive alerts, billing forecasts etc.)
Timesheet Field Automation	\$300,000	Integrate field time sheets with mobile workforce system
Asset Management System	\$200,000	Implement enterprise wide asset tracking
Commercial & Industrial Apps	\$400,000	Customer engagement tools for commercial and industrial customers
SAP Business Process Improvements	\$300,000	Implement SAP enhancements to incorporate process changes
Green Button	\$150,000	Design and implement new features for Green Button standard
Analytics System Phase 2	\$250,000	Develop and optimize business intelligence
<b>Sub-total Enhancements</b>	<b>\$2,025,000</b>	
<b>New Systems</b>		
Automated Billing Payments	\$200,000	Enable automatic billing payment from IVR/CE website
Residential Customer Mobile Application	\$200,000	Deploy residential customer mobile app to increase customer engagement
JDE Upgrade	\$500,000	Upgrade JDE system to avoid obsolescence risk
<b>Sub-total New Systems</b>	<b>\$900,000</b>	
<b>Infrastructure</b>		
	\$735,000	Asset refresh, enhanced DR capability, new communication channels with our customer and system upgrades as part of life cycle management
<b>Sub-total Infrastructure</b>	<b>\$735,000</b>	
<b>2017 Total Capital Budget</b>	<b>\$4,510,000</b>	

5  
 6 *2017 Regulatory & Sustainment Projects*

7 Oracle Upgrade

8 Oracle is an industry standard relational database product used to store application data in  
 9 customizable formats that are appropriate to computer applications.

10 The purpose of this project is to implement an essential Oracle upgrade and the required  
 11 changes to related applications (that use the Oracle database function to store their data). The  
 12 Oracle upgrade is significant and the protocols with which it interfaces and exchanges data with  
 13 other London Hydro IT systems will be affected. This project will ensure that necessary code  
 14 changes due to the Oracle upgrade for both backend services and systems are implemented. A



1 number of systems will be affected by this upgrade including the Outage Management System  
2 (OMS), GIS and JDE.

3 The Oracle upgrade will reduce the risk of system failure due to obsolescence and ensure that  
4 key systems that affect reliability and customer value, including OMS, GIS and JDE, are  
5 functioning properly.

#### 6 Security System Upgrades

7 This project will include a security audit, virtual firewall enablement and upgrades. These  
8 measures are necessary to make sure London Hydro systems are secure and protected from  
9 malicious targets and are in response to increased cyber-attacks on utility systems. It is critical  
10 for London hydro to safeguard its systems from the threat of these attacks.

#### 11 HRIS Enhancements

12 With the implementation of the Human Resources Information System (HRIS) in 2015, a  
13 conscious decision was made not to automate or replace a number of features in order to lower  
14 the risk of this significant system replacement, ease the transition between old and new  
15 systems, and reduce the learning curve for HR staff and users.

16 This project will target full automation of additional HR activities and processes that were not  
17 covered under the 2015 implementation, such as benefits calculation and automated pay stubs.  
18 By purposely deferring some aspects of implementation, London Hydro also benefits by having  
19 the opportunity to work with the system and identify gaps in processes that need to be  
20 addressed.

21 These HRIS system enhancements will further augment London Hydro's ERP implementation  
22 and create efficiencies related to Payroll and Finance functions.

#### 23 Infrastructure Upgrades - Applications Enhancements

24 The purpose of this two-year project is to implement changes to applications related to  
25 infrastructure upgrades. London Hydro has embraced virtualization and Cloud technologies, and  
26 most applications have already been migrated to these platforms. As part of this initiative,  
27 London Hydro will be focusing on enhancing overall resiliency of applications within virtualized  
28 and Cloud environments. London Hydro will also pursue a data prevention loss strategy and  
29 implement various tools to ensure London Hydro's applications are further safeguarded and to





1 keep up with platform upgrades. These upgrades will reduce the risk of system obsolescence  
2 and ensure London Hydro's IT infrastructure aligns with the latest technologies, thereby  
3 increasing system reliability and efficiency.

#### 4 Regulatory Changes

5 Included in this project are the twice a year rate changes to the "RPP Electricity Commodity  
6 Prices." It is anticipated that in addition to this activity, additional changes may result from the  
7 discussions that will be occurring within the microFIT program regarding Net Metering versus  
8 Parallel Contract Price models.

#### 9 ODS Upgrade

10 The Operational Data Store (ODS) is an on-premise, platform-based OTS system. With  
11 increased data gathering from meters, this system needs to be upgraded to provide scalability,  
12 low cost maintenance and also address the technology platform obsolescence. With the  
13 upgrade of ODS, the reliability of the ODS system will increase and customer value will be  
14 enhanced as London Hydro will be in a better position to provide more detailed usage analytics.

#### 15 *2017 Enhancement Projects*

##### 16 Customer Engagement Solutions

17 In this project, London Hydro will evaluate the usage patterns for its consumer-facing  
18 applications, including MyLondonHydro, Interval Data Centre and Property Management Portal.  
19 On the basis of customer usage statistics and customer focus groups, we will make changes to  
20 the user interface of these applications in order to improve the overall customer experience. The  
21 overall objective for this project is to optimize and enhance features that our customers find  
22 most valuable and minimize the development and maintenance of features that are little used.

23 As part of the technical elements of this project, we will update the open source user interface  
24 frameworks utilized to provide a responsive design for the applications. This update will ensure  
25 ongoing compatibility with both new and old devices that our customers use while allowing us to  
26 continue providing services that meet requisite accessibility guidelines.



1 Timesheet Field Automation

2 The purpose of this project is to integrate a time and attendance system into the Mobile  
3 Workforce Management System. This enhancement will enable the automation of time entry for  
4 field crews using the Mobile Workforce Management System.

5 The objective of this project is to reduce the manual effort required by field workers to enter the  
6 time details for service orders, and, as a result, it will also reduce the potential for error. This  
7 project will help automate the time and attendance approval process for supervisors, thereby  
8 reducing the post-processing steps, and enable seamless integration between the workforce  
9 management system and London Hydro's ERP systems.

10 Asset Management System

11 This project will implement a centralized and computerized Asset Management System that  
12 London Hydro currently lacks. London Hydro utilizes multiple disparate databases and  
13 spreadsheets to track assets, which can lead to lost material and inefficient tracking. With a  
14 robust, automated Asset Management System, London Hydro aims to identify and track  
15 changes regarding the location of assets, the increase or decrease in the number of assets,  
16 assignment status and user information. This project will enhance both efficiency and reliability  
17 as it will capture the complete lifecycle of all major assets, which will result in detailed and  
18 accurate asset reporting and alerting and a decrease in missing inventory, and also automate  
19 and consolidate London Hydro's EIAM process. See Exhibit 4, Section "London Hydro's  
20 Electrical Inspection and Maintenance Program ("EIAM"), for more information.

21 Commercial & Industrial Apps

22 This project will be a continuation of London Hydro's effort to provide advanced customer  
23 engagement solutions to commercial customers to improve their energy forecasts and facilitate  
24 energy conservation. Leveraging the initial success of London Hydro's Interval Data Centre  
25 (IDC) and Event Assist (EA) solutions, London Hydro will continue to roll out enhancements that  
26 have been identified and prioritized by our customers.

27 SAP Enhancements

28 The SAP Enhancements project aims to continue leveraging the value of SAP investments to  
29 date by enabling new business processes and enhancing and optimizing existing business



1 processes using the technology available in the existing system deployments. This project will  
2 be comprised of several sub-projects addressing specific objectives on a per-department basis.  
3 Implementation decisions for new discretionary SAP enhancements will typically be based on  
4 either a direct business value (e.g. business process simplification) or an indirect benefit (e.g.  
5 improving the customer experience through backend system enhancements).

#### 6 Green Button

7 London Hydro plans to enhance its Green Button platform with the latest version of the  
8 published standards. It is expected that enhancements will deliver additional functionality for  
9 customers using the Green Button Standard and thereby enhance customer value. London  
10 Hydro has championed the Green Button initiative across North America and has been at the  
11 forefront in the development of the standard. Under this initiative, London Hydro will continue to  
12 develop applications that will take advantage of the Green Button platform and continue to  
13 provide support to third party vendors for developing customer-focused applications to help  
14 customers reduce their energy consumption.

#### 15 Analytics System Phase 2

16 Phase 2 of this project will be a continuation of Analytics Systems implementation that will  
17 enable more effective use of interval and smart meter data in conjunction with grid connectivity  
18 and billing data using "big data" technologies. This functionality will support improved  
19 distribution system planning processes and enable the development of analytical processes that  
20 can provide more context to customers with respect to their individual energy usage. This  
21 project will realize the following benefits:

- 22 • Facilitate executives and senior managers to see critical data presented in a highly  
23 visual and engaging manner, such as customer service data (problem resolution and  
24 customer satisfaction statistics), credit and collection bad payments by month,  
25 metering disconnection, reconnection orders, and billing - monthly rebills
- 26 • Provide tactical dashboards and reports for:



- 1                   ○ Balance analysis
- 2                   ○ Profitability analysis
- 3                   ○ Product development
- 4                   ○ Flexible Portfolio analysis
- 5                   ○ Demand side management
- 6                   ○ Energy settlement
- 7                   ○ Unbilled revenue
  
- 8                   ● Provide self-service BI with Web Intelligence – Business user autonomy from
- 9                   IT/power users
- 10                  ● Generate reports from multiple data sources – Ease of report creation, broad
- 11                   adoption with simple user experience

## 12 *2017 New System Projects*

### 13 Automated Billing Payments

14 This project will involve the design and implementation of a feature that addresses customer  
15 requests for an automated billing and payment option. Currently London Hydro does not offer  
16 such an option for customers to make online payments directly from their MyAccount service  
17 provided in the MyLondonHydro portal. As a result of this project, London Hydro customers will  
18 have a convenient method of making secure payments via web and IVR channels, and be able  
19 to make payments with an Interactive Voice Response (IVR) option. This project is focused on  
20 increasing customer satisfaction. This enhancement will also improve London Hydro's efficiency  
21 as time and costs associated with manual cheque processing will be reduced.

### 22 Residential Customer Mobile Application

23 This project will involve building and deploying a mobile application aimed at improved and  
24 varied communications with the residential customer. As the shift towards smartphones and  
25 tablets intensifies, London Hydro wants to give its customers more control over where, when  
26 and how they engage with the utility.

27 Under this project, London Hydro will develop a customer-facing mobile application that will  
28 encourage greater customer engagement through gamification, and it will be designed keeping  
29 the individual customer needs in mind. This application will have innovative features such as  
30 instant complaint registration (the ability to register a complaint, such as a broken line, by simply



1 clicking a picture), location-based outage notifications, billing alerts, online chat etc. This project  
2 will increase customer engagement by providing a feature-rich mobile application that will be  
3 intuitive and user-friendly.

4 This application will enable greater user interaction since it will reach customers on their most  
5 used devices. Due to instant customer feedback, London Hydro will be able to address any  
6 safety-related complaints quickly. By putting control of electricity usage into the hands of  
7 customers, London Hydro expects to help them reduce energy consumption.

#### 8 JDE Upgrade

9 As part of London Hydro's ERP Strategy (see Exhibit 4, Appendix 4-1 for details), London Hydro  
10 will upgrade its JD Edwards system to a more current version.

11 London Hydro implemented JDE for its Finance and other ERP functions in 2004. Since then,  
12 London Hydro has not upgraded JDE or replaced it with a new platform. London Hydro's current  
13 JDE system is no longer supported by the vendor, and it has become very difficult to include  
14 any new business processes into the current system. Therefore, London Hydro has decided to  
15 upgrade JDE to its latest version and thereby mitigate the risks associated with an unsupported  
16 and obsolete system.

17 For this upgrade, London hydro aims to maintain the existing functional scope while moving to  
18 an IAAS (public cloud) infrastructure model with hybrid application support (in-house  
19 supplemented by external resource augmentation).

20 In addition, this upgrade will provide London Hydro with an opportunity to take advantage of the  
21 new functionalities such as job costing, vehicle preventive maintenance and warehouse bar-  
22 code integration offered under the latest version of JDE to further improve efficiencies.



## 1 Capital Spending by DSP Investment Category

2 Pursuant to the OEB Chapter 5 Distribution System Plan Filing Requirements, London Hydro  
 3 has submitted its Distribution System Plan as a component of this Rate Application (See  
 4 Appendix 2-6).

5 Table 2-42 below categorizes London Hydro's capital spending into 5 investment categories:  
 6 System Access, System Renewal, System Service, General Plant and Other. Additionally, this  
 7 table reconciles the total of these categories to the total capital spending in Table 2-16 (Page  
 8 42). This reconciliation confirms that all capital spending documented in this Application has  
 9 also been documented in the DSP.

10 **Table 2-42 – Capital Spending by DSP Investment Category 2012 - 2017**

CAPITAL SPENDING 2012 - 2017 SUMMARY BY OEB CHAPTER 5 GROUPING							
Annual Spending Summary by Grouping	2012 Actual	2013 Actual	2013 Board Approved	2014 Actual	2015 Actual	2016 Bridge	2017 Test
	\$	\$	\$	\$	\$	\$	\$
System Access	7,077,665	6,038,038	6,111,400	7,419,807	8,966,380	7,893,000	8,441,000
System Renewal	10,866,993	10,869,290	11,673,000	11,740,647	13,786,694	14,849,000	14,319,000
System Service	1,948,635	1,625,550	1,774,000	1,476,143	1,248,710	975,000	895,000
General Plant	8,666,600	8,935,351	8,295,000	6,763,153	9,741,642	10,002,000	8,920,000
Other	(787,340)	241,807	-	(450,497)	757,661	-	-
	<b>27,772,554</b>	<b>27,710,036</b>	<b>27,853,400</b>	<b>26,949,253</b>	<b>34,501,087</b>	<b>33,719,000</b>	<b>32,575,000</b>
Capital Contributions	(3,780,997)	(2,418,672)	(2,700,000)	(1,870,692)	(3,788,551)	(2,087,000)	(2,101,000)
<b>Total</b>	<b>23,991,557</b>	<b>25,291,364</b>	<b>25,153,400</b>	<b>25,078,561</b>	<b>30,712,535</b>	<b>31,632,000</b>	<b>30,474,000</b>

11  
 12 The 'Other' line above contains "Inventory held for capital projects", which represents spending  
 13 on capital-related inventory items such as transformers that have been purchased but not yet  
 14 assigned to a specific capital job, as well as the "CGAAP to MIFRS Burden Adjustment"  
 15 amount, which refers to the 1576 IFRS-GAAP Transitional PP&E Amounts that were discussed  
 16 fully in London Hydro's 2013 Cost of Service Rate Application.



## 1 Capitalization Policy

2 A copy of London Hydro's capitalization policy can be found in Appendix 2-2, at the end of this  
3 Exhibit. No significant changes have been made to the policy since the 2013 rebasing.

### 4 *Overview*

5 As of January 1, 2015, London Hydro follows International Financial Accounting Standards  
6 (IFRS). Effective January 1, 2012, following a detailed review of the useful lives analysis  
7 conducted by Kinetrics, London Hydro implemented certain changes in accounting estimates  
8 related to useful lives of certain assets. Although London Hydro deferred its adoption to IFRS  
9 until January 1, 2015, it was determined that these changes needed to be applied under  
10 CGAAP as additional and more relevant information had been made available.

### 11 *Recognition*

12 An item of Property, Plant and Equipment (PP&E), or an intangible asset, is recognized as a  
13 capital asset if and only if,

- 14 1. it is probable that *future economic benefits* associated with the asset will flow to the  
15 Company,
- 16 2. the cost of the item can be measured reliably and
- 17 3. expenditures incurred will provide benefits lasting beyond one year.

18 Expenditures incurred to improve (betterment) an existing asset will be capitalized if it is  
19 probable that future economic benefits will flow to the Company.

20 Expenditures for repairs and/or maintenance designed to maintain an asset in its original state  
21 are not capital expenditures and should be charged to an operating account.

### 22 *Measurement*

23 Whether capital assets are purchased or constructed by the Company, they are stated at cost  
24 and include expenditures that are directly attributable to bringing the asset to the location and  
25 condition necessary for it to be capable of operating in the manner intended.

26 The cost of self-constructed assets includes direct materials, initial delivery and assembly,  
27 labour, employee benefits, professional fees and any other costs directly attributable to bringing



1 the asset to a working condition for its intended use. Other costs could include expenditures  
2 directly attributable to the asset from engineering, overheads, contracted services, and interest  
3 or borrowing costs.

4 Costs that are not included in the cost of an item of PP&E include training costs, administration  
5 and other general overhead costs, feasibility studies conducted prior to project approval.

#### 6 *Depreciation*

7 Depreciation is discussed in full in Exhibit 4, Section 'Depreciation and Amortization Expense',  
8 Page 379.

#### 9 *Derecognition (Retirements and Disposals)*

10 An item of PP&E or Intangibles will be removed from the capital assets on the balance sheet  
11 when it is taken out of service or abandoned where no future benefits are expected or when  
12 sold. The resulting loss equal to its net book value less disposal costs will be recognized in profit  
13 and loss. In the case of a sale of an item of PP&E or Intangibles, gains and losses are  
14 determined by comparing the proceeds from the disposal with the net book value of the item  
15 disposed with the gain or loss recognized in profit or loss.

#### 16 *Impairments*

17 At the end of each annual reporting period, the Company assesses whether there is any  
18 indication that an asset may be impaired, and if so, determines and measures the impairment  
19 loss.

20 If there is an indication that an impairment loss on assets exists, the recoverable amount is  
21 estimated. The impairment loss is the amount by which the asset's carrying amount or net book  
22 value exceeds its recoverable amount. The impairment loss is recognized in profit or loss.

#### 23 *Betterment*

24 Expenditures for betterments are capitalized if the capital asset will provide future economic  
25 benefit to the Company.

26





1 *Materiality Limits*

2 All expenditures for capital assets are subject to materiality limits.

3 While an expenditure might meet the definition to qualify as a capital asset, a materiality limit  
4 has been established to minimize the cost disadvantages where administration costs of  
5 capitalizing an asset may outweigh the intended benefits.

6 *Componentization of Assets*

7 For each part of an item of PP&E with a cost that is significant in relation to the total cost of the  
8 item, the item shall be depreciated separately.

9 A significant part of an item of PP&E may have a useful life and a depreciation method that are  
10 the same as the useful life and the depreciation method of another part of the same item. Such  
11 parts may be grouped in determining the depreciation charge.

12 *Interest or Borrowing Costs*

13 Borrowing costs that are directly attributable to the construction or acquisition of qualifying  
14 assets are capitalized as part of the cost of the asset. The OEB usually identifies borrowing  
15 costs that are capitalized as being Allowance for Funds Used in Construction (AFUDC). Only  
16 those assets with construction periods of over one year are to be considered for having their  
17 interest or borrowing costs capitalized.

18 *Replacement Parts*

19 The cost of replacing part of an item of PP&E is recognized in the carrying amount of the item if  
20 it is probable that the future incremental economic benefits embodied within the part will flow to  
21 the Company and its costs can be measured reliability. The carrying amount of the replaced  
22 part is derecognized.

23 *Capital Spares*

24 Spare parts and stand-by equipment are considered PP&E when the Company expects to use  
25 them during more than one period (year). Therefore, spare transformers and meters and other  
26 such items of PP&E that are applicable to this guidance, are accounted for as an item of PP&E  
27 as they are: i) not intended for resale, ii) have a longer period of future benefit as compared to

1 inventory items, iii) form an integral part of the original distribution plant by enhancing reliability  
2 of the original distribution plant, and iv) provide future benefits because they are expected to be  
3 placed in service.

4 Spare parts commence to be amortized when the spare part is available for use (rather than put  
5 to use).

#### 6 *Contributed Capital*

7 Certain assets may be acquired or constructed with financial assistance in the form of  
8 contribution from customers or developers.

9 Capital contributions received are treated as a liability on the balance sheet.

10 Amortization of the deferred customer contributions is calculated over the average life span of  
11 the related assets and, if necessary, would be adjusted to reflect any changes in the remaining  
12 useful lives of the underlying capital assets.

13 Amounts that are amortized are to be recorded as a charge to the revenue deferral account and  
14 a credit to the revenue account. For the purposes of reporting to the OEB, contributed capital is  
15 considered to be recorded as a capital account (as a credit to the asset contra account).

#### 16 *London Hydro Contributions to PP&E not Owned by London Hydro*

17 Contributions to PP&E made by London Hydro, where ownership is not realized by London  
18 Hydro, should be classified as an intangible asset. The contribution is a resource that is  
19 controlled by the entity as a result of asset purchase or self-creation and from which future  
20 economic benefits (inflows of cash or other assets) are expected.

#### 21 *Computer Software Expenditures*

22 Computer software expenditures are to be classified as an intangible asset if it is probable that  
23 the expected future economic benefits attributable to it will flow to the entity. Only major  
24 application software projects with total “acquisition and enhancement expenditures” in excess of  
25 the established materiality limit and with an expected future life exceeding two years are  
26 capitalized. All other software expenditures are charged to operations as incurred.

## 1 Capitalization of Overhead

2 London Hydro capitalizes three types of overhead expenses: Employee Benefits, the Fleet  
3 Department, and the Materials Management Department.

### 4 *Employee Benefits*

5 Employee benefit costs can be broken down into three groupings: Statutory (such as CPP, EI,  
6 EHT, WSIB), Active Employees (such as OMERS, health, dental, life insurance, long-term  
7 disability insurance, pension contributions) and Retired Employees (such as life insurance  
8 premiums, employee future benefit costs).

9 Total benefit costs are allocated amongst OM&A, capital and billable jobs, based on actual  
10 labour hours, by applying benefit rates. These rates are derived by comparing the relationship  
11 between estimated total benefits and estimated total base salaries for the year and calculating  
12 an appropriate percentage to ensure all benefit costs are accounted for.

13 London Hydro's fully burdened rate for full-time employees is 63.75%. This rate accounts for  
14 both the benefit costs mentioned above, as well as a factor for non-productive time (vacation,  
15 sick, etc.). This method ensures all employee-related benefits culminate in the proper  
16 OM&A/capital accounts, based on direct labour hours. See Table 2-43 below for complete  
17 information on various allocation rates.

### 18 *Fleet Department*

19 Fleet Department costs include labour, materials, fuel, repairs, vehicle depreciation, and other  
20 costs associated with maintaining London Hydro's fleet of vehicles and equipment. Hourly fleet  
21 burden rates are based on vehicle/equipment type and reviewed annually. Rates are calculated  
22 using an estimation of annual costs and usage per type of vehicle/equipment. These rates are  
23 allocated to capital and billable jobs based on actual vehicle/equipment usage, which is tracked  
24 by employee via timesheet. Fleet costs are also allocated to various OM&A Departments based  
25 on vehicle availability. For example, a vehicle designated for the Health and Safety Department  
26 would be allocated 40 hours/week of fleet burden, based on the respective vehicle's  
27 predetermined rate.



1 *Materials Management Department*

2 Materials Management Department costs to be allocated include labour and benefits of the  
3 employees who monitor inventory, issue materials and supplies, and oversee this department.  
4 Non-capital allocations also include administrative costs such as telephone equipment and  
5 office supplies. Costs are allocated using pre-determined allocation rates, based on type of  
6 project and type of material. Allocation rates to capital are lower than non-capital due to IFRS  
7 restrictions regarding costs being directly attributable to bringing an asset to the location and  
8 condition necessary for it to operate in the manner intended by management. Table 2-43 below  
9 lists all London Hydro's allocation rates.

10 **Table 2-43 – Allocation Rates\*\***

<b>LONDON HYDRO INC. COST ALLOCATION RATES</b>	
<b>Burden Type</b>	<b>Rate</b>
<b>Labour</b>	
Full-Time	63.75%
Part-Time	22.0%
<b>Materials Management</b>	
Items >\$1k and cable/wire	
Capital	4.0%
Non-Capital	7.0%
Items <\$1k and non cable/wire	
Capital	5.0%
Non-Capital	16.0%

11  
12 \*\*Fleet rates not included above; allocated using flat rate per vehicle type, not percentage allocation

13 Rates are assessed annually for appropriateness and adjusted if necessary. Burden rates have  
14 not changed since the London Hydro's last Cost of Service Rate Application in 2013, other than  
15 small fluctuations based on projected budgets and usage rates.



1 **Costs of Eligible Investments for the Connection of Qualifying Generation**  
2 **Facilities**

3 There is significant renewable generation activity across London Hydro's distribution system. As  
4 of June 30, 2016, London Hydro has connected one RESOP project with 2.85MW and 41 active  
5 renewable FIT generation projects with a total nameplate capacity of 8,125kW.

6 London Hydro does not expect any capital expenditures related to REG in its DSP. There are no  
7 additional OM&A costs related to REG facilities as London Hydro is able to process both  
8 microFIT and FIT applications utilizing existing employees. Therefore, London Hydro does not  
9 require recovering costs incurred to make eligible investments as described in Section 79.1 of  
10 the Act and O. Reg. 330/09 under the Act.

11 Since London Hydro does not expected any capital expenditures related to REG, London Hydro  
12 has not completed nor filed Appendix 2-FA to Appendix 2-FC.



1 **Addition of Previously Approved ACM and ICM Project Assets to Rate**  
2 **Base**

3 London Hydro has not applied for an Incremental Capital Module between the last COS year  
4 (2013) and the current Test Year. Therefore, London Hydro is not requesting any ICM capital  
5 asset amounts to be incorporated into its rate base.

## 1 **New Policy Options for the Funding of Capital - Advance Capital Module**

### 2 **Overview**

3 On September 18, 2014, the OEB issued the *Report of the Board - New Policy Options for the*  
4 *Funding of Capital Investments: The Advanced Capital Module (EB-2014-0219)* (the ACM  
5 Report). The Advanced Capital Module (ACM) reflects an evolution of the Incremental Capital  
6 Module (ICM) adopted by the OEB in 2008.

7 The ACM expands the ICM concept to incorporate the concept of recovery for qualifying  
8 incremental capital investments during the Price Cap IR period with an opportunity to identify  
9 and pre-test such discrete capital projects documented in the DSP as part of the cost of service  
10 application.

11 As part of a cost of service application, a distributor may propose qualifying ACM capital  
12 projects that are expected to come into service during the subsequent Price Cap IR term.  
13 These will be discrete projects as documented in the DSP. The distributor must also identify  
14 that it is proposing ACM treatment for these future projects, and provide the cost information  
15 and ACM/ICM materiality threshold calculations to show that these would qualify for ACM  
16 treatment based on the forecasted information at the time of the DSP and cost of service  
17 application. The ACM Report provides further details on the information required. A distributor  
18 applying for an ACM must file the completed spreadsheet: Capital Module Applicable to ACM  
19 and ICM.

20 The timing and actual amount of the rate riders used to recover the costs of qualifying ACM  
21 projects in the subsequent Price Cap IR period will not be determined in the cost of service  
22 application. This determination will be made in the Price Cap IR application for the year in  
23 which the capital investment will be made and the project comes into service. At that time, the  
24 distributor must file updated information on the forecasted costs and demonstrate that the  
25 capital project still qualifies for incremental capital funding and recovery. However, the nature  
26 and need for the project will be determined as part of the DSP during the cost of service  
27 application.

28 On January 22, 2016, the OEB issued the *Report of the OEB - New Policy Options for the*  
29 *Funding of Capital Investments: Supplemental Report (EB-2014-0219)*. This report made

1 changes to the materiality threshold on which both ICM and ACM proposals are assessed, but  
2 otherwise does not alter the requirements for ACM and ICM proposals by an applicant. The  
3 Supplemental Report also reaffirms the applicability of the half-year rule for determining the  
4 return on capital in the first year that assets enter service.

5 Consistent with the OEB Minimum Filing Requirements issued on July 14, 2016, London Hydro  
6 has completed the OEB model 2017\_Capital\_Module\_ACM\_Model as found on the OEB  
7 website. PDF copies of the model can be found in Exhibit 2 Tab 3 Schedule 1 Appendix 2-4, as  
8 well the live excel version submitted with this application.

### 9 **ACM Criteria**

10 An ACM is available to distributors during the Price Cap IR years for capital investment needs  
11 that are additional to those approved through the last cost of service application.

12 Capital projects included in an ACM request must meet three criteria:

13 **Materiality** – each incremental capital project or expenditure must be material and clearly  
14 have a significant influence on the operation of the distributor,

15 **Need** – distributor must pass the Means Test; amounts must be based on discrete projects  
16 and directly related to the claimed driver, and must be clearly outside of the base upon  
17 which the rates were derived, and

18 **Prudence** – amounts to be incurred must be prudent.

19 In addition to the criterion that each project included in the ACM request be material, the total  
20 ACM request must exceed the ACM materiality threshold.

### 21 **Project Materiality**

22 Each capital project approved for ACM funding must be material to the distributor. Project  
23 materiality is 0.5% of distribution revenue requirement for distributors with a revenue  
24 requirement greater than \$10 million and less than or equal to \$200 million. London Hydro's  
25 requested distribution revenue requirement is \$73.0 M resulting in a project materiality of  
26 \$365,000. See Exhibit 1 Tab 10 Schedule 1 for calculation.



1 **Need and the Means Test**

2 As part of the criterion of need, the OEB applies the Means Test when reviewing ACM  
3 applications. The Means Test states that if a distributor's regulated return exceeds 300 basis  
4 points above the deemed regulatory return on equity (ROE) embedded in its rates, the funding  
5 for any incremental capital project will not be allowed. London Hydro submits it is herein  
6 requesting an adjustment to its regulatory ROE to 9.19% and has not, at any time, exceeded its  
7 scorecard ROE deemed equity by the dead band of 300 basis points over the last many years.

8 **Prudence**

9 To be eligible for ACM funding, expenditures must be prudent, illustrating good judgement in the  
10 management of capital budgets. London Hydro is confident that the OEB will find that the  
11 proposed projects are prudent as described in the presentation of details below.

12 **ACM Materiality Threshold**

13 The OEB expects a distributor to fund its capital expenditures within the ACM materiality  
14 threshold, before being eligible to apply for ACM funding. The ACM materiality threshold is  
15 deducted from the total ACM request to determine the amount eligible to be recovered from  
16 customers.

17 The OEB has defined the ACM materiality threshold in Chapter 3 of the *Filing Requirements for*  
18 *Electricity Distribution Rate Applications* (the Filing Requirements). It represents a distributor's  
19 financial capacities underpinned by existing rates, including growth and a 20% dead band. The  
20 equation used to calculate the materiality threshold at the time of London Hydro's application is  
21 as follows:

22 
$$\text{Materiality Threshold Value} = 1 + (\text{RB}/d) * (g + \text{PCI} * (1 + g)) + 20\%$$

23 Where:

24 RB = rate base included in base rates (\$)

25 d = depreciation expense included in base rates (\$)

26 g = distribution revenue change from load growth (%)

27 PCI = price cap index

28 London Hydro has calculated its preliminary materiality threshold value to be 136%, which is  
29 multiplied by the last approved annual depreciation of \$17.9M to determine the ACM threshold



1 of \$24.4M for 2018 as calculated on Sheet 9. Threshold Test of the OEB model  
 2 2017\_Capital\_Module\_ACM\_Model and shown in Table 2.2.6.1 below.

3 **Table 2.2.6.1 – Results from Preliminary Threshold Calculation**

**Depreciation** \$ 17,984,944 *d*

**Threshold Value (varies by Price Cap IR Year subsequent to CoS rebasing)**

Price Cap IR Year 2018	136%
Price Cap IR Year 2019	136%
Price Cap IR Year 2020	136%
Price Cap IR Year 2021	137%

**Threshold CAPEX**

*Threshold Value × d*

Price Cap IR Year 2018	\$ 24,378,972
Price Cap IR Year 2019	\$ 24,448,961
Price Cap IR Year 2020	\$ 24,520,016
Price Cap IR Year 2021	\$ 24,592,153

4

5

6 **Table 2.2.6.2 – Maximum Eligible Incremental Capital (Forecasted Capex less Threshold)**

	Cost of Service	Price Cap IR			
	Test Year 2017	Year 1 2018	Year 2 2019	Year 3 2020	Year 4 2021
Distribution System Plan CAPEX	\$ 32,575,000	\$ 35,717,000	\$ 32,959,000	\$ 33,893,000	\$ 33,807,000
Materiality Threshold		\$ 24,378,972	\$ 24,448,961	\$ 24,520,016	\$ 24,592,153
Maximum Eligible Incremental Capital (Forecasted CAPEX less Threshold)		\$ 11,338,028	\$ 8,510,039	\$ 9,372,984	\$ 9,214,847
Maximum Eligible Incremental Capital (Forecasted Capex less Threshold)		\$ 11,338,028	\$ 8,510,039	\$ 9,372,984	\$ 9,214,847

7

8



1 **Proposed Projects**

2 **Table 2.2.6.3 – Proposed Capital Projects Eligible for ACM Treatment**

Project Descriptions:	Cost of Service	Price Cap IR				Total
	Test Year 2017	Year 1 2018	Year 2 2019	Year 3 2020	Year 4 2021	
Nelson TS Capital Contribution		\$ 7,165,590			\$ 1,450,000	\$ 8,615,590
JD Edwards		\$ 2,000,000				\$ 2,000,000
HONI CCRA True-up's Talbot and Buchanan		\$ 1,000,000				\$ 1,000,000
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
<b>Maximum Allowed Incremental Capital</b>		\$ 10,165,590	\$ -	\$ -	\$ 1,450,000	

4 **Nelson TS Capital Contribution**

5 The decision to convert Nelson TS from 13.8 kV to 27.6 kV was based on a collaborative  
 6 approach to long term supply options for the City of London, conducted by London Hydro and  
 7 Hydro One (Ontario Hydro). The planning started in the early 1980's with the installation of the  
 8 Talbot TS (near downtown), which provided 27.6 kV supply to the north side of downtown. At  
 9 that time, 27.6 kV had become the standard distribution voltage for most of Ontario, including  
 10 much of the City of London outside the downtown core. The Nelson TS was one of the oldest  
 11 transformer stations in London and had several non-standard designs that made it more  
 12 vulnerable to some contingencies. The only other 13.8 kV supply point was at Highbury TS to  
 13 the east, which was approaching end of life and was in need of replacement.

14 In 1990, London Hydro and Hydro One agreed that new connections would be made only to the  
 15 27.6 kV supply (if possible) and existing 13.8 kV load would be reduced over time. With much  
 16 of the 13.8 kV distribution system approaching end of life, reduction of the 13.8 kV load  
 17 proceeded at a gradual pace.

18 By 1999, the 13.8 kV station at Highbury TS was decommissioned, which left the Nelson TS as  
 19 the sole supply of 13.8 kV for London's downtown core.



1 In 2005/2006, joint planning meetings with Hydro One examined supply options and needs for  
2 the City of London, with the Nelson TS identified as the preferred location for new supply. In  
3 subsequent years, different scenarios were reviewed and issues at the 13.8 kV Nelson TS  
4 surfaced, which made conversion to 27.6 kV more desirable. Between 2009 and 2014, Hydro  
5 One and London Hydro examined the cost and benefits of keeping Nelson at 13.8 kV or  
6 converting it to 27.6 kV.

7 During this time period, London Hydro met with the major customers impacted by the proposed  
8 conversion from 13.8 kV to 27.6 kV to address concerns and to educate them on the changing  
9 system. A large number of these customers also have equipment that is aging and approaching  
10 end of life. Several customers had electrical supplies with no spare transformers or they did not  
11 have a restoration plan and were pleased to discuss options with London Hydro. Two  
12 government building managers were supportive of a supply from a system that would provide  
13 alternate sources with SCADA control. Larger customers understood that if they were not in a  
14 position to convert, then the short term solution would be to leverage a step down substation.  
15 Two significant customers have an internal supply arrangement that existed before their building  
16 was subdivided and would like to move to a standard utility supply. Based on discussions with  
17 London Hydro, several of the larger customers that had to replace transformers or switchgear  
18 have since installed equipment that will support 27.6kV in the future.

19 In early 2015, an agreement was reached whereby Hydro One would rebuild Nelson TS at 27.6  
20 kV and London Hydro would be responsible for only the incremental cost of conversion. The  
21 terms of the agreement were documented in a CCRA which includes the following payment  
22 schedule:

23	June 15, 2015	\$1.6M plus HST
24	March 15, 2016	\$1.75M plus HST
25	March 15, 2017	\$1.75M plus HST
26	March 15, 2018	\$1.75M plus HST

27 The 27.6 kV portion of the rebuilt Nelson TS will be "ready for service" by December 15, 2018.

28 A final reconciliation payment of \$1.45M plus HST is expected March 15, 2021 at which time the  
29 final 13.8 kV supply portion of the Nelson TS will be fully decommissioned.



1 London Hydro has documented this decision making process in a report entitled, “*London*  
2 *Downtown - 13.8kV/27.6kV - Nelson TS - 5 Year Plan – February 2015*”, which is included in  
3 DSP Appendix J. In addition, the plan to convert the 13.8 kV distribution system and to  
4 accommodate future connections has been documented in the report entitled, “*Downtown*  
5 *Intensification – December 2015*”, which is also included in DSP Appendix J. These two reports  
6 provide a comprehensive review of the work needed in the downtown core to continue to  
7 provide safe and reliable supply for the foreseeable future.

## 8 **JD Edwards**

9 London Hydro’s current JD Edwards financial accounting system, the Company’s financial  
10 reporting tool (Insight Reporting) and a Cloud-based platform used for sharing knowledge and  
11 information with the Board of Directors has been determined to be at end of life and in need of  
12 replacement. London Hydro is proposing to move the legacy JD Edwards financial accounting  
13 system from an on-premise solution to a Cloud-based solution. The timing for this conversion is  
14 to be in 2018. For the purposes of the ACM, London Hydro is currently estimating that it will  
15 incur software development capital costs of \$2.0M leading up to the planned system activation  
16 in 2018.

17 The current financial system was implemented in 2004 and has now exceeded its end of life.  
18 Over the last several years, plans for upgrading the accounting system have been postponed to  
19 allow for attention to more urgent matters including the implementation of the SAP Customer  
20 Information System and Smart Meters, the transition to HST, the conversion to IFRS, as well as  
21 the completion of this rate application. In addition, the Finance division has experienced the  
22 retirement of 3 key management personnel since the last cost of Service in 2013. London  
23 Hydro has therefore determined that an upgrade will be planned to commence in 2017 and be  
24 implemented in 2018.

25 As the 2004 financial system was deemed to be essentially running on borrowed time and with  
26 the view to reducing costs, London Hydro chose to cease payments for Oracle maintenance  
27 and support services in 2011. Since 2011, London Hydro has been utilizing third-party support  
28 services which has provided for cost savings in excess of \$40,000 annually. However, as a  
29 result of the upgrade, those Oracle maintenance and support services will be reinstated.

1 In 2014, London Hydro initiated a cost-benefit analysis on the various options available (for  
2 example, JDE vs. SAP, on premise vs. the Cloud). Ernst and Young (“E&Y”) was engaged to  
3 conduct an “ERP Needs Assessment and Scoping” study in the spring of 2014 and an  
4 “Evaluation of JDE Upgrade and Deployment Options” in the summer of 2016 to analyze  
5 benefits fulfillment, total cost of ownership and risk factors for a number of options.

6 The resulting E&Y recommendation is that London Hydro select a strategy of continuing on with  
7 JD Edwards and adding on external applications (“point solutions”) for certain modules such as  
8 the Human Resources Information System (“HRIS”). A copy of the E&Y studies can be found In  
9 Exhibit 4 Appendix 4-1 of this application. It should be noted that E&Y has included the ERP  
10 Needs Assessment and Scoping study performed in 2014 as Appendix 3 in their attached study  
11 labeled Evaluation of JDE and Upgrade and Deployment Options which was performed in 2016.

#### 12 **HONI CCRA True-up Talbot and Buchanan**

13 London Hydro and Hydro One entered into a Connection and Cost Recovery Agreement  
14 (CCRA) on January 26, 2006 for the construction of a second 230-28kV transformer station  
15 “Talbot TS #2” and for the provision of four new feeder breaker positions at Buchanan TS.  
16 Talbot TS #2 and the Buchanan feeder breakers went into service by end of December 2007.

17 For the first True-Up (January 2007 to December 2011), a revised CCRA reflecting actual costs  
18 of the project was not received (however, actual costs with agreed to overage amounts were  
19 provided) and guidelines for incorporating CDM and DG, as required in the Transmission  
20 System Code (TSC) in the True-Up evaluation was not available. Nonetheless, London Hydro  
21 provided their True-Up calculations based on actual historical loads, forecasted loads, CDM/DG  
22 contributions in accordance with the TSC as interpreted by London Hydro. The analysis was  
23 performed using the actual project costs received via email from Hydro One in 2011.

24 At the time of submission of London Hydro’s first True-Up calculations, Hydro One disputed the  
25 inclusion of CDM/DG in the True-Up analysis. On September 17, 2015, Hydro One provided  
26 newly developed guidelines on accounting for CDM and DG for the True-Up evaluations and a  
27 revised CCRA including actual costs significantly larger than previously stated. London Hydro  
28 and Hydro One met on April 19, 2016 to review outstanding items required to complete the first  
29 True-Up analysis. Discussions between Hydro One and London Hydro are still ongoing and  
30 main items of discussion include the following subjects: the actual cost of Talbot TS #2



1 (\$14,129,894 vs \$15,078,000), Transformation Connection Charge Rate (fixed \$1.50/kW/month  
2 rate vs. actual increasing rate since agreement), and the surplus/shortfall parameter for  
3 evaluation (MW of load vs actual net present value of revenue collected). The second True-Up  
4 analysis covers the period of January 2012 to December 2016.

5 As discussed in the Enersource Decision and Rate Order EB-2015-0065 dated April 7, 2016 the  
6 Transmission System Code (TSC) sets out cost responsibility principles for construction or  
7 modification of transmission facilities. It states that load customers shall contribute capital to a  
8 transmitter to cover the cost of a facility required to meet their needs where the cost of the  
9 facility is not recoverable through revenues. The TSC also requires a transmitter to carry out a  
10 true-up calculation, based on actual customer load, for low risk projects, every five years. This  
11 ensures that the customer – rather than the transmitter – bears the risk of the investment. This  
12 is also set out in the Connection and Cost Recovery Agreement between the transmitter and the  
13 distributor.

14 In this case, London Hydro is Hydro One's customer. Based on internal estimates, London  
15 Hydro is estimating amounts for the two True-Up Periods which need to be resolved with Hydro  
16 One as follows:

17 First Period, Year Ending 2011, Estimated Payment = \$0

18 Second Period, Year Ending 2016, Estimated Payment = \$0 to \$500,000

19 London Hydro is conservatively place-holding an estimated payment in the amount of \$1.0M,  
20 subject to final outcome of HONI negotiations.

## 1 **Service Quality and Reliability Performance**

2 London Hydro follows the Board's Reporting and Record Keeping Requirements Guideline to  
3 report its Service Quality Indicators annually. In accordance with the Filing Requirements the  
4 Board Appendix 2-G - Service Quality Indicators is included in Exhibit 2 Tab 3 Schedule 1  
5 Appendix 2-5 of this Exhibit. The table provides the performance measurements for the last five  
6 historical years 2011 through 2015. London Hydro confirms that the data values presented  
7 herein are consistent with our scorecard.

8 London Hydro has consistently performed within the Board's range of acceptable performance  
9 over the previous five years and submits that no corrective action is required.

### 10 **Reliability Performance**

11 London Hydro tracks service reliability statistics SAIDI (System Average Interruption Duration  
12 Index) and SAIFI (System Average interruption Frequency Index) including and excluding loss  
13 of supply related incidents. In accordance with the OEB's Report of the Board (EB-2014-0189)  
14 Setting System Reliability Performance objectives, dated August 25, 2015, London Hydro has  
15 calculated in the tables below its baselines based on an average of the previous 5 years (2011-  
16 2015). The following tables show results for the past 5 years as well as the 5 Year historical  
17 average as determined in the OEB Appendix 2-G included in Exhibit 2 Tab 3 Schedule 1  
18 Appendix 2-5 of this Exhibit.

19 **Table 2.3.1.1 - Calculation of System Reliability Performance Baseline including Loss of**  
20 **Supply**

Index	Including outages caused by loss of supply				
	2011	2012	2013	2014	2015
<b>SAIDI</b>	1.860	0.900	1.020	1.110	1.060
<b>SAIFI</b>	2.360	1.420	1.380	1.620	1.370

#### 5 Year Historical Average

<b>SAIDI</b>		1.190
<b>SAIFI</b>		1.630



1 **Table 2.3.1.2 - Calculation of System Reliability Performance Baseline excluding Loss of**  
 2 **Supply**

Index	Excluding outages caused by loss of supply				
	2011	2012	2013	2014	2015
SAIDI	1.670	0.890	0.990	0.980	1.040
SAIFI	2.140	1.300	1.240	1.210	1.220

3 **5 Year Historical Average**

SAIDI		1.114
SAIFI		1.422

4 **Table 2.3.1.3 - Calculation of System Reliability Performance Baseline excluding Major Event**  
 5 **Days**

Index	Excluding Major Event Days				
	2011	2012	2013	2014	2015
SAIDI	1.860	0.900	0.853	1.110	0.950
SAIFI	2.360	1.420	1.227	1.620	1.220

6 **5 Year Historical Average**

SAIDI		1.135
SAIFI		1.569

7 London Hydro notes that it has experienced two major event days during 2011 to 2015. On  
 8 September 11th 2013, a thunderstorm rolled through the City of London in the late afternoon  
 9 resulting in a large number of interruptions that lasted for a long duration. In total, that single  
 10 day accumulated over 1.5 million customer-minutes of interruptions and caused sustained  
 11 power interruptions to over 22,000 customers. Similarly, on June 23rd 2015, a severe lightning  
 12 storm hit the City of London after midnight resulting in a high frequency and duration of  
 13 interruptions. This storm resulted in over 1 million customer-minutes of interruptions and over  
 14 21,500 customers lost power.

15 London Hydro is committed to the reliability of the distribution system. Customers have  
 16 expressed overall satisfaction with the current level of reliability and a desire to keep rates low.  
 17 This combination of preferences has directed the development of London Hydro's Distribution  
 18 System Plan (DSP) and Asset Management Plan (AMP) to ensure spending on infrastructure is  
 19 optimized and targeted at portions of the distribution system most at risk of causing reliability to

1 deteriorate while keeping rates competitive within the industry. A portion of the spending in the  
 2 coming five years will be allocated to the supply to the downtown core and will address both the  
 3 long-term capacity requirements and the elimination of a significant reliability risk (single supply  
 4 point). In order to meet these targets London Hydro will need to continue to invest in capital and  
 5 maintenance programs. In particular, the capital programs noted in Exhibit 2 with a primary  
 6 driver of asset renewal are aimed at rebuilding infrastructure with a high probability of failure.  
 7 Renewal of these assets removes the risk to reliability and safety which would otherwise be  
 8 unacceptable.

9 **Service Quality**

10 In addition to the reliability indices, London Hydro also measures Electricity Service Quality  
 11 Requirements (ESQRs).

12 The following table summarizes London Hydro's reported ESQRs for the historical years 2011  
 13 thru 2015.

14 **Table 2.3.1.4 - Electricity Service Quality Requirements**

**Service Quality**

Indicator	OEB Minimum Standard	2011	2012	2013	2014	2015
Low Voltage Connections	90.0%	97.6%	96.8%	99.9%	100.0%	97.6%
High Voltage Connections	90.0%	100.0%	100.0%	100.0%	n/a	100.0%
Telephone Accessibility	65.0%	67.3%	68.3%	67.1%	65.9%	68.0%
Appointments Met	90.0%	99.5%	99.9%	99.9%	99.3%	100.0%
Written Response to Enquires	80.0%	100.0%	100.0%	100.0%	100.0%	100.0%
Emergency Urban Response	80.0%	100.0%	99.2%	98.1%	99.1%	100.0%
Emergency Rural Response	80.0%	n/a	n/a	n/a	n/a	n/a
Telephone Call Abandon Rate	10.0%	2.1%	2.1%	2.4%	3.2%	2.6%
Appointment Scheduling	90.0%	93.4%	97.5%	96.7%	95.3%	98.6%
Rescheduling a Missed Appointment	100.0%	100.0%	100.0%	100.0%	100.0%	n/a
Reconnection Performance Standard	85.0%	96.2%	98.3%	98.6%	99.1%	99.1%

15  
 16 Many of the above measures are discussed in greater depth in our Executive Summary (Exhibit  
 17 1 Tab 2 Schedule 1) and Performance Measurement (Exhibit 1 Tab 7 Schedule 1).

## Prescribed Tables Listing

---

As per the Filing Requirements, London Hydro has completed the required tables listed below in connection with rate base. To assist with navigation, the location of this information throughout the Application is provided as follows:

### Appendix 2-BA: Fixed Asset Continuity Schedules (2013 – 2017)

- Exhibit 2, Appendix 2-1, Tables 2-44, 2-45, 2-46, 2-47 and 2-48, pages 181-186
- 2016 Filing Requirements Chapter 2 Appendices (Excel workbook)

### Appendix 2-AB: Capital Expenditures

- 2016 Filing Requirements Chapter 2 Appendices (Excel workbook)

### Appendix 2-AA: Capital Projects Table

- 2016 Filing Requirements Chapter 2 Appendices (Excel workbook)

### Appendix 2-D: Overhead Costs

- 2016 Filing Requirements Chapter 2 Appendices (Excel workbook)

### Appendix 2-G: Service Reliability Indicators

- Exhibit 2, Appendix 2-4, page 251
- 2016 Filing Requirements Chapter 2 Appendices (Excel workbook)



*This page is intentionally left blank*



## **Appendix 2-1: Fixed Asset Continuity Schedules**

---



**Table 2-44 – 2013 Fixed Asset Continuity Schedule (OEB Appendix 2-BA)**

OEB Object	Description	Current CCA Class	Deprec Rate (Yrs)	Cost			Accumulated Depreciation			Net Book Value 31-Dec 2013		
				Balance 12/31/12	Additions	Adjustments / Disposals	Balance 12/31/13	Balance 12/31/12	Provision		Adjustments / Disposals	Balance 12/31/13
1805	Land	n/a	n/a	385,690	-	-	385,690	-	-	-	-	385,690
1612	Land Rights	CEC	25	364,045	2,189	-	366,233	164,137	16,759	-	180,897	185,337
1808	Buildings (Substations & Gagen)	47	30-75	1,128,336	-	-	1,128,336	702,365	11,093	-	713,458	414,877
1820	Equipment (Substations)	47	15-45	15,737,888	127,415	(34,820)	15,830,483	6,300,334	279,177	(34,820)	6,544,691	9,285,793
1610	Intangible Wholesale Meters	CEC	30	1,293,406	-	-	1,293,406	164,817	43,096	-	207,913	1,085,493
1830	Poles, Towers & Fixtures	47	45	38,369,731	1,368,435	-	39,738,167	18,561,593	571,117	-	19,132,710	20,605,457
1835	OH Conductors & Devices	47	45-50	53,161,202	1,975,643	-	55,136,846	21,596,621	790,092	-	22,386,713	32,750,133
1840	UG Conduit	47	30-60	33,594,419	2,158,405	(54,461)	35,698,363	9,032,304	505,992	(54,461)	9,483,834	26,214,529
1845	UG Conductors & Devices	47	25-40	110,187,258	3,367,053	(11,978,155)	101,576,155	62,817,472	3,895,648	(11,978,155)	54,734,965	46,841,190
1850	Transformers	47	35	75,704,254	3,928,409	-	79,632,662	29,214,449	1,768,803	(3,578)	30,979,674	48,652,988
1855	Services	47	30-60	22,721,712	1,999,222	-	24,720,934	7,563,950	485,325	-	8,049,275	16,671,659
1860	Electric Meters	8	15-30	24,670,246	832,303	(421,068)	25,081,481	6,991,958	1,397,374	(402,822)	7,986,510	17,094,971
1908	Buildings (General Plant Area)	1	12-65	23,890,273	434,952	(2,233,572)	22,091,652	11,726,201	866,806	(2,233,572)	10,359,435	11,732,218
1915	General Office	8	5	1,084,565	101,296	(454,002)	731,859	716,113	158,789	(454,002)	420,900	310,959
1920	Computer Equipment - Hardware	50	3	3,301,189	1,427,608	(1,528,471)	3,200,325	2,030,213	734,873	(1,528,471)	1,236,614	1,963,711
1611	Computer Software	12	3-5	25,594,826	4,770,971	(2,124,421)	28,241,375	11,306,525	4,867,907	(2,124,421)	14,050,010	14,191,365
1930	Transportation	10 & 38	8-12	10,845,192	1,140,047	(512,333)	11,472,907	6,140,525	620,730	(470,924)	6,290,330	5,182,576
1935	Stores Department	8	8	276,017	5,499	(3,378)	278,138	256,821	7,600	(3,378)	261,042	17,095
1940	Tools, Shop, Garage Equipment	8	8	1,247,265	112,143	(335,999)	1,023,409	729,160	129,401	(335,999)	522,561	500,848
1945	Meter Department	8	8	131,798	18,374	(30,559)	119,614	42,102	13,720	(30,559)	25,264	94,350
1950	Power Operated (Major) Equipment	38	8	877,841	53,630	-	931,471	328,312	106,171	-	434,483	496,988
1955	Communication Equipment	8	8-35	3,627,554	128,544	-	3,756,098	659,790	215,390	-	875,181	2,880,917
1960	Miscellaneous	8	8	-	-	-	-	-	-	-	-	-
1980	System Supervisory Equip (Scada)	47	10-20	3,465,859	239,274	(1,550,637)	2,154,497	2,089,939	124,593	(1,550,637)	663,896	1,490,601
1995	Contributed Capital	47	40	(36,843,371)	(2,418,672)	-	(39,262,043)	(7,752,231)	(864,118)	-	(8,616,349)	(30,645,694)
2440	Deferred Revenue	47	40	-	-	-	-	-	-	-	-	-
	<b>Total before Work In Progress</b>			<b>414,817,196</b>	<b>21,772,739</b>	<b>(21,261,877)</b>	<b>415,328,059</b>	<b>191,383,469</b>	<b>16,746,338</b>	<b>(21,205,799)</b>	<b>186,924,008</b>	<b>228,404,051</b>
2055	Work in progress			6,720,715	3,505,688	-	10,226,404	-	-	-	-	10,226,404
	<b>Total After Work In Progress</b>			<b>421,537,911</b>	<b>25,278,428</b>	<b>(21,261,877)</b>	<b>425,554,462</b>	<b>191,383,469</b>	<b>16,746,338</b>	<b>(21,205,799)</b>	<b>186,924,008</b>	<b>238,630,454</b>
2075	Renewable Generation	43.2	20	2,249,573	14,412	-	2,263,985	88,860	112,587	-	201,447	2,062,538
	<b>Total London Hydro Inc</b>			<b>423,787,484</b>	<b>25,292,840</b>	<b>(21,261,877)</b>	<b>427,818,447</b>	<b>191,472,329</b>	<b>16,858,925</b>	<b>(21,205,799)</b>	<b>187,125,455</b>	<b>240,692,992</b>
	Work in progress											(10,226,404)
	LH renewable generation								(112,587)			(2,062,538)
	Fully allocated vehicle depreciation								(726,900)			-
	Amortization of 1576 IFRS-GAAP PP&E Transitional Amounts								78,654			-
	Deferred Revenue											-
								<u>16,098,091</u>				<u>228,404,051</u>



**Table 2-45 – 2014 Fixed Asset Continuity Schedule (OEB Appendix 2-BA)**

OEB Object	Description	Current CCA Class	Deprec Rate (Yrs)	Cost			Accumulated Depreciation			Net Book Value 31-Dec 2014	
				Balance 12/31/13	Adjustments / Additions	Balance 12/31/14	Balance 12/31/13	Adjustments / Provision	Balance 12/31/14		
1805	Land	n/a	n/a	385,690	-	-	385,690	-	-	-	385,690
1612	Land Rights	CEC	25	366,233	17,281	-	383,514	180,897	17,264	-	185,353
1808	Buildings (Substations & Gagen)	47	30-75	1,128,336	-	-	1,128,336	713,458	11,093	-	403,784
1820	Equipment (Substations)	47	15-45	15,830,483	272,871	-	16,103,355	6,544,691	273,317	-	9,285,347
1610	Intangible Wholesale Meters	CEC	30	1,293,406	-	-	1,293,406	207,913	43,096	-	1,042,398
1830	Poles, Towers & Fixtures	47	45	39,738,167	1,924,767	-	41,662,934	19,132,710	602,360	-	21,927,864
1835	OH Conductors & Devices	47	45-50	55,136,846	3,330,254	-	58,467,100	22,386,713	832,597	-	35,247,790
1840	UG Conduit	47	30-60	35,698,363	2,527,012	(14,268)	38,211,108	9,483,834	540,572	(14,268)	28,200,969
1845	UG Conductors & Devices	47	25-40	101,576,155	3,944,185	(8,793,672)	96,726,669	54,734,965	3,637,493	(8,793,672)	47,147,882
1850	Transformers	47	35	79,632,662	3,907,876	-	83,540,538	30,979,674	1,874,691	(59)	50,686,232
1855	Services	47	30-60	24,720,934	2,287,367	-	27,008,301	8,049,275	540,782	-	18,418,244
1860	Electric Meters	8	15-30	25,081,481	955,008	(261,931)	25,774,558	7,986,510	1,422,492	(261,931)	16,627,486
1908	Buildings (General Plant Area)	1	12-65	22,091,652	1,123,130	(434,692)	22,780,090	10,359,435	892,356	(434,692)	11,962,991
1915	General Office	8	5	731,859	121,041	(120,051)	732,848	420,900	129,719	(120,051)	302,281
1920	Computer Equipment - Hardware	50	3	3,200,325	464,181	(283,350)	3,381,156	1,236,614	975,771	(283,350)	1,452,121
1611	Computer Software	12	3-5	28,241,375	4,120,230	(228,905)	32,132,701	14,050,010	5,217,828	(228,905)	13,093,767
1930	Transportation	10 & 38	8-12	11,472,907	686,041	(332,449)	11,826,499	6,290,330	705,622	(332,449)	6,663,503
1935	Stores Department	8	8	278,138	3,348	(7,727)	273,759	261,042	6,493	(7,727)	13,950
1940	Tools, Shop, Garage Equipment	8	8	1,023,409	133,094	(116,499)	1,040,004	522,561	126,202	(116,499)	507,740
1945	Meter Department	8	8	119,614	82,862	-	202,476	25,264	17,164	-	160,048
1950	Power Operated (Major) Equipment	38	8	931,471	100,000	(80,190)	951,281	434,483	109,352	(57,637)	465,083
1955	Communication Equipment	8	8-35	3,756,098	236,693	-	3,992,791	875,181	230,548	-	2,887,062
1960	Miscellaneous	8	8	-	-	-	-	-	-	-	-
1980	System Supervisory Equip (Scada)	47	10-20	2,154,497	284,577	-	2,439,074	663,896	137,338	-	1,637,840
1995	Contributed Capital	47	40	(39,262,043)	-	-	(39,262,043)	(8,616,349)	(899,701)	-	(29,745,992)
2440	Deferred Revenue	47	40	-	(1,870,692)	-	(1,870,692)	-	(20,811)	-	(1,849,881)
	<b>Total before Work In Progress</b>			<b>415,328,059</b>	<b>24,651,127</b>	<b>(10,673,733)</b>	<b>429,305,453</b>	<b>186,924,008</b>	<b>17,423,639</b>	<b>(10,651,238)</b>	<b>235,609,045</b>
2055	Work in progress			10,226,404	432,133	-	10,658,537	-	-	-	10,658,537
	<b>Total After Work In Progress</b>			<b>425,554,462</b>	<b>25,083,261</b>	<b>(10,673,733)</b>	<b>439,963,990</b>	<b>186,924,008</b>	<b>17,423,639</b>	<b>(10,651,238)</b>	<b>246,267,582</b>
2075	Renewable Generation	43.2	20	2,263,985	-	-	2,263,985	201,447	113,203	-	1,949,335
	<b>Total London Hydro Inc</b>			<b>427,818,447</b>	<b>25,083,261</b>	<b>(10,673,733)</b>	<b>442,227,975</b>	<b>187,125,455</b>	<b>17,536,842</b>	<b>(10,651,238)</b>	<b>248,216,916</b>

Work in progress	-	(10,658,537)
LH renewable generation	(113,203)	(1,949,335)
Fully allocated vehicle depreciation	(814,974)	-
Amortization of 1576 IFRS-GAAP PP&E Transitional Amounts	117,981	-
Deferred Revenue	20,811	-
	<b>16,747,457</b>	<b>235,609,045</b>



**Table 2-46 – 2015 Fixed Asset Continuity Schedule (OEB Appendix 2-BA)**

OEB Object	Description	Current CCA Class	Deprec Rate (Yrs)	Cost			Accumulated Depreciation			Net Book Value 31-Dec 2015		
				Balance 12/31/14	Additions	Adjustments / Disposals	Balance 12/31/15	Balance 12/31/14	Provision		Adjustments / Disposals	Balance 12/31/15
1805	Land	n/a	n/a	385,690	-	-	385,690	-	-	-	-	385,690
1612	Land Rights	CEC	25	383,514	31,245	-	414,759	198,161	17,569	-	215,730	199,029
1808	Buildings (Substations & Gagen)	47	30-75	1,128,336	-	-	1,128,336	724,552	11,093	-	735,645	392,691
1820	Equipment (Substations)	47	15-45	16,103,355	166,791	-	16,270,145	6,818,008	280,134	-	7,098,142	9,172,003
1610	Intangible Wholesale Meters	CEC	30	1,293,406	-	-	1,293,406	251,009	43,096	-	294,105	999,302
1830	Poles, Towers & Fixtures	47	45	41,662,934	1,462,624	-	43,125,558	19,735,070	637,346	-	20,372,416	22,753,143
1835	OH Conductors & Devices	47	45-50	58,467,100	2,727,289	-	61,194,389	23,219,310	895,073	-	24,114,383	37,080,006
1840	UG Conduit	47	30-60	38,211,108	5,093,586	(7,843)	43,296,851	10,010,139	595,660	(7,843)	10,597,956	32,698,895
1845	UG Conductors & Devices	47	25-40	96,726,669	5,009,616	(10,932,504)	90,803,781	49,578,787	3,502,825	(10,932,504)	42,149,108	48,654,673
1850	Transformers	47	35	83,540,538	5,679,475	-	89,220,013	32,854,306	2,008,373	-	34,862,679	54,357,334
1855	Services	47	30-60	27,008,301	2,450,919	-	29,459,220	8,590,057	590,947	-	9,181,004	20,278,216
1860	Electric Meters	8	15-30	25,774,558	1,299,238	(242,150)	26,831,646	9,147,072	1,472,935	(242,150)	10,377,857	16,453,790
1908	Buildings (General Plant Area)	1	12-65	22,780,090	673,316	(56,452)	23,396,955	10,817,099	919,069	(56,452)	11,679,716	11,717,238
1915	General Office	8	5	732,848	79,805	(291,749)	520,905	430,567	122,832	(291,749)	261,650	259,254
1920	Computer Equipment - Hardware	50	3	3,381,156	631,317	(1,489,367)	2,523,106	1,929,035	959,362	(1,489,367)	1,399,030	1,124,076
1611	Computer Software	12	3-5	32,132,701	4,995,403	(11,252,279)	25,875,825	19,038,934	4,976,787	(11,252,279)	12,763,442	13,112,383
1930	Transportation	10 & 38	8-12	11,826,499	1,150,226	(163,461)	12,813,264	6,663,503	754,474	(163,461)	7,254,516	5,558,747
1935	Stores Department	8	8	273,759	-	(6,161)	267,598	259,809	6,033	(6,161)	259,681	7,917
1940	Tools, Shop, Garage Equipment	8	8	1,040,004	89,981	(188,855)	941,130	532,264	122,990	(188,855)	466,399	474,730
1945	Meter Department	8	8	202,476	316,421	(2,290)	516,606	42,427	33,574	(2,290)	73,712	442,895
1950	Power Operated (Major) Equipment	38	8	951,281	147,000	(65,998)	1,032,283	486,198	110,778	(65,998)	530,978	501,305
1955	Communication Equipment	8	8-35	3,992,791	71,394	-	4,064,185	1,105,729	247,985	-	1,353,714	2,710,470
1960	Miscellaneous	8	8	-	4,039	-	4,039	-	42	-	42	3,997
1980	System Supervisory Equip (Scada)	47	10-20	2,439,074	946,159	-	3,385,233	801,234	162,396	-	963,629	2,421,604
1995	Contributed Capital	47	40	(39,262,043)	-	-	(39,262,043)	(9,516,050)	(899,701)	-	(10,415,752)	(28,846,291)
2440	Deferred Revenue	47	40	(1,870,692)	(3,788,551)	-	(5,659,243)	(20,811)	(78,721)	-	(99,531)	(5,559,712)
	<b>Total before Work in Progress</b>			<b>429,305,453</b>	<b>29,237,293</b>	<b>(24,699,109)</b>	<b>433,843,637</b>	<b>193,696,409</b>	<b>17,492,952</b>	<b>(24,699,109)</b>	<b>186,490,251</b>	<b>247,353,386</b>
2055	Work in progress			10,658,537	1,652,885	-	12,311,422	-	-	-	-	12,311,422
	<b>Total After Work In Progress</b>			<b>439,963,990</b>	<b>30,890,178</b>	<b>(24,699,109)</b>	<b>446,155,059</b>	<b>193,696,409</b>	<b>17,492,952</b>	<b>(24,699,109)</b>	<b>186,490,251</b>	<b>259,664,808</b>
2075	Renewable Generation	43.2	20	2,263,985	-	-	2,263,985	314,650	113,203	-	427,853	1,836,132
	<b>Total London Hydro Inc</b>			<b>442,227,975</b>	<b>30,890,178</b>	<b>(24,699,109)</b>	<b>448,419,044</b>	<b>194,011,059</b>	<b>17,606,154</b>	<b>(24,699,109)</b>	<b>186,918,104</b>	<b>261,500,940</b>

Work in progress	-	(12,311,422)
LH renewable generation	(113,203)	(1,836,132)
Fully allocated vehicle depreciation	(865,252)	-
Amortization of 1576 IFRS-GAAP PP&E Transitional Amounts	117,981	-
Deferred Revenue	78,721	-
	<b>16,824,401</b>	<b>247,353,386</b>





**Table 2-47 – 2016 FORECAST Fixed Asset Continuity Schedule (OEB Appendix 2-BA)**

OEB Object	Description	Current CCA Class	Deprec Rate (Yrs)	Cost			Accumulated Depreciation			Net Book Value 31-Dec 2016	
				Balance 12/31/15	Additions	Adjustments / Disposals	Balance 12/31/16	Balance 12/31/15	Provision		Adjustments / Disposals
1805	Land	n/a	n/a	385,690	-	-	385,690	-	-	-	385,690
1612	Land Rights	CEC	25	414,759	-	-	414,759	215,730	18,715	-	234,445
1808	Buildings (Substations & Gagen)	47	30-75	1,128,336	40,000	-	1,168,336	735,645	11,360	-	747,005
1820	Equipment (Substations)	47	15-45	16,270,145	116,100	-	16,386,245	7,098,142	282,855	-	7,380,997
1610	Intangible Wholesale Meters	CEC	30	1,293,406	-	-	1,293,406	294,105	43,096	-	337,201
1830	Poles, Towers & Fixtures	47	45	43,125,558	1,954,100	-	45,079,658	20,372,416	684,522	-	21,056,938
1835	OH Conductors & Devices	47	45-50	61,194,389	3,282,200	-	64,476,589	24,114,383	968,409	-	25,082,792
1840	UG Conduit	47	30-60	43,296,851	4,552,300	-	47,849,151	10,597,956	700,503	-	11,298,459
1845	UG Conductors & Devices	47	25-40	90,803,781	5,897,300	(6,190,659)	90,510,422	42,149,108	3,395,271	(6,190,659)	39,353,720
1850	Transformers	47	35	89,220,013	4,270,000	-	93,490,013	34,862,679	2,179,781	-	37,042,460
1855	Services	47	30-60	29,459,220	1,514,900	-	30,974,120	9,181,004	654,800	-	9,835,804
1860	Electric Meters	8	15-30	26,831,646	1,093,600	-	27,925,246	10,377,857	1,549,534	-	11,927,391
1908	Buildings (General Plant Area)	1	12-65	23,396,955	1,160,000	(56,452)	24,500,503	11,679,716	952,683	(56,452)	12,575,948
1915	General Office	8	5	520,905	455,000	(177,974)	797,931	261,650	142,206	(177,974)	225,883
1920	Computer Equipment - Hardware	50	3	2,523,106	323,200	(1,083,069)	1,763,237	1,399,030	748,030	(1,083,069)	1,063,991
1611	Computer Software	12	3-5	25,875,825	4,551,800	(3,592,822)	26,834,803	12,763,442	5,659,508	(3,592,822)	14,830,128
1930	Transportation	10 & 38	8-12	12,813,264	1,130,000	(723,954)	13,219,310	7,254,516	893,524	(723,954)	7,424,086
1935	Stores Department	8	8	267,598	80,000	(2,057)	345,540	259,681	7,429	(2,057)	265,052
1940	Tools, Shop, Garage Equipment	8	8	941,130	155,000	(106,544)	989,586	466,399	126,144	(106,544)	485,999
1945	Meter Department	8	8	516,606	210,000	-	726,606	73,712	77,744	-	151,456
1950	Power Operated (Major) Equipment	38	8	1,032,283	-	-	1,032,283	530,978	125,906	-	656,884
1955	Communication Equipment	8	8-35	4,064,185	770,500	-	4,834,685	1,353,714	273,998	-	1,627,712
1960	Miscellaneous	8	8	4,039	-	-	4,039	42	505	-	547
1980	System Supervisory Equip (Scada)	47	10-20	3,385,233	331,000	-	3,716,233	963,629	213,472	-	1,177,101
1995	Contributed Capital	47	40	(39,262,043)	-	-	(39,262,043)	(10,415,752)	(899,701)	-	(11,315,453)
2440	Deferred Revenue	47	40	(5,659,243)	(2,087,000)	-	(7,746,243)	(99,531)	(167,569)	-	(267,100)
	<b>Total before Work In Progress</b>			<b>433,843,637</b>	<b>29,800,000</b>	<b>(11,933,531)</b>	<b>451,710,106</b>	<b>186,490,251</b>	<b>18,642,725</b>	<b>(11,933,531)</b>	<b>193,199,445</b>
2055	Work in progress			12,311,422	1,832,000	-	14,143,422	-	-	-	14,143,422
	<b>Total After Work In Progress</b>			<b>446,155,059</b>	<b>31,632,000</b>	<b>(11,933,531)</b>	<b>465,853,528</b>	<b>186,490,251</b>	<b>18,642,725</b>	<b>(11,933,531)</b>	<b>272,654,083</b>
2075	Renewable Generation	43.2	20	2,263,985	-	-	2,263,985	427,853	113,203	-	541,056
	<b>Total London Hydro Inc</b>			<b>448,419,044</b>	<b>31,632,000</b>	<b>(11,933,531)</b>	<b>468,117,513</b>	<b>186,918,104</b>	<b>18,755,928</b>	<b>(11,933,531)</b>	<b>193,740,501</b>

Work in progress	-	(14,143,422)
LH renewable generation	(113,203)	(1,722,929)
Fully allocated vehicle depreciation	(1,019,430)	-
Amortization of 1576 IFRS-GAAP PP&E Transitional Amounts	118,000	-
Deferred Revenue	167,569	-
	<u>17,908,864</u>	<u>258,510,661</u>



**Table 2-48 – 2017 FORECAST Fixed Asset Continuity Schedule (OEB Appendix 2-BA)**

OEB Object	Description	Current CCA Class	Deprec Rate (Yrs)	Cost					Accumulated Depreciation				Net Book Value 31-Dec 2017	
				Balance 12/31/16	Transfers from Reg Deferrals	Additions	Adjustments / Disposals	Balance 12/31/17	Balance 12/31/16	Transfers from Reg Deferrals	Provision	Adjustments / Disposals		Balance 12/31/17
1805	Land	n/a	n/a	385,690	-	-	-	385,690	-	-	-	-	-	385,690
1612	Land Rights	CEC	25	414,759	-	-	-	414,759	234,445	-	18,715	-	253,160	161,599
1808	Buildings (Substations & Gagen)	47	30-75	1,168,336	-	42,000	-	1,210,336	747,005	-	11,906	-	758,911	451,425
1820	Equipment (Substations)	47	15-45	16,386,245	-	114,500	-	16,500,745	7,380,997	-	286,323	-	7,667,320	8,833,425
1610	Intangible Wholesale Meters	CEC	30	1,293,406	-	-	-	1,293,406	337,201	-	43,096	-	380,297	913,110
1830	Poles, Towers & Fixtures	47	45	45,079,658	-	2,193,800	-	47,273,458	21,056,938	-	730,610	-	21,787,548	25,485,911
1835	OH Conductors & Devices	47	45-50	64,476,589	-	3,510,900	-	67,987,489	25,082,792	-	1,037,964	-	26,120,756	41,866,733
1840	UG Conduit	47	30-60	47,849,151	-	4,321,900	-	52,171,051	11,298,459	-	780,908	-	12,079,367	40,091,684
1845	UG Conductors & Devices	47	25-40	90,510,422	-	5,530,700	(3,505,306)	92,535,816	39,353,720	-	3,401,814	(3,505,306)	39,250,228	53,285,588
1850	Transformers	47	35	93,490,013	19,000	4,275,800	-	97,784,813	37,042,460	4,117	2,305,664	-	39,352,241	58,432,572
1855	Services	47	30-60	30,974,120	-	1,595,800	-	32,569,920	9,835,804	-	695,097	-	10,530,901	22,039,019
1860	Electric Meters	8	15-30	27,925,246	-	1,113,500	-	29,038,746	11,927,391	-	1,615,894	-	13,543,285	15,495,462
1908	Buildings (General Plant Area)	1	12-65	24,500,503	-	870,000	(2,273,932)	23,096,571	12,575,948	-	745,229	(2,273,932)	11,047,245	12,049,326
1915	General Office	8	5	797,931	-	197,000	(134,227)	860,704	225,883	-	179,238	(134,227)	270,894	589,810
1920	Computer Equipment - Hardware	50	3	1,763,237	-	297,200	(1,427,608)	632,829	1,063,991	-	473,050	(1,427,608)	109,433	523,396
1611	Computer Software	12	3-5	26,834,803	419,897	3,662,800	(2,656,748)	28,260,752	14,830,128	177,973	4,912,194	(2,656,748)	17,263,547	10,997,205
1930	Transportation	10 & 38	8-12	13,219,310	-	924,000	(553,478)	13,589,831	7,424,086	-	950,897	(553,478)	7,821,505	5,768,326
1935	Stores Department	8	8	345,540	-	15,000	(125,569)	234,972	265,052	-	12,247	(125,569)	151,731	83,241
1940	Tools, Shop, Garage Equipment	8	8	989,586	-	155,000	(123,791)	1,020,795	485,999	-	125,485	(123,791)	487,693	533,101
1945	Meter Department	8	8	726,606	-	150,000	(11,016)	865,590	151,456	-	98,824	(11,016)	239,264	626,327
1950	Power Operated (Major) Equipment	38	8	1,032,283	-	175,000	(100,304)	1,106,979	656,884	-	125,654	(95,080)	687,458	419,521
1955	Communication Equipment	8	8-35	4,834,685	-	747,500	-	5,582,185	1,627,712	-	316,047	-	1,943,759	3,638,425
1960	Miscellaneous	8	8	4,039	-	-	-	4,039	547	-	505	-	1,052	2,987
1980	System Supervisory Equip (Scada)	47	10-20	3,716,233	-	300,600	(10,015)	4,006,818	1,177,101	-	237,203	(10,015)	1,404,289	2,602,529
1995	Contributed Capital	47	40	(39,262,043)	-	-	-	(39,262,043)	(11,315,453)	-	(899,701)	-	(12,215,154)	(27,046,889)
2440	Deferred Revenue	47	40	(7,746,243)	-	(2,101,000)	-	(9,847,243)	(267,100)	-	(219,919)	-	(487,019)	(9,360,224)
	<b>Total before Work In Progress</b>			<b>451,710,106</b>	<b>438,897</b>	<b>28,092,000</b>	<b>(10,921,994)</b>	<b>469,319,009</b>	<b>193,199,445</b>	<b>182,089</b>	<b>17,984,944</b>	<b>(10,916,770)</b>	<b>200,449,709</b>	<b>268,869,300</b>
2055	Work in progress			14,143,422	-	2,382,000	-	16,525,422	-	-	-	-	-	16,525,422
	<b>Total After Work In Progress</b>			<b>465,853,528</b>	<b>438,897</b>	<b>30,474,000</b>	<b>(10,921,994)</b>	<b>485,844,431</b>	<b>193,199,445</b>	<b>182,089</b>	<b>17,984,944</b>	<b>(10,916,770)</b>	<b>200,449,709</b>	<b>285,394,722</b>
2075	Renew able Generation	43.2	20	2,263,985	-	-	-	2,263,985	541,056	-	113,203	-	654,259	1,609,726
	<b>Total London Hydro Inc</b>			<b>468,117,513</b>	<b>438,897</b>	<b>30,474,000</b>	<b>(10,921,994)</b>	<b>488,108,416</b>	<b>193,740,501</b>	<b>182,089</b>	<b>18,098,147</b>	<b>(10,916,770)</b>	<b>201,103,968</b>	<b>287,004,448</b>
	Work in progress													(16,525,422)
	LH renew able generation										(113,203)			(1,609,726)
	Fully allocated vehicle depreciation										(1,076,551)			-
	Deferred Revenue										219,919			-
											<b>17,128,312</b>			<b>268,869,300</b>



## **Appendix 2-2: Capitalization Policy**

---

# CAPITAL ASSETS ACCOUNTING POLICIES AND PROCEDURES

## (Property, Plant and Equipment and Intangible Assets)

### OVERVIEW

London Hydro applies International Financial Accounting Standards (IFRS), as identified in IFRS 1 First Time Adoption of IFRS and in IAS 16 Property, Plant and Equipment (PP&E), for the following general capitalization principles and procedures.

#### Background

On February 13, 2008, the Canadian Accounting Standards Board (“AcSB”) officially confirmed the requirement for publicly accountable enterprises to adopt IFRS for financial reporting purposes in 2011. However, transition was deferred due to issues surrounding rate-regulated accounting for regulatory assets and liabilities.

London Hydro’s eventual and actual transition date to IFRS is January 1, 2015 with 2014 amounts being restated for comparative purposes.

Up to and including the date of transition to IFRS, Canadian Generally Accepted Accounting Principles (CGAAP), and in particular CICA Handbook (Sections 3061 to 3064), and the guidelines as specified in the Ontario Energy Board (OEB) Accounting Procedures Handbook (APH) (Article 410) were the basis for general capitalization principles and procedures.

To ease in the transition from CGAAP to IFRS and to help with Cost of Service filings, London Hydro implemented the following required IFRS changes acceptable under the CGAAP accounting standard effective January 1, 2012, as follows:

- Capital assets were segregated into more intricate components and new life spans were applied;

- Materials Management overhead burdens were reduced to consider direct labour only. (All other expenditures cannot be tied to a specific item so are considered general and administrative in nature under MIFRS); and
- Labour overhead burdens were reduced slightly to exclude the capitalization of costs associated with training employees.

## **GENERAL CAPITALIZATION POLICY**

### **1.0 PURPOSE**

This document describes the accounting policies and processes set for the appropriate classification of London Hydro's expenditures and provides guidelines to assist in determining whether expenditures are capitalized and recorded to the balance sheet (capital assets) or expensed to operations in the period incurred (expensed).

The accounting policies and processes document is to permit accurate recognition of expenditures as either capital assets or operating expenses which is necessary for meeting the financial reporting requirements for IFRS and of the OEB, to provide accurate financial reporting to management and our shareholder, and to prepare meaningful budgets.

*It should also be noted that capitalized expenditures attempt to provide for an equitable allocation of cost among existing and future customers as the assets are used.*

### **2.0 ACCOUNTING POLICY**

#### **2.1 Recognition Principle**

An *item* of Property, Plant and Equipment should be recognized as a capital asset, if and only if, it is probable that *future economic benefits* associated with the asset will flow to the Company, and the cost of the item can be measured reliably. (IAS 1 67.74 a and b)

Intangible assets are also considered capital assets under this criteria and are identified as identifiable non-monetary assets that lack physical substance. (IAS 38.8)

Other Criteria for recognition as a capital asset include:

Expenditures incurred to purchase or to build tangible or intangible assets that will provide *benefits lasting beyond one year* to the Company will be capitalized.

Expenditures incurred to improve (betterment) an existing asset will be capitalized if it is probable that future economic benefits will flow to the Company. Future economic benefits are demonstrated by the expenditure extending the asset's useful life/lifespan or increasing the asset's potential productivity/capacity or potentially lowering operating costs.

London Hydro's capital assets typically include electric plant, transmission, generation and distribution facilities, meters, vehicles, office furniture, computer hardware and other equipment.

Intangible assets general represent land rights, capital contributions paid to Hydro One and computer software.

Expenditures for repairs and/or maintenance designed to maintain an asset in its original state are not capital expenditures and should be charged to an operating account.

***In the event of uncertainty surrounding the determination of a cost to be capital or operating or the application of materiality limits, if any exist, the Finance Department or the CFO should be consulted.***

## **2.2 Measurement**

Whether capital assets are purchased or constructed by the Company, they are stated at cost and include expenditures that are directly attributable to bringing the asset to the location and condition necessary for it to be capable of operating in the manner intended.

The cost of self-constructed assets includes direct materials, initial delivery and assembly, labour, employee benefits, professional fees and any other costs directly attributable to bringing the asset to a working condition for its intended use. Other costs could include expenditures *directly attributable* to the asset from engineering, overheads, contracted services, and interest or borrowing costs.

Overheads are identified as being costs that support capital and operating activities, specifically within Supply Chain Management, Fleet Operations and Labour costing. Similarly, expenditures

included in Overheads must be reviewed to determine whether they are “directly attributable” to bringing the asset to the location and working condition for its intended use (IAS 16.16 b). Interest or borrowing costs should be capitalized on qualifying projects where construction activity extends over one year.

Costs that are not included in the cost of an item of PP&E include training costs, administration and other general overhead costs, feasibility studies conducted prior to project approval.

### **2.3 Amortization / Depreciation**

Depreciation is recognized in profit or loss on a straight-line basis over the estimated useful life of each part or component of an item of PP&E that is significant in relation to the total cost of the item. PP&E are considered tangible assets. Land and perpetual land rights are not depreciated. Finite lived intangible assets are amortized over their estimated useful life (IAS 38).

Construction-in-progress assets are not amortized until the item of PP&E is “**available for use**” (in its location and condition necessary for it to be capable of operating in the manner intended by management) (IAS 16.55).

Depreciation methods, useful lives and residual values are reviewed annually. Changes in useful life and residual values resulting from this review will be accounted for on a prospective basis as a change in accounting estimate in accordance with IAS 8.

Depreciation of an asset ceases when the asset is derecognized. (IAS 16.55). Depreciation does not cease when the asset is idle or retired from active use except when the asset is classified as held for sale.

### **2.4 Derecognition (Retirements and Disposals)**

An item of PP&E or Intangibles will be removed from the capital assets on the balance sheet when it is taken out of service, or abandoned where no future benefits are expected or when sold. The resulting loss equal to its net book value less disposal costs will be recognized in profit and loss. In the case of a sale of an item of PP&E or Intangibles, gains and losses are determined by comparing the proceeds from the disposal with the net book value of the item disposed with the gain or loss recognized in profit or loss. (IAS 16.68)

Derecognition will follow materiality limits to avoid undue administrative burden where costs may outweigh the benefits. For assets which cannot be individually identified, *this materiality limit has been set by London Hydro to \$10,000* in that an item will not be removed from PP&E where its net book value is equal to or less than this limit. This threshold takes into consideration, and assists in offsetting for, those assets in service that have exceeded their life expectancy.

This above-noted materiality limit does not apply where an individual asset record is maintained. For example, in the case of a vehicle.

## 2.5 Impairments

At the end of each annual reporting period, the Company must assess whether there is any indication that an asset may be impaired, and if so, determine and measure the impairment loss (IAS 36.9).

An item of PP&E or intangible asset is considered impaired if objective evidence indicates that one or more events have had a negative effect on the estimated future cash flows of the item. IAS 36.12 (f) states that a plan to dispose of an asset before the previously expected date is an indicator of impairment that triggers the calculation of the asset's recoverable amount for the purpose of determining whether the asset is impaired. Further indications of possible impairment are reflected below.

### *Indications of Impairment* [IAS 36.12]

#### External sources:

- market value declines
- negative changes in technology, markets, economy, or laws
- increases in market interest rates

#### Internal sources:

- obsolescence or physical damage
- asset is part of a restructuring or held for disposal
- worse economic performance than expected

The above list is not intended to be exhaustive. [IAS 36.13]



If there is an indication that an impairment loss on assets exists, the recoverable amount is estimated. The impairment loss is the amount by which the asset's carrying amount or net book value exceeds its recoverable amount. The impairment loss is recognized in profit or loss.

## **3.0 DEFINITIONS**

### **3.1 Tangible Assets**

Property, Plant and Equipment as set out in IAS 16.6 indicates that they are a tangible item that:

- are held for use in the production or supply of goods or services, for rental to others, or for administrative purposes; and
- are expected to be used during more than one period.

### **3.2 Intangible Assets**

An intangible asset is an identifiable non-monetary asset without physical substance. An asset is a resource that is controlled by the entity as a result of past events (for example, purchased or self-creation) and from which future economic benefits (inflows of cash or other assets) are expected. [IAS 38.8] Thus, the three critical attributes of an intangible asset are:

- identifiable
- control (power to obtain benefits from the asset) resulting from a past event
- future economic benefits (such as revenues or reduced future costs)

*Identifiable:* an intangible asset is identifiable when it: (IAS 38.12) is separable (capable of being separated and sold, transferred, licensed, rented, or exchanged, either individually or together with a related contract) or arises from contractual or other legal rights, regardless of whether those rights are transferable or separable from the entity or from other rights and obligations.

### **3.3 Betterment**

A betterment is defined as the cost incurred to enhance the service potential of a capital asset. It can include the increasing of the capacity of the asset, lowering associated operating costs, improving the quality of output or extending the asset's useful life. Expenditures for betterments are capitalized if the capital asset will provide future economic benefit to the Company (see 4.1 for materiality limits as to betterments).

### **3.4 Repair**

A repair is a cost which is incurred in the maintenance of the existing service potential of a capital asset. These costs are normally wear and tear in the normal use of the capital asset and do not enhance the service life of the asset. Repair costs are expensed in the period in which they occur.

### **3.5 Administrative and other general overhead**

IAS 16.19 (d) explicitly prohibits capitalization of administration and other general overhead costs (“G&A”). IAS 16 does not define administration and other general overhead costs nor is it defined elsewhere in IFRS literature and therefore requires the application of judgment to identify such costs. In considering whether a cost is in the nature of G&A, the nature of the cost itself is not determinative. Rather, it is the specific facts and circumstances surrounding the cost at an entity and the entity’s ability to demonstrate that the cost is directly attributable to an item of PP&E.

G&A costs typically benefit the organization as a whole or areas of the organization more broadly rather than contributing directly to bringing a physical asset to the location and condition necessary for it to be capable of operating in the manner intended by management. The more the nature of a particular costs strays from being directly attributable to an item of PP&E, then the more likely it is that the cost will be determined to be in the nature of G&A.

### **3.6 Recoverable amount**

The recoverable amount of an asset is the higher of its fair value less cost to sell and its value in use.

Fair value, less costs to sell, is the amount obtainable from the sale of an asset in an arm’s length transaction between knowledgeable, willing parties, less the costs of disposal. Value in use is the present value of the future cash flows expected to be derived from an asset.

### **3.7 Qualifying assets**

A qualifying asset is an asset that necessarily takes a substantial period of time to get ready for its intended use or sale. A substantial period of time is defined as greater than one year.

## **4.0 CAPITALIZATION GUIDELINES**

### **4.1 Materiality Limits**

All expenditures for capital assets, including betterments, are subject to materiality limits.

While an expenditure might meet the definition to qualify as a capital asset, a materiality limit has been established to minimize the cost disadvantages where administration costs of capitalizing an asset may outweigh the intended benefits.

In view of the foregoing, expenditures that *are less than \$2,000* should be charged to an operating account (expensed). This limit applies to an individual asset, the total costs of a constructed asset, as well as betterments.

In cases where items are routinely purchased as a set, and have an aggregate purchase price of \$2,000 or more, the items will be capitalized and depreciated. For example: the purchase of a table and 4 chairs from the same vendor where the table and chairs are to be utilized as a set and the value of which is over \$2,000 in total.

Bulk purchases of similar items that have an *aggregate value of \$5,000* or more are to be recorded as a fixed asset regardless of individual price of item. For example: the purchase of 10 hand tools at \$500 each, where the total purchase is \$5,000 or more.

With respect to office furniture and computer hardware purchases, these materiality limits are reduced to \$500 and \$2,000. Specifically, expenditures that are less than \$500 should be expensed and bulk purchase of \$2,000 or more are to be capitalized. All acquisitions of used office furniture should be charged to expense.

### **4.2 Componentization of Assets**

For each part of an item of PP&E with a cost that is significant in relation to the total cost of the item, the item shall be depreciated separately (IAS 16.43).

An entity allocates the amount initially recognized in respect of an item of property, plant and equipment to its significant parts and depreciates each such part (IAS 16.44).

A significant part of an item of PP&E may have a useful life and a depreciation method that are the same as the useful life and the depreciation method of another part of the same item. Such parts may be grouped in determining the depreciation charge (IAS 16.45).

### **4.3 Interest or Borrowing Costs**

Borrowing costs that are directly attributable to the construction or acquisition of qualifying assets are capitalized as part of the cost of the asset. The OEB usually identifies borrowing costs that are capitalized as being Allowance for Funds Used in Construction (AFUDC). Only those assets with construction periods of *over 1 year* are to be considered for having their interest or borrowing costs capitalized.

For the purposes of determining whether an asset is a qualifying asset, those periods of time where there is a lack of construction activity, for whatever reason, should reflect a reduction of construction duration. Therefore, the period of time reflecting a lack of construction should be eliminated from the construction duration when determining whether the asset has a construction period of greater than one year.

Further requirements include that the qualifying asset has a reasonable expectation of completion and recovery. Interest or borrowing costs are to be charged to an operating account once substantially all of the activities necessary to prepare the qualifying asset for its intended use are complete (IAS 23.22).

The capitalization of borrowing costs should be suspended when there are extended periods where active development of a qualifying asset are suspended.

Borrowing costs are based on the Company's cost of borrowing. Borrowing costs that are directly attributable to the acquisition or construction of a qualifying asset are those borrowing costs that would have been avoided if the expenditure on the qualifying asset had not been made. When the company borrows funds specifically for the purpose of obtaining a particular qualifying asset, the borrowing costs that directly relate to that qualifying asset can be readily identified. Borrowing costs related to general borrowings, where general borrowings are used to obtain a qualifying asset, should be determined. A capitalization rate should be calculated as the weighted average of the borrowing costs applicable to the borrowings outstanding during the

period (IAS 23.14). The amount of borrowing costs that are capitalized during the period should not exceed the amount of borrowing costs incurred during that period. London Hydro calculates borrowing costs to be capitalized using the lower of the Ontario Energy Board's published Constuction Work-In-Progress (CWIP) interest rates and actual borrowing costs incurred.

#### **4.4 Replacement Parts**

The cost of replacing part of an item of PP&E is recognized in the carrying amount of the item if it is probable that the future incremental economic benefits embodied within the part will flow to the Company and its costs can be measured reliability (IAS 16.7, 16.13). The carrying amount of the replaced part is derecognized (IAS 16.13).

#### **4.5 Decommissioning or Dismantling (Constructive and Asset Retirement Obligations or ARO)**

Where there is a legal or constructive obligation to remove and dispose of PP&E at the end of their useful life, a provision is recorded to cover such future removal and disposal costs. (IAS 37, Provisions, Contingent Liabilities and Contingent Assets) The obligation costs are recognized at best estimate to settle the present obligation (IAS 37.36).

It is felt that the Company's distribution network essentially operates in perpetuity, and accordingly the date upon which it will be taken out of service is generally not determinable. Therefore, the present value of that obligation should be immaterial if it exists at all.

Decommissioning or dismantling obligations may arise from contractual agreements (such as leases) or legislation governing the disposal requirements for an asset. When such obligations arise as a result of a past event and it is probable that an outflow of resources will be required to settle the obligation, a liability should be recorded. The initial estimate of such a liability is included in the cost of the asset (IAS 16.16 (c)).

#### **4.6 Capital Spares**

Spare parts and stand-by equipment are considered PP&E when the Company expects to use them during more than one period (year). If the spare parts and servicing equipment can be used only in connection with an item of PP&E, they are considered PP&E (IAS 16.8).

Therefore, spare transformers and meters and other such items of PP&E that are applicable to this guidance, are accounted for as an item of PP&E as they are i) not intended for resale, ii) have a longer period of future benefit as compared to inventory items, iii) form an integral part of the original distribution plant by enhancing reliability of the original distribution plant, and iv) provide future benefits because they are expected to be placed in service.

Spare parts commence to be amortized when the spare part is available for use (rather than put to use) (IAS 16.55).

#### **4.7 Contributed Capital (Contributions in Aid of Construction)**

Certain assets may be acquired or constructed with financial assistance in the form of contribution from customers or developers.

Capital contributions received are treated as a liability on the balance sheet (IFRIC 18).

Amortization of the deferred customer contributions is required and done so over the average life span of the related assets.

Additions to contributed capital throughout the year need to be amortized as incurred.

*Amounts that are amortized are to be recorded as a charge to the revenue deferral account and a credit to revenue account. For the purposes of reporting to the OEB, contributed capital is considered to be recorded as a capital account (as a credit to the asset contra account).*

The Company has yet to have a customer or developer with a new expansion project select an “alternative bid” option as determined under 3.2.3 of the OEB Distribution System Code. An alternative bid option is one in which the customer provides on their own the purchase or building of the expansion facilities. Upon acceptance of these facilities by the Company as meeting specific requirements, the facility ownership is then to be transferred from the customer to the Company. The transfer price for the expansion project is based on the Company’s initial offer that was made to the customer.

#### **4.8 Major Inspections/Overhauls of Item of PP&E**

If regular “major” inspections are instituted on an item or items of PP&E, regardless if the parts of the item are replaced, this cost is recognized in the carrying amount of the item of PP&E. (IAS 16.13). If the PP&E item is derecognized the remaining carrying amount of the cost of the previous major inspection is also derecognized.

The cost of the major inspection or overhaul included in the amount initially recognized for an item of PP&E should be allocated to the major inspection or overhaul component and amortized separately over the useful life of this component so that it is fully depreciated before the next major inspection occurs.

The Company does not normally realize regular major inspections on its PP&E, and therefore does not anticipate having a separate component for major inspection costs.

#### **4.9 London Hydro Contributions to PP&E not Owned by London Hydro**

Contributions to PP&E made by London Hydro, where ownership is not realized by London Hydro, should be classified as an Intangible Asset, based on the following requirements:

The contribution is a resource that is controlled by the entity as a result of asset purchase or self-creation and from which future economic benefits (inflows of cash or other assets) are expected.

[IAS 38.8]

Thus, the three critical attributes of an intangible asset are:

- identifiability
- control (power to obtain benefits from the asset)
- future economic benefits (such as revenues or reduced future costs)

An example of such an intangible asset would be London Hydro contributions to a Hydro One Transformer Station. Although London Hydro provided expenditures to the PP&E item, London Hydro does not retain ownership of the item. However, London Hydro does obtain future economic benefit and has been provided by Hydro One assurance that London Hydro has the right to use the item of PP&E or that the item of PP&E’s future economic benefits will continue to accrue to London Hydro.

## 4.10 Computer Software Expenditures

Computer software expenditures are to be classified as an intangible asset if it is probable that the expected future economic benefits attributable to it will flow to the entity (IAS 38.21). Only major application software projects with total “acquisition and enhancement expenditures” in excess of the established materiality limit, per 4.1 Materiality Limit, and with an expected future life *exceeding two years*, are capitalized. All other software expenditures are charged to operations as incurred.

IAS 38, Intangible Assets, guidance for the recording and recognition of computer software expenditure:

- Purchased: capitalize
- Operating system for hardware: include in hardware cost \*\*
- Internally developed (whether for use or sale): charge to expense until technological feasibility, probable future benefits, intent and ability to use or sell the software, resources to complete the software, and ability to measure cost
- Amortization: over useful life based on pattern of benefits (straight-line is the default)

Further criteria for computer software expenditures to be recorded as an item of an intangible asset is identified in item 3.2 Intangible Assets. Further interpretations can be found under “*Further Guidance, Intangible Assets*”, towards end of this Capital Asset Accounting Policy and Procedures document.

Software acquisition and enhancement expenditures include:

- Software purchase costs (including internal and external customization charges)
- Development costs for internally developed software. Permitted development costs must be identified with the following:
  - i. being technological feasibility,
  - ii. intending to complete the software,
  - iii. having the ability to use the intangible asset,
  - iv. having probable future benefits,
  - v. having available resources to complete the software, and
  - vi. having the ability to measure cost.

Examples of permitted development costs for internal development software projects can include testing, data purchase and loading costs, commissioning and documentation.



Software-related expenditures for existing data clean up or repair prior to loading are not capitalized as they represent a repair of existing data (exclusion to this is where data is required to be formatted before loading to a new computer system). Business process reengineering costs that are directly related to certain computer systems are charged to operation as incurred, as these costs are not an integral component for software. Training costs associated with any computer software projects are charged to operation as incurred (IAS 38.69).

Subsequent expenditure on computer software after its purchase or completion should be recognized as an expense when it is incurred, unless it is probable that this expenditure will enable the asset to generate future economic benefits in excess of its originally assessed standard of performance and the expenditure can be measured and attributed to the asset reliably. [Referenced to IAS 38.60]

\*\* Software required for hardware to function (integral part of the related hardware) is considered hardware. For example, an operating system is to be charged to tangible fixed assets under computer hardware. Software that is not an integral part of computer hardware will be considered software and capitalized as an intangible asset. Both examples assume expenditures meet materiality limits and life span requirements.

## **5.0 POLICY COMPLIANCE**

As with any policy, there are to be no exemptions to the requirements of this policy in the execution of day-to-day business. Staff must report incidents of non-compliance relating to this policy in a timely manner to their Manager or Supervisor. Non-compliance issues of a serious nature will be immediately reported to the CFO.

## ***FURTHER GUIDANCE***

### ***Measurement Recognition***

The Company shall measure an item of PP&E at initial recognition at its cost (IAS 16.15).

The cost of an item of PP&E comprises of:

- a) purchase price, including legal and brokerage fees, import duties and non-refundable purchase taxes, after deducting trade discounts and rebates.
- b) Any costs directly attributable to bring the asset to the location and condition necessary for it to be capable of operating in the manner intended by management. These can be costs of site preparation, initial delivery and handling, installation and assembly, and testing of functionality.
- c) The initial estimate of the costs of dismantling and removing the item and restoring the site on which it is located, the obligation for which the Company incurs either when the item is acquired or as a consequence of having used the item during a particular period for purposes other than to produce inventories during that period. (IAS 16.16 a., b. and c.) (reference Item 4.5 for further information)

Examples of directly attributable costs are costs of employee benefits (as defined IAS 19 Employee Benefits), directly arising from the construction or acquisition of the item of PP&E; costs of site preparation; initial delivery and handling costs; installation and assembly costs; cost of testing whether the asset is functioning properly and professional fees.

As per IAS 16.19, the following costs are examples of costs not to be included as PP&E, and therefore shall be expensed. They are: Costs of opening a new facility, introduction of a new product or service, conducting business in a new location or with a new class of customer, administration and other general overhead costs. Other costs that should be recorded as expense include training, non-specific pre-construction project costs (where it is uncertain whether the costs will result in an addition to PP&E), and abnormal waste.

### ***Useful Life Determinates***

The Company shall consider all the following factors in determining the useful life of an asset (IAS 17.12):

- a) The expected usage of the asset. Usage is assessed by reference to the asset's expected capacity or physical output
- b) Expected physical wear and tear, which depends on operational factors such as loads to be used on asset, the repairs and maintenance program, and the care and maintenance of the asset while it is idle
- c) Technical or commercial obsolescence arising from changes or improvements in production, or change in the market demand or service input of the asset
- d) Legal or similar limits on the use of the asset

### ***Intangible Assets***

#### ***Classification of Intangible Assets Based on Useful Life***

Intangible assets are classified as: [IAS 38.88]

- **Indefinite life:** no foreseeable limit to the period over which the asset is expected to generate net cash inflows for the entity
- **Finite life:** a limited period of benefit to the entity

#### ***Measurement Subsequent to Acquisition: Intangible Assets with Finite Lives***

The cost less residual value of an intangible asset with a finite useful life should be amortized on a systematic basis over that life: [IAS 38.97]

- The amortization method should reflect the pattern in which the benefits are expected to be consumed.
- If the pattern cannot be determined reliably, amortize by the straight line method.
- The amortization charge is recognized in profit or loss unless another IFRS requires that it be included in the cost of another asset.
- The amortization period and method should be reviewed when required.
- The asset should also be assessed for impairment in accordance with IAS 36. [IAS 38.111]

#### ***Measurement Subsequent to Acquisition: Intangible Assets with Indefinite Lives***

An intangible asset with an indefinite useful life should not be amortized. [IAS 38.107]

Its useful life should be reviewed each reporting period to determine whether events and circumstances continue to support an indefinite useful life assessment for that asset. If they do not, the change in the useful life assessment from indefinite to finite should be accounted for as a change in an accounting estimate. [IAS 38.109]

The asset should also be assessed for impairment in accordance with IAS 36 on an annual basis. [IAS 38.108]

### *Subsequent Expenditure*

Subsequent expenditure on an intangible asset after its purchase or completion should be recognized as an expense when it is incurred, unless it is probable that this expenditure will enable the asset to generate future economic benefits in excess of its originally assessed standard of performance and the expenditure can be measured and attributed to the asset reliably. [IAS 38.60]

### *Land and Land Rights*

Capitalized land includes direct purchase costs including appraisals, fees, commissions, surveys, title search and registration. Costs for first clearing and grading and installation of the plant are ultimately capitalized as part of the cost of PP&E constructed on the land, rather than as an integral cost of the land.

Capitalized land rights include costs of acquiring rights, interests and privileges in land owned by others. Land rights are considered under IFRS as an intangible asset and so guidance can be identified in intangible sections of this policy.



## **Appendix 2-3: Lead Lag Study**

---

## Working Capital Requirements of London Hydro's Electricity Distribution Business

Prepared for:



**Submitted by:**

Navigant Consulting, Ltd.  
333 Bay Street  
Suite 1250  
Toronto, ON, M5H 2R2

[navigant.com](http://navigant.com)

Reference No.: 181518  
July 12, 2016

This report (the “report”) was prepared for London Hydro Limited (“London Hydro”) by Navigant Consulting, Ltd. (“Navigant”). The report was prepared solely for the purposes of London Hydro’s rate filing before the Ontario Energy Board and may not be used for any other purpose. Use of this report by any third party outside of London Hydro’s rate filing is prohibited. Use of this report should not, and does not, absolve the third party from using due diligence in verifying the report’s contents. Any use which a third party makes of this report, or any reliance on it, is the responsibility of the third party. Navigant extends no warranty to any third party.

## Table of Contents

<b>Section I: Executive Summary .....</b>	<b>3</b>
Summary .....	3
Organization of the Report .....	4
<b>1. Revenue Lags .....</b>	<b>5</b>
1.1 Retail Revenue Lag .....	6
1.1.1 Service Lag .....	7
1.1.2 Billing Lag .....	7
1.1.3 Collections Lag .....	7
1.1.4 Payment Processing Lag .....	7
<b>2. Expense Leads .....</b>	<b>8</b>
2.1 Cost of Power .....	8
2.1.1 IESO Cost of Power Expenses .....	9
2.1.2 Hydro One Cost of Power Expenses .....	10
2.1.3 Payments to Embedded Generation Customers .....	11
2.1.4 Payments to Retailers .....	11
2.2 OM&A Expenses .....	11
2.2.1 Payroll & Benefits .....	12
2.2.2 Property Taxes .....	13
2.2.3 Other Miscellaneous OM&A .....	13
2.3 Debt Retirement Charge (DRC) .....	14
2.4 Payment in Lieu of Taxes (PILs) .....	15
2.5 Interest on Short-Term and/or Long-Term Debt .....	16
<b>3. Harmonized Sales Tax (HST) .....</b>	<b>17</b>
<b>4. Conclusions .....</b>	<b>18</b>
<b>Appendix A. Working Capital Methodology .....</b>	<b>A-1</b>
A.1 Key Concepts .....	A-1
Mid-Point Method .....	A-1
Statutory Approach .....	A-1
Expense Lead Components .....	A-2
Dollar Weighting .....	A-2
A.2 Methodology .....	A-2
<b>Appendix B. Detailed Data Tables .....</b>	<b>B-1</b>
<b>Appendix C. Expert Information .....</b>	<b>C-1</b>



## Section I: Executive Summary

### Summary

---

This report provides the results of a lead-lag study used to calculate the working capital requirements of London Hydro's ("the Company") distribution business.

Performing a lead-lag study requires two key undertakings:

1. Developing an understanding of how the regulated distribution business operates in terms of products and services sold to customers/purchased from vendors, and the policies and procedures that govern such transactions; and,
2. Modeling such operations using data from a relevant period of time and a representative data set. It is important to ascertain and factor into the study whether (or not) there are known changes to existing business policies and procedures going forward. Where such changes are known and material, they should be factored into the study.

Results from the lead-lag study using data for calendar year 2014 identify the following working capital amount in Table 1, below.

**Table 1: Summary of Working Capital Requirements**

Year	2014
Percentage of OM&A	8.67%
Working Capital Requirement Incl. HST	\$ 35,010,605

Table 2, below summarizes the detailed working capital requirements for the test year, considering known and measurable changes calculated in the study.

**Table 2: London Hydro Distribution Working Capital Requirements (Test Year)**

Description	Revenue Lag Days	Expense Lead Days	Net Lag Days	Working Capital Factor	Expenses	Working Capital Requirements
Cost of Power	60.28	33.07	27.21	7.46%	\$ 365,958,637	\$ 27,285,731
Aggregate OM&A	60.28	10.83	49.46	13.55%	\$ 37,832,710	\$ 5,126,314
Debt Retirement Charge	60.28	33.96	26.32	7.21%	\$ 14,810,815	\$ 1,068,011
Payment in Lieu of Taxes	60.28	24.79	35.49	9.72%	\$ 1,900,000	\$ 184,741
Interest Expense	60.28	36.44	23.84	6.53%	\$ 3,009,460	\$ 196,575
<b>Total</b>					<b>\$ 423,511,621</b>	<b>\$ 33,861,373</b>
HST						\$ 1,149,232
<b>Total - Including HST</b>						<b>\$ 35,010,605</b>
<b>Working Capital as a Percent of OM&amp;A incl. Cost of Power</b>						<b>8.67%</b>

### Organization of the Report

Section 1 of the report discusses the lag times associated with London Hydro's collections of revenues. The section includes a description of the sources of revenues and how an overall revenue lag is derived.

Section 2 presents the lead times associated with London Hydro's expenses. The section includes a description of the types of expenses incurred by London Hydro's distribution operations and how expenses are treated for the purposes of deriving an overall expenses lead time.

Section 3 presents an overall summary of the results from the study.

Appendix A provides a discussion of the methodology used to determine the working capital allowance for London Hydro.

Appendix B provides detailed data tables to support the findings of the report.

## 1. Revenue Lags

A distribution utility providing service to its customers generally derives its revenue from bills paid for service by its customers. A revenue lag represents the number of days from the date service is rendered by London Hydro until the date payments are received from customers and funds are available to London Hydro.

Interviews with London Hydro personnel indicate that its distribution business receives funds from the following funding streams:

1. Retail Customers; and,
2. Other Sources (revenues from miscellaneous service charges).

Prior to January 1, 2016 London Hydro took into account the Ontario Clean Energy Benefit (OCEB) when billing customers and was reimbursed for OCEB through the settlement processes with the Independent Electricity System Operator (IESO). The OCEB ceased December 31, 2015. OCEB was removed from retail revenues in this study to reflect this known and measurable change.

Prior to January 1, 2016 London Hydro charged both residential and non-residential customers for the Debt Retirement Charge (DRC) and remitted the DRC collected from customers to the Ontario Electricity Financial Corporation (OEFC). O.Reg 156/15 exempts residential customers from paying DRC on electricity consumed after December 31, 2015. DRC was removed from residential customers' retail revenues in this study to reflect this known and measurable change.

The lag times associated with the funding streams (adjusted for known and measurable changes) were weighted and combined to calculate an overall revenue lag time as shown below. Detailed data tables are provided in Appendix B.

**Table 3: Summary of Revenue Lag**

Description	Revenues	Lag Days	Weighting	Weighted Lag
Retail Revenue	\$ 436,504,494	60.81	97.97%	59.58
Other Revenue	\$ 9,041,199	34.80	2.03%	0.71
<b>Total</b>	<b>\$ 445,545,693</b>		<b>100.00%</b>	<b>60.28</b>

**1.1 Retail Revenue Lag**

Retail Revenue lag consists of the following components:

1. Service Lag;
2. Billing Lag;
3. Collections Lag; and,
4. Payment Processing Lag.

The lag times for each of the above components, when added together, results in the Retail Revenue Lag for the purpose of calculating the working capital requirements for London Hydro's distribution business. The components are intended to represent a continuous process from the end date of the customer's previous billing cycle to the date in which the payment is available to London Hydro. Figure 1 illustrates the start and end point for each component of London Hydro's retail revenue lag.




Table 4, below summarizes the total Retail Revenue Lag.

**Table 4: Summary of Retail Revenue Lag**

Description	Lag Days
Service Lag	15.21
Billing Lag	18.00
Collections Lag	26.35
Payment Lag	1.25
<b>Total</b>	<b>60.81</b>

The estimation of each component of the Retail Revenue Lag is described below.

### 1.1.1 Service Lag

The Service Lag is the time from London Hydro's provision of electricity to a customer, to the time the customer's service period ends, which is typically defined as when the meter is read. All of London Hydro's customers have monthly billing cycles. Using the information provided, the Service Lag was estimated to be 15.21 days ( $365 \text{ days} / 12 \text{ months} / 2$ ).

### 1.1.2 Billing Lag

The Billing Lag is the time period from when the customer's service period ends, which is typically defined as when the meter is read to the time that the bill is sent to the customer. Interviews with London Hydro staff and data provided indicated that London Hydro customers have an average billing lag of 18.00 days.

### 1.1.3 Collections Lag

The Collections Lag is the time period from when the bill is posted to accounts receivable, until the time when the customer provides a payment to London Hydro. The Collections Lag is measured by analyzing the receivables aging data provided by London Hydro. London Hydro's Collection lag was calculated to be 26.35 days for London Hydro's distribution operations<sup>1</sup>.

### 1.1.4 Payment Processing Lag

The Payment Processing lag is the time period from when the customer provides a payment to London Hydro until such time as the funds associated with that payment are available to the company. The Payment Processing Lag is measured by analyzing the payment methods used by London Hydro customers. Some examples of the payment methods used include credit card, electronic and pre-authorized payment and post-dated cheque payments. London Hydro provided the processing time associated with each method of payment and the amount processed under each method of payment. Using the data provided by London Hydro a customer-weighted average payment processing lag of 1.25 days was determined for London Hydro's distribution operations.

---

<sup>1</sup> An adjustment was made to London Hydro's collections lag. London Hydro's current write-off policy is 18 months after the bill due date. Using an 18 month write-off policy would have resulted in a collection lag of 36.58 days. This result skews the results of the study to a significantly higher working capital percentage than other utilities in Ontario. For the purposes of this study, the write-off policy has been revised to 365 days after bill due date.

## 2. Expense Leads

Expense Leads are defined as the time period between when a service is provided to London Hydro and when payment is remitted for that service. Typically services are provided in advance of payment which reduces the capital requirement of the company. Therefore, in conjunction with the calculation of the revenue lag, expense lead times were calculated for the following items:

1. Cost of Power;
2. OM&A Expenses;
3. Debt Retirement Charge (DRC);
4. Payments in Lieu of Taxes; and,
5. Interest Expenses.

### 2.1 Cost of Power

---

For the purpose of the distribution lead- lag study, cost of power expenses were considered to consist of payments made by London Hydro to its vendors in the following categories:

1. Independent Electricity System Operator (IESO) Cost of Power Expenses;
2. Hydro One Cost of Power Expenses;
3. Embedded Generation; and,
4. Payments to Retailers.

Expense lead times were calculated individually for each of the items listed above and then dollar- weighted to derive a composite expense lead time of 33.07 days for cost of power expenses.

**Table 5: Summary of Cost of Power Expenses**

Description	Amounts	Expense Lead Time	Weighting	Weighted Lead Time
IESO - COP	\$ 354,570,390	32.81	96.89%	31.79
HONI COP Charges	\$ 281,186	34.21	0.08%	0.03
Embedded Generation	\$ 7,317,662	36.28	2.00%	0.73
Retailer Payments	\$ 3,789,398	50.91	1.04%	0.53
<b>Total</b>	<b>\$ 365,958,637</b>		<b>100.00%</b>	<b>33.07</b>

### 2.1.1 IESO Cost of Power Expenses

London Hydro purchases its power supply requirements on a monthly basis from the IESO and pays for such supplies on a schedule defined by the IESO's billing and settlement procedures. Using the actual cost of power payments made by London Hydro during calendar year 2014, a dollar-weighted IESO Cost of Power expense lead time of 32.81 days was calculated. Table 6 below summarizes the components of the Cost of Power expense lead calculation.

**Table 6: Summary of IESO Cost of Power Expenses**

Delivery Period	Payment Date	Amounts	Service Lead Time	Payment Lead Time	Total Lead Time	Weighting Factor %	Weighted Lead Time
Jan-14	02/19/14	\$ 35,240,355	15.50	19.00	34.50	9.94%	<b>3.43</b>
Feb-14	03/18/14	\$ 32,461,220	14.00	18.00	32.00	9.16%	<b>2.93</b>
Mar-14	04/16/14	\$ 29,995,816	15.50	16.00	31.50	8.46%	<b>2.66</b>
Apr-14	05/16/14	\$ 19,248,861	15.00	16.00	31.00	5.43%	<b>1.68</b>
May-14	06/17/14	\$ 23,770,323	15.50	17.00	32.50	6.70%	<b>2.18</b>
Jun-14	07/17/14	\$ 31,336,939	15.00	17.00	32.00	8.84%	<b>2.83</b>
Jul-14	08/19/14	\$ 31,476,600	15.50	19.00	34.50	8.88%	<b>3.06</b>
Aug-14	09/17/14	\$ 31,046,919	15.50	17.00	32.50	8.76%	<b>2.85</b>
Sep-14	10/17/14	\$ 28,918,162	15.00	17.00	32.00	8.16%	<b>2.61</b>
Oct-14	11/19/14	\$ 28,297,014	15.50	19.00	34.50	7.98%	<b>2.75</b>
Nov-14	12/16/14	\$ 28,431,603	15.00	16.00	31.00	8.02%	<b>2.49</b>
Dec-14	01/19/15	\$ 34,346,579	15.50	19.00	34.50	9.69%	<b>3.34</b>
<b>Total</b>		<b>\$ 354,570,390</b>				<b>100.00%</b>	<b>32.81</b>

### 2.1.2 Hydro One Cost of Power Expenses

London Hydro incurs and provides payment to Hydro One for Cost of Power expenses on a monthly basis. Based upon cost of power payments made by London Hydro during calendar year 2014 related to cost of power expenses during calendar year 2014, a dollar-weighted Hydro One Cost of Power expense lead time of 34.21 days was calculated. Table 7, below summarizes the components of the Hydro One Cost of Power expense lead calculation.

**Table 7: Summary of Hydro One Cost of Power Expenses**

Delivery Period	Payment Date	Amounts	Service Lead Time	Payment Lead Time	Total Lead Time	Weighting Factor %	Weighted Lead Time
Jan-14	03/06/14	\$ 34,883	15.50	34.00	49.50	12.41%	6.14
Feb-14	03/06/14	\$ 29,979	14.00	6.00	20.00	10.66%	2.13
Mar-14	04/10/14	\$ 42,342	15.50	10.00	25.50	15.06%	3.84
Apr-14	05/15/14	\$ 15,117	15.00	15.00	30.00	5.38%	1.61
May-14	06/05/14	\$ 18,069	15.50	5.00	20.50	6.43%	1.32
Jun-14	07/10/14	\$ 19,412	15.00	10.00	25.00	6.90%	1.73
Jul-14	08/07/14	\$ 21,510	15.50	7.00	22.50	7.65%	1.72
Aug-14	09/11/14	\$ 21,998	15.50	11.00	26.50	7.82%	2.07
Sep-14	10/16/14	\$ 22,423	15.00	16.00	31.00	7.97%	2.47
Oct-14	11/20/14	\$ 19,846	15.50	20.00	35.50	7.06%	2.51
Nov-14	02/05/15	\$ 19,797	15.00	67.00	82.00	7.04%	5.77
Dec-14	02/05/15	\$ 15,810	15.50	36.00	51.50	5.62%	2.90
<b>Total</b>		<b>\$ 281,186</b>				<b>100.00%</b>	<b>34.21</b>



### 2.1.3 Payments to Embedded Generation Customers

London Hydro purchases power supply from Feed-in-Tariff (FIT), micro Feed-in-Tariff (MFIT), and cogeneration customers on a monthly basis according to each customer's billing cycle. London Hydro provided transaction level data including, invoice dates, payment dates, and payment amounts. Using the data provided by London Hydro staff, a dollar-weighted expense lead time of 36.28 days was calculated.

### 2.1.4 Payments to Retailers

London Hydro remits payments to retailers for applicable revenues collected from customers on retailer billing. Note that the net payment can be positive or negative. Retailers are invoiced after the retailer customer is billed. Using invoice and payment information for each retailer transaction from calendar year 2014 and retail revenue lag components determined from the revenue analysis, a dollar-weighted expense net lead time of 50.91 days was calculated.

## 2.2 OM&A Expenses

For the purpose of the distribution lead-lag study, OM&A expenses were considered to consist of payments made by London Hydro to its employees, vendors and government in the following categories:

1. Payroll and Benefits;
2. Property Taxes; and,
3. Other Miscellaneous OM&A.

Expense lead times were calculated individually for each of the items listed above and then dollar-weighted to derive a composite expense lead time of 10.83 days for OM&A expenses.

**Table 8: Summary of OM&A Expenses**

Description	Amounts	Expense Lead Time	Weighting	Weighted Lead Time
Payroll and Benefits	\$ 23,142,117	13.75	61.17%	8.41
Property Tax	\$ 601,892	(9.62)	1.59%	(0.15)
Other OM&A	\$ 14,088,700	6.90	37.24%	2.57
<b>Total</b>	<b>\$ 37,832,710</b>		<b>100.00%</b>	<b>10.83</b>

### 2.2.1 Payroll & Benefits

The following items were considered to be expenses related to the Payroll & Benefits of London Hydro:

1. Payroll;
2. Withholdings including the Canada Pension Plan, Employment Insurance, and Income Tax withholdings;
3. Pension contributions;
4. Group Health, Group Life, and long-term disability;
5. Payments made for Employer Health Tax (EHT);
6. Payments made for the Workplace Safety and Insurance Board (WSIB); and,
7. Other benefits payments.

When all Payroll, Withholdings and Benefits were dollar-weighted using actual payment data, the weighted average expense lead time associated with Payroll & Benefits was determined to be 13.75 days as shown in Table 9, below<sup>2</sup>. Additional detail can be found in Appendix B.

**Table 9: Summary of Payroll & Benefits Expenses**

Description	Amounts	Expense Lead Time	Weighting	Weighted Lead Time
Payroll	\$ 11,521,596	7.82	49.79%	3.89
Withholdings	\$ 5,468,932	9.40	23.63%	2.22
Pensions	\$ 3,554,722	45.03	15.36%	6.92
Group Health Insurance	\$ 791,857	9.30	3.42%	0.32
Group Life Insurance	\$ 141,724	(8.06)	0.61%	(0.05)
Long-Term Disability	\$ 319,981	(3.55)	1.38%	(0.05)
EHT	\$ 364,017	7.90	1.57%	0.12
WSIB	\$ 168,768	44.40	0.73%	0.32
Other Benefits	\$ 810,519	1.36	3.50%	0.05
<b>Total</b>	<b>\$ 23,142,117</b>		<b>100.00%</b>	<b>13.75</b>

<sup>2</sup> It should be noted that the dollar amounts in the table below represent the labor and benefit costs related to expenses. Labor and benefit costs that were capitalized were not included the dollar amounts below.

### 2.2.2 Property Taxes

London Hydro remits property taxes to the City of London and payment in lieu (PIL) of property taxes to the Ontario Electricity Financing Corporation. Using payment dates during calendar year 2014 and amounts associated with London Hydro's distribution business, a dollar-weighted expense lead (-lag) time of negative 9.62 days was determined. Table 10, below summarizes the property tax expense lead calculation.

**Table 10: Summary of Property Tax Expenses**

Description	Amounts	Expense Lead Time	Weighting	Weighted Lead Time
Property Tax	\$ 539,843	(10.71)	89.69%	(9.61)
PIL Property Tax	\$ 62,049	(0.12)	10.31%	(0.01)
<b>Total</b>	<b>\$ 601,892</b>		<b>100.00%</b>	<b>(9.62)</b>

### 2.2.3 Other Miscellaneous OM&A

London Hydro provided transaction level data for calendar year 2014 from their accounts payable system under the Miscellaneous OM&A category, a dollar-weighted expense lead time of 6.90 days was derived. Table 11, below summarizes the components of miscellaneous OM&A expense lead calculation.

**Table 11: Summary of Miscellaneous OM&A Expenses**

Description	Amounts	Expense Lead Time	Weighting	Weighted Lead Time
Insurance	\$ 100,436	(150.07)	0.71%	(1.07)
Hardware and Software Prepayments	\$ 1,106,829	(179.36)	7.86%	(14.09)
Other Prepayments	\$ 847,142	(113.87)	6.01%	(6.85)
Other	\$ 11,934,292	32.98	84.71%	27.93
Rent	\$ 100,000	136.50	0.71%	0.97
<b>Total</b>	<b>\$ 14,088,700</b>		<b>100.00%</b>	<b>6.90</b>

### 2.3 Debt Retirement Charge (DRC)

London Hydro makes payments for the debt retirement charge on a monthly basis to the Ontario Electricity Financial Corporation. O.Reg 156/15 exempts residential customers from paying DRC on electricity consumed after December 31, 2015. This has been modeled as a known and measurable change and only DRC to non-residential customers is included in the model. Using payment amounts that were made during calendar year 2014, a dollar-weighted expense lead time of 33.96 days was determined for DRC. Table 12, below summarizes the components of the DRC expense lead calculation.

**Table 12: Summary of DRC Expenses**

Delivery Period	Payment Date	Amounts	Service Lead Time	Payment Lead Time	Total Lead Time	Weighting Factor %	Weighted Lead Time
Dec-13	1/20/2014	\$ 1,177,816	15.50	20.00	35.50	7.95%	2.82
Jan-14	2/18/2014	\$ 1,244,580	15.50	18.00	33.50	8.40%	2.82
Feb-14	3/18/2014	\$ 1,240,933	14.00	18.00	32.00	8.38%	2.68
Mar-14	4/21/2014	\$ 1,269,387	15.50	21.00	36.50	8.57%	3.13
Apr-14	5/20/2014	\$ 1,213,350	15.00	20.00	35.00	8.19%	2.87
May-14	6/18/2014	\$ 1,138,320	15.50	18.00	33.50	7.69%	2.57
Jun-14	7/18/2014	\$ 1,238,469	15.00	18.00	33.00	8.36%	2.76
Jul-14	8/18/2014	\$ 1,182,927	15.50	18.00	33.50	7.99%	2.68
Aug-14	9/18/2014	\$ 1,429,798	15.50	18.00	33.50	9.65%	3.23
Sep-14	10/20/2014	\$ 1,297,847	15.00	20.00	35.00	8.76%	3.07
Oct-14	11/18/2014	\$ 1,230,922	15.50	18.00	33.50	8.31%	2.78
Nov-14	12/18/2014	\$ 1,146,466	15.00	18.00	33.00	7.74%	2.55
<b>Total</b>		<b>\$ 14,810,815</b>				<b>100.00%</b>	<b>33.96</b>

## 2.4 Payment in Lieu of Taxes (PILs)

London Hydro makes payments in lieu of taxes in monthly installments to the relevant taxing authorities. Using payment amounts that were made during calendar year 2014, a dollar-weighted expense lead time of 24.79 days was determined for PILs. Table 13, below summarizes the components of the PILs expense lead calculation.

**Table 13: Summary of PILs Expenses**

Delivery Period	Payment Date	Amounts	Service Lead Time	Payment Lead Time	Total Lead Time	Weighting Factor %	Weighted Lead Time
Jan-14	1/23/2014	\$ 130,000	182.50	(342.00)	(159.50)	6.84%	(10.91)
Feb-14	2/20/2014	\$ 130,000	182.50	(314.00)	(131.50)	6.84%	(9.00)
Mar-14	3/20/2014	\$ 130,000	182.50	(286.00)	(103.50)	6.84%	(7.08)
Apr-14	4/17/2014	\$ 130,000	182.50	(258.00)	(75.50)	6.84%	(5.17)
May-14	5/22/2014	\$ 130,000	182.50	(223.00)	(40.50)	6.84%	(2.77)
Jun-14	6/19/2014	\$ 150,000	182.50	(195.00)	(12.50)	7.89%	(0.99)
Jul-14	7/24/2014	\$ 150,000	182.50	(160.00)	22.50	7.89%	1.78
Aug-14	8/21/2014	\$ 150,000	182.50	(132.00)	50.50	7.89%	3.99
Sep-14	9/25/2014	\$ 200,000	182.50	(97.00)	85.50	10.53%	9.00
Oct-14	11/5/2014	\$ 200,000	182.50	(56.00)	126.50	10.53%	13.32
Nov-14	11/21/2014	\$ 200,000	182.50	(40.00)	142.50	10.53%	15.00
Dec-14	12/16/2014	\$ 200,000	182.50	(15.00)	167.50	10.53%	17.63
<b>Total</b>		<b>\$ 1,900,000</b>				<b>100.00%</b>	<b>24.79</b>

## 2.5 Interest on Short-Term and/or Long-Term Debt

London Hydro provided information regarding payments made four debt instruments in calendar year 2014 specifying known and measurable changes in unsecured loans. Taking into account the long term and short term debt instruments and known and measurable changes, a dollar-weighted expense lead time of 36.44 days was determined for calendar year 2014.

**Table 14: Summary of Interest Expenses**

Description	Amounts	Expense Lead Time	Weighting	Weighted Lead Time
Operating Line	\$ 60,413	14.97	2.01%	0.30
Smart Meter, Unsecured Loan	\$ 401,512	(15.90)	13.34%	(2.12)
Unsecured Loan	\$ 2,443,808	45.63	81.20%	37.05
Revolving Loan Payments	\$ 103,726	35.23	3.45%	1.21
<b>Total</b>	<b>\$ 3,009,460</b>		<b>100.00%</b>	<b>36.44</b>

### 3. Harmonized Sales Tax (HST)

The expense lead times associated with the following items that attract HST were considered in London Hydro's distribution lead-lag study.

1. Revenues;
2. Cost of Power; and,
3. OM&A<sup>3</sup>.

A summary of the expense lead times and working capital amounts associated with each of the above items is provided in Table 15. Note that the statutory approach described in Appendix A was used to determine the expense lead times associated with London Hydro's remittances and disbursements of HST (i.e., remittances are generally on the last day of the month following the date of the applicable return).

*Table 15: Summary of HST Working Capital Factors*

Description	HST Lead Time	Working Capital Factor	Working Capital Requirement
Revenue	(29.61)	-8.11%	\$ (4,698,270)
Cost of Power	43.16	11.82%	\$ 5,625,616
Misc. OM&A Expenses	44.54	12.20%	\$ 221,886

---

<sup>3</sup> Costs within OM&A that attract HST include Other OM&A (hardware and software prepayments, other prepayments, and other).

## 4. Conclusions

Using the revenue lags and expense leads developed in the previous sections and London Hydro's calendar year 2014 distribution revenues and expenses (adjusted for known and measurable changes) the overall working capital requirements were calculated. Table 16 summarizes the working capital requirements for 2014 calculated in the study.

**Table 16: London Hydro Distribution Working Capital Requirements (2014)**

Description	Revenue Lag Days	Expense Lead Days	Net Lag Days	Working Capital Factor	Expenses	Working Capital Requirements
Cost of Power	60.28	33.07	27.21	7.46%	\$ 365,958,637	\$ 27,285,731
Aggregate OM&A	60.28	10.83	49.46	13.55%	\$ 37,832,710	\$ 5,126,314
Debt Retirement Charge	60.28	33.96	26.32	7.21%	\$ 14,810,815	\$ 1,068,011
Payment in Lieu of Taxes	60.28	24.79	35.49	9.72%	\$ 1,900,000	\$ 184,741
Interest Expense	60.28	36.44	23.84	6.53%	\$ 3,009,460	\$ 196,575
Total					\$ 423,511,621	\$ 33,861,373
HST						\$ 1,149,232
<b>Total - Including HST</b>						<b>\$ 35,010,605</b>
<b>Working Capital as a Percent of OM&amp;A incl. Cost of Power</b>						<b>8.67%</b>



## Appendix A. Working Capital Methodology

Working capital is the amount of funds that are required to finance the day- to- day operations of a regulated utility and which are included as part of a rate base for ratemaking purposes. A lead-lag study is the most accurate basis for determination of working capital and was used by Navigant for this purpose.

A lead-lag study analyzes the time between the date customers receive service and the date that customers' payments are available to London Hydro (or "lag") together with the time between which London Hydro receives goods and services from its vendors and pays for them at a later date (or "lead")<sup>4</sup>. "Leads" and "Lags" are both measured in days and are dollar- weighted where appropriate.<sup>5</sup> The dollar- weighted net lag (lag minus lead) days is then divided by 365 (or 366 for leap years) and then multiplied by the annual test year expenses to determine the amount of working capital required. The resulting amount of working capital is then included in London Hydro's rate base for the purpose of deriving revenue requirements.

### A.1 Key Concepts

---

Two key concepts need to be defined as they appear throughout the report:

#### Mid-Point Method

When a service is provided to (or by) London Hydro over a period of time, the service is deemed to have been provided (or received) evenly over the midpoint of the period, unless specific information regarding the provision (or receipt) of that service indicates otherwise. If both the service end date ("Y") and the service start date ("X") are known, the mid-point of a service period can be calculated using the formula:

$$\text{Mid-Point} = \frac{([Y-X]+1)}{2}$$

When specific start and end dates are unknown, but it is known that a service is evenly distributed over the mid-point of a period, an alternative formula that is generally used is shown below. The formula uses the number of days in a year (A) and the number of periods in a year (B):

$$\text{Mid-Point} = \frac{A/B}{2}$$

#### Statutory Approach

In conjunction with the mid-point method, it is important to note that not all areas of the study may utilize dates on which actual payments were made to (or by) London Hydro. In some instances, particularly for the HST, the due dates for payments are established by statute or

---

<sup>4</sup> A positive lag (or lead) indicates that payments are received (or paid for) after the provision of a good or service.

<sup>5</sup> The notion of dollar-weighting is pursued further in the sub-section titled "Key Concepts".

by regulation with significant penalties for late payments. In these instances, the due date established by statute has been used in lieu of when payments were actually made.

## **Expense Lead Components**

As used in the study, Expense Leads are defined to consist of two components:

1. Service Lead component (services are assumed to be provided to London Hydro evenly around the mid-point of the service period), and
2. Payment Lead component (the time period from the end of the service period to the time payment was made and when funds have left London Hydro's possession).

## **Dollar Weighting**

Both leads and lags should be dollar-weighted where appropriate and where data is available to accurately reflect the flow of dollars. For example, suppose that a particular transaction has a lead time of 100 days and has a dollar value of \$100. Further, suppose that another transaction has a lead time of 30 days with a dollar value of \$1 Million. A simple un-weighted average of the two transactions would give us a lead time of 65 days  $([100+30]/2)$ . However, when these two transactions are dollar weighted, the resulting lead time would be closer to 30 days which is more representative of how the dollars actually flow.

## **A.2 Methodology**

---

Performing a lead-lag study requires two key undertakings:

1. Developing an understanding of how the regulated distribution business operates in terms of products and services sold to customers/purchased from vendors, and the policies and procedures that govern such transactions; and,
2. Modeling such operations using data from a relevant period of time and a representative data set. It is important to ascertain and factor into the study whether (or not) there are known changes to existing business policies and procedures going forward. Where such changes are known and material, they should be factored into the study.

To develop an understanding of London Hydro's operations, interviews with London Hydro staff were conducted. Key questions that were addressed during the course of the interviews included:

1. What is being sold (or purchased)? If a service is being provided to (or by) London Hydro, over what time period was this service provided;
2. Who are the buyers (or sellers);
3. What are the terms for payment? Are the terms for payment driven by industry norms or by company policy? Is there flexibility in the terms for payment;
4. Are any changes to the terms for payment expected? Are these terms driven by industry or internally? What is the basis for any such changes;
5. Are there any new rules or regulations governing transactions relating to distribution operations that are expected to materialize over the time frame considered in this report; and,
6. How are payments made (or received)? Payment types have different payment lead times (i.e., internet payments have shorter deposit times than cheque deposit times)

## Appendix B. Detailed Data Tables

### B.1 Other Revenues

Description	Amounts	Revenue Lag Time	Weighting	Weighted Lead Time
Interest	\$ 174,813	60.81	1.93%	1.18
Late Payment Charges	\$ 1,739,022	42.81	19.23%	8.23
Collection Charges	\$ 691,645	22.17	7.65%	1.70
Occupancy Charges	\$ 594,327	42.81	6.57%	2.81
Customer billing service fees	\$ 592,065	42.81	6.55%	2.80
Pole Rentals	\$ 357,678	50.38	3.96%	1.99
Other Miscellaneous Rev	\$ 987,999	40.96	10.93%	4.48
Water Cost Recoveries	\$ 3,903,650	26.88	43.18%	11.60
<b>Total</b>	<b>\$ 9,041,199</b>		<b>100.00%</b>	<b>34.80</b>

### B.2 Payroll, Withholdings and EHT

Description	Amounts	Expense Lead Time	Weighting	Weighted Lead Time
Payroll	\$ 11,521,596	7.82	66.39%	5.19
Withholdings	\$ 5,468,932	9.41	31.51%	2.97
EHT	\$ 364,017	7.90	2.10%	0.17
<b>Total</b>	<b>\$ 17,354,545</b>		<b>100.00%</b>	<b>22.48</b>

### B.3 Pensions

Delivery Period	Payment Date	Amounts	Service Lead Time	Payment Lead Time	Total Lead Time	Weighting Factor %	Weighted Lead Time
Jan-14	02/28/14	\$ 268,180	15.50	28.00	43.50	7.54%	3.28
Feb-14	03/31/14	\$ 265,809	14.00	31.00	45.00	7.48%	3.36
Mar-14	04/30/14	\$ 264,730	15.50	30.00	45.50	7.45%	3.39
Apr-14	05/30/14	\$ 276,903	15.00	30.00	45.00	7.79%	3.51
May-14	06/30/14	\$ 337,439	15.50	30.00	45.50	9.49%	4.32
Jun-14	07/31/14	\$ 268,342	15.00	31.00	46.00	7.55%	3.47
Jul-14	08/29/14	\$ 331,847	15.50	29.00	44.50	9.34%	4.15
Aug-14	09/30/14	\$ 263,199	15.50	30.00	45.50	7.40%	3.37
Sep-14	10/31/14	\$ 262,743	15.00	31.00	46.00	7.39%	3.40
Oct-14	11/28/14	\$ 326,358	15.50	28.00	43.50	9.18%	3.99
Nov-14	12/30/14	\$ 260,198	15.00	30.00	45.00	7.32%	3.29
Dec-14	01/30/15	\$ 428,974	15.50	30.00	45.50	12.07%	5.49
<b>Total</b>		<b>\$ 3,554,722</b>				<b>100.00%</b>	<b>45.03</b>

## B.4 Group Health Insurance

Delivery Period	Payment Date	Amounts	Service Lead Time	Payment Lead Time	Total Lead Time	Weighting Factor %	Weighted Lead Time
Jan-14	12/19/13	\$ 66,160	15.50	(43.00)	(27.50)	8.35%	(2.30)
Feb-14	02/27/14	\$ 65,294	14.00	(1.00)	13.00	8.25%	1.07
Mar-14	03/27/14	\$ 64,800	15.50	(4.00)	11.50	8.18%	0.94
Apr-14	05/01/14	\$ 66,840	15.00	1.00	16.00	8.44%	1.35
May-14	05/29/14	\$ 68,159	15.50	(2.00)	13.50	8.61%	1.16
Jun-14	06/26/14	\$ 65,746	15.00	(4.00)	11.00	8.30%	0.91
Jul-14	07/31/14	\$ 66,657	15.50	-	15.50	8.42%	1.30
Aug-14	08/28/14	\$ 66,385	15.50	(3.00)	12.50	8.38%	1.05
Sep-14	10/02/14	\$ 65,496	15.00	2.00	17.00	8.27%	1.41
Oct-14	10/30/14	\$ 65,674	15.50	(1.00)	14.50	8.29%	1.20
Nov-14	11/27/14	\$ 65,612	15.00	(3.00)	12.00	8.29%	0.99
Dec-14	12/18/14	\$ 65,036	15.50	(13.00)	2.50	8.21%	0.21
<b>Total</b>		<b>\$ 791,857</b>				<b>100.00%</b>	<b>9.30</b>

## B.5 Group Life Insurance

Delivery Period	Payment Date	Amounts	Service Lead Time	Payment Lead Time	Total Lead Time	Weighting Factor %	Weighted Lead Time
Jan-14	01/13/14	\$ 11,395	15.50	(18.00)	(2.50)	8.04%	(0.20)
Feb-14	02/07/14	\$ 11,980	14.00	(21.00)	(7.00)	8.45%	(0.59)
Mar-14	03/07/14	\$ 11,503	15.50	(24.00)	(8.50)	8.12%	(0.69)
Apr-14	04/04/14	\$ 11,995	15.00	(26.00)	(11.00)	8.46%	(0.93)
May-14	05/07/14	\$ 11,959	15.50	(24.00)	(8.50)	8.44%	(0.72)
Jun-14	06/09/14	\$ 11,656	15.00	(21.00)	(6.00)	8.22%	(0.49)
Jul-14	07/08/14	\$ 11,795	15.50	(23.00)	(7.50)	8.32%	(0.62)
Aug-14	08/06/14	\$ 11,803	15.50	(25.00)	(9.50)	8.33%	(0.79)
Sep-14	09/05/14	\$ 11,766	15.00	(25.00)	(10.00)	8.30%	(0.83)
Oct-14	10/08/14	\$ 11,775	15.50	(23.00)	(7.50)	8.31%	(0.62)
Nov-14	11/11/14	\$ 12,080	15.00	(19.00)	(4.00)	8.52%	(0.34)
Dec-14	12/01/14	\$ 12,017	15.50	(30.00)	(14.50)	8.48%	(1.23)
<b>Total</b>		<b>\$ 141,724</b>				<b>100.00%</b>	<b>(8.06)</b>

## B.6 Long-term Disability

Delivery Period	Payment Date	Amounts	Service Lead Time	Payment Lead Time	Total Lead Time	Weighting Factor %	Weighted Lead Time
Jan-14	01/16/14	\$ 25,726	15.50	(15.00)	0.50	8.04%	0.04
Feb-14	02/13/14	\$ 26,927	14.00	(15.00)	(1.00)	8.42%	(0.08)
Mar-14	03/13/14	\$ 26,008	15.50	(18.00)	(2.50)	8.13%	(0.20)
Apr-14	04/10/14	\$ 27,026	15.00	(20.00)	(5.00)	8.45%	(0.42)
May-14	05/15/14	\$ 26,935	15.50	(16.00)	(0.50)	8.42%	(0.04)
Jun-14	06/12/14	\$ 26,550	15.00	(18.00)	(3.00)	8.30%	(0.25)
Jul-14	07/10/14	\$ 26,849	15.50	(21.00)	(5.50)	8.39%	(0.46)
Aug-14	08/07/14	\$ 26,777	15.50	(24.00)	(8.50)	8.37%	(0.71)
Sep-14	09/11/14	\$ 26,701	15.00	(19.00)	(4.00)	8.34%	(0.33)
Oct-14	10/09/14	\$ 26,512	15.50	(22.00)	(6.50)	8.29%	(0.54)
Nov-14	11/13/14	\$ 27,017	15.00	(17.00)	(2.00)	8.44%	(0.17)
Dec-14	12/11/14	\$ 26,955	15.50	(20.00)	(4.50)	8.42%	(0.38)
<b>Total</b>		<b>\$ 319,981</b>				<b>100.00%</b>	<b>(3.55)</b>

## B.7 WSIB

Delivery Period	Payment Date	Amounts	Service Lead Time	Payment Lead Time	Total Lead Time	Weighting Factor %	Weighted Lead Time
Jan-14	02/28/14	\$ 14,034	15.50	28.00	43.50	8.32%	3.62
Feb-14	03/28/14	\$ 13,957	14.00	28.00	42.00	8.27%	3.47
Mar-14	04/30/14	\$ 13,983	15.50	30.00	45.50	8.29%	3.77
Apr-14	05/30/14	\$ 14,247	15.00	30.00	45.00	8.44%	3.80
May-14	06/27/14	\$ 18,427	15.50	27.00	42.50	10.92%	4.64
Jun-14	07/31/14	\$ 14,970	15.00	31.00	46.00	8.87%	4.08
Jul-14	08/29/14	\$ 18,196	15.50	29.00	44.50	10.78%	4.80
Aug-14	09/30/14	\$ 14,482	15.50	30.00	45.50	8.58%	3.90
Sep-14	10/31/14	\$ 13,278	15.00	31.00	46.00	7.87%	3.62
Oct-14	11/28/14	\$ 14,365	15.50	28.00	43.50	8.51%	3.70
Nov-14	12/30/14	\$ 9,389	15.00	30.00	45.00	5.56%	2.50
Dec-14	01/29/15	\$ 9,441	15.50	29.00	44.50	5.59%	2.49
<b>Total</b>		<b>\$ 168,768</b>				<b>100.00%</b>	<b>44.40</b>

## B.8 Other Benefits

Description	Amounts	Expense Lead Time	Weighting	Weighted Lead Time
Retiree (GS)	\$ 170,020	(17.49)	20.98%	(3.67)
Retiree (DFS)	\$ 189,612	(3.48)	23.39%	(0.81)
Retiree Benefits	\$ 287,295	12.80	35.45%	4.54
OHIP	\$ 129,560	6.47	15.98%	1.03
Maternity Top Up	\$ 34,033	6.51	4.20%	0.27
<b>Total</b>	<b>\$ 810,519</b>		<b>100.00%</b>	<b>1.36</b>



## Appendix C. Expert Information

Ralph Zarumba, Director in the Energy Practice at Navigant Consulting, specializes in Regulatory Matters. Mr. Zarumba oversees that part of Navigant's Energy Practices specializing in retail regulatory matters. Mr. Zarumba has appeared as an expert in several dozen regulatory proceedings in Canada and the United States.

Business address: 30 South Wacker Drive, Suite 3100, Chicago, IL 60606

Navigant has previously undertaken or supported numerous lead-lag studies across North America and for several of Ontario's electricity local distribution companies (LDCs) including Hydro One, Toronto Hydro, Horizon Utilities, London Hydro, London Hydro and others. Navigant lead-lag reports have been submitted by many of these other clients as evidence to support their rate submissions, and our approach and findings have been accepted, in large part, by the OEB and interveners. Some examples of recent lead-lag studies conducted by Navigant where Mr. Zarumba was the projected manager which have been filed with the OEB by Ontario utilities are outlined below.

**Table 17: Recent Navigant Lead-Lag Studies (Ontario)**

Utility	Reference
<b>Toronto Hydro-Electric System Limited</b>	EB-2014-0116 Exhibit 2A, Tab 3, Schedule 2
<b>Hydro One Networks Inc. (distribution)</b>	EB-2013-0141 Exhibit D1, Tab 1, Schedule 3
<b>Hydro One Networks Inc. (transmission)</b>	EB-2012-0031 Exhibit D1, Tab 1, Schedule 3, Attachment 1
<b>Horizon Utilities</b>	EB-2014-0002 Exhibit 2, Tab 4, Schedule 1
<b>North Bay Hydro</b>	EB-2014-0099, Correspondence
<b>Entegrus Powerlines Inc.</b>	EB-2015-0061, Exhibit 2, Attachment 2-B
<b>Kingston Hydro</b>	EB-2015-0083
<b>Hydro Ottawa</b>	EB-2015-0004

## Ralph Zarumba

### Director

Ralph.zarumba@navigant.com

30 S. Wacker Drive, Chicago, IL 60606

Mobile: 312.342.4387

### Professional Summary

Ralph Zarumba is a Director in the Energy Practice with 30 years of experience specializing in regulatory issues and economic analysis associated with energy utilities in North America, Europe and Asia. Mr. Zarumba has appeared as an expert witness in a number of regulatory and legal proceedings addressing electric generation, transmission and distribution issues, unregulated operations of utility holding companies, asset valuation and regulatory treatment of Smart Grid investments.

He has also assisted clients in other matters including Depreciation Studies, Transfer Pricing Mechanisms and evaluation of the results of competitive bidding for electric generation services. These testimonies have been presented before the Nova Scotia Utility and Review Board, the Federal Energy Regulatory Commission ("FERC"), the Massachusetts Department of Public Utilities, the Rhode Island Public Utilities Commission, the Illinois Commerce Commission, the Wisconsin Public Service Commission, the Ontario Energy Board, the New York Public Service Commission, the New Mexico Public Regulation Commission, the Kansas Corporation Commission as well as a number of other venues.

Mr. Zarumba has provided a number of papers and presentations on various regulatory and market analysis issues.

### Recent Whitepapers

- » White Paper Prepared for the Ontario Energy Board on Approaches to Rate Mitigation for Transmitters and Distributors

[http://www.ontarioenergyboard.ca/OEB/\\_Documents/EB-2010-0378/EB-2010-0378\\_Navigant\\_Report.pdf](http://www.ontarioenergyboard.ca/OEB/_Documents/EB-2010-0378/EB-2010-0378_Navigant_Report.pdf)

- » White Paper Prepared for the Ontario Energy Board Cost addressing Distributor Efficiency

[http://www.ontarioenergyboard.ca/OEB/\\_Documents/EB-2012-0397/Navigant\\_Report\\_Elect-Dist-Efficiency\\_20130225.pdf](http://www.ontarioenergyboard.ca/OEB/_Documents/EB-2012-0397/Navigant_Report_Elect-Dist-Efficiency_20130225.pdf)

- » White Paper Prepared for the Ontario Energy Board Cost addressing Cost Assessment Models for Regulators

[http://www.rds.ontarioenergyboard.ca/webdrawer/webdrawer.dll/webdrawer/rec/319593/view/Cost%20Assessment%20Model%20Report\\_Jan%2013%202011\\_20120116pdf.PDF](http://www.rds.ontarioenergyboard.ca/webdrawer/webdrawer.dll/webdrawer/rec/319593/view/Cost%20Assessment%20Model%20Report_Jan%2013%202011_20120116pdf.PDF)

## Ralph Zarumba

Director

- » Economic Issues Related to Tariff Development (with Thomas Welch)  
<http://www.erranet.org/index.php?name=OE-eLibrary&file=download&id=6052&keret=N&showheader=N>

### Recent Publications

- » Public Utilities Fortnightly “Pricing Social Benefits - Calculating and allocating costs for non-traditional utility services” Ralph Zarumba, Benjamin Grunfeld and Koby Bailey, August 2013
- » American Gas “Modernization: The Quest for 21st Century Utilities” Ralph Zarumba and Peter Haapaniemi, November 2012
- » Public Utilities Fortnightly “Pre-Funding to Mitigate Rate Shock” Sherman Elliot and Ralph Zarumba, September 2012

### Professional Experience

#### Cost of Service

- » Provided testimony in the proceedings reviewing the 2014 Nova Scotia Power Cost-of-Service study (NSPI-P-892-/M05473).
- » Prepared and sponsored before the FERC a cost-of-service filing supporting a Reliability Must-Run filing on the Cayuga Operating Company.
- » Managed a project team which completed a Remaining Life Study for the Western Minnesota Municipal Power Agency.
- » For a confidential client reviewed the cost-of-service application for a natural gas distributor in Central Canada.

## Ralph Zarumba

Director

### Regulatory and Pricing

- » Assisted the Ontario Energy in formulating a regulatory process and pricing design for Revenue Decoupling.
- » Prepared a white paper on rate mitigation mechanisms for the Ontario Energy Board.
- » Prepared a white paper for the Ontario Energy Board on apportionment of regulatory commission costs to various stakeholders.
- » Prepared a number of working capital studies for various distributors and transmitters in the Province of Ontario.
- » Prepare a functional cost separation study for a regulated electric utility in Ontario.
- » For a confidential client prepared a benchmarking analysis of the costs of regulatory proceedings associated with the introduction of new electric generation.
- » Prepared an analysis of the pricing of voluntary renewable energy products for a Midwestern public power association.
- » Led a team that prepared a cost of service, rate design, legal evaluation and financial analysis for the Puerto Rico Electric Power Authority.
- » Performed a Pricing Strategy for the South Carolina Public Service Company (Santee Cooper).
- » Prepared a financial plan, electric rate design and phase-in plan for a new electric generation plan for Fayetteville (North Carolina) Public Works Commission.
- » Assisted Commonwealth Edison Company in their Electric Rate Request (Illinois Commerce Commission Docket No. 10-467).
- » Prepared proposals for Retail Conjunctive Billing Pricing filed in Illinois and Wisconsin which were filed before the Illinois Commerce Commission and the Wisconsin Public Service Commission.
- » Developed the Wisconsin Electric Power Company's first Curtailable Electric Tariff available to commercial customers.
- » Negotiated complex service contracts with thermal energy customers which led to a major expansion of the Wisconsin Electric Steam System.

## Ralph Zarumba

### Director

- » Assisted Indianapolis Power & Light in preparing a cost recovery plan for Energy Efficiency and Demand Side Management Expenditures.
- » Trained regulatory staffs in the Republic of Macedonia, Bosnia and Herzegovina, Croatia and Albania.
- » Prepared proposals for ancillary services pricing based upon market-based mechanisms for San Diego Gas and Electric Company.
- » Completed the development of wholesale and retail rate designs for a southeastern G&T, an analysis of stranded cost exposure for a northeastern utility, and prepared a strategic plan for a large municipal utility.
- » Developed a proposal for electric generation transfer pricing that would be used as a transition mechanism between the existing vertically integrated utility and a deregulated environment.
- » Filed testimony in Wisconsin proposing that state's first Demand Response Program.

### Demand Response

- » Assisted the Building Owners and Managers of Chicago (BOMA/Chicago) develop a program where they can bid demand response based ancillary services into the PJM market.
- » Prepared a presentation for the Public Utilities Commission of Ohio on Commercial and Industrial Dynamic Pricing and Demand Response in an unregulated regulatory environment.

### Electric Transmission

- » Assisted the Long Island Power Authority to purchase distribution, transmission and regulatory assets and prepared its non-jurisdictional open-access transmission tariff.
- » Prepared the pricing portion of a FERC open access tariff (Docket No. ER96-96-43.000) for San Diego Gas and Electric Company; testified on revenue requirements and pricing including opportunity costs.

### Generation Market Analysis

- » For a major public power generation owner prepared a strategy of internal coal versus natural gas generation dispatch protocols including the treatment of liquidated damages.

## Ralph Zarumba

### Director

- » Co-authored a report for Nalcor on the feasibility and economics of the proposed development of the Lower Churchill Hydroelectric project.
- » Prepared a number of electric market price forecasts for many regions of the United States and Central America.
- » Supported the electric pricing and infrastructure analysis for a Least-Cost Resource Plan for San Diego County.
- » Prepared an analysis of the saturation of coal-fired electric generation technology in the Western Electric Coordinating Council.
- » Developed a long-run electric expansion plan for the Railbelt System in Alaska.
- » Managed a team that prepared a long-term capacity and energy forecast for a medium-sized municipal utility.
- » For Manitowoc Public Utilities prepared a resource plan evaluating various generation expansion options.

### Merger, Acquisition and Divesture

- » On behalf of the Minnesota Public Service Commission. Mr. Zarumba co-authored an analysis of the merger savings associated with the proposed Primergy Merger (the proposed combination of Northern States Power and Wisconsin Energy). The analysis included a detailed review of cost savings that would emanate from the merger and regulatory commitments made by the companies to regulatory authorities in Minnesota.
- » The Ontario Energy Board desired to identify factors that potentially impede the combination of regulated distributors in that province. Mr. Zarumba co-authored a study which identified those factors and discussed policies in other jurisdictions.
- » For the Manitowoc Public Utilities prepared an analysis that evaluated the divesture of its transmission assets to the American Transmission Company.

## Ralph Zarumba

Director

### International

- » Currently assisting the Israel Public Utility Authority is electric tariff reviews for the Israel Electric Company and the Jerusalem District Electric Company.
- » Mr. Zarumba assisted the electric regulator in the Republic of Macedonia with various regulatory issues including pricing design, revenue requirements and privatization issues. Included in the assistance was the development of market designs for the electricity sector.
- » Completed a tariff implementation plan proposal for the privatization of the distribution companies of the Bulgarian Electric Utility.
- » Led a team to implement regulatory procedures and methodology for the electric power industry in Bosnia and Herzegovina.
- » Conducted a study of the electric power market in El Salvador including a quantification of the level of generation market power using the Lerner Index.

### Work History

Director, Navigant Consulting  
Director, Science Applications International Corporation  
President, Zarumba Consulting  
Management Consultant, Sargent & Lundy Consulting Group  
President, Analytical Support Network, Inc.  
Manager, Pricing Practice, Synergic Resources Corporation  
Senior Analyst – San Diego Gas & Electric Company  
Senior Analyst – Wisconsin Electric Power Company  
Analyst 4 – Eastern Utilities Associates  
Analyst – Illinois Power Company

### Education

MA, Economics	DePaul University, Chicago, IL
BS, Economics	Illinois State University, Normal, IL



*This page is intentionally left blank*



## **Appendix 2-4: New Policy Options for the Funding of Capital**

---



Ontario Energy Board

# Capital Module

## Applicable to ACM and ICM

Note: Depending on the selections made below, certain worksheets in this workbook will be hidden.

Version 3.01

Utility Name London Hydro Inc.

Service Territory (if filing more than one model)

Assigned EB Number EB-2016-0091

Name of Contact and Title Martin Benum, Director of Regulatory Affairs

Phone Number 519-661-5800 x5750

Email Address benumm@londonhydro.com

Is this Capital Module being filed in a CoS or Price-Cap IR Application? COS Rate Year 2017

London Hydro Inc. is applying for: ACM Approval

Last COS OEB Application Number EB-2012-0146

The most recent complete year for which actual billing and load data exists 2015

Current IPI 2.10%

Stretch Factor Assigned to Middle Cohort III

Stretch Factor Value 0.30%

Price Cap Index 1.80%

Based on the inputs above, the growth factor utilized in the Materiality Threshold Calculation will be determined by: 2017 Test Year Distribution Revenues / 2015 Actual Distribution Revenues

### Notes

Pale green cells represent input cells.

Pale blue cells represent drop-down lists. The applicant should select the appropriate item from the drop-down list.

White cells contain fixed values, automatically generated values or formulae.

This Workbook Model is protected by copyright and is being made available to you solely for the purpose of filing your ICM application. You may use and copy this model for that purpose, and provide a copy of this model to any person that is advising or assisting you in that regard. Except as indicated above, any copying, reproduction, publication, sale, adaptation, translation, modification, reverse engineering or other use or dissemination of this model without the express written consent of the Ontario Energy Board is prohibited. If you provide a copy of this model to a person that is advising or assisting you in preparing the application or reviewing your draft rate order, you must ensure that the person understands and agrees to the restrictions noted above.



Ontario Energy Board

# Capital Module

## Applicable to ACM and ICM

London Hydro Inc.

Select the appropriate rate classes as they appear on your most recent Board-Approved Tariff of Rates and Charges, excluding the MicroFit Class.

How many classes are on your most recent Board-Approved Tariff of Rates and Charges?

9

Select Your Rate Classes from the **Blue Cells** below. Please ensure that a rate class is assigned to **each shaded cell**.

	<b>Rate Class Classification</b>
1	RESIDENTIAL
2	GENERAL SERVICE LESS THAN 50 KW
3	GENERAL SERVICE 50 TO 4,999 KW
4	GENERAL SERVICE 50 TO 4,999 KW (COGENERATION)
5	STANDBY POWER
6	LARGE USE
7	STREET LIGHTING
8	SENTINEL LIGHTING
9	UNMETERED SCATTERED LOAD

# Capital Module

## Applicable to ACM and ICM

London Hydro Inc.

Input the billing determinants and base distribution rates associated with London Hydro Inc.'s 2017 Test Year Distribution Revenues. Sheets 4 & 5 calculate the NUMERATOR portion of the growth factor calculation.

Rate Class	Units	2017 Test Year Distribution Revenues			2017 Test Year Distribution Revenues		
		Billed Customers or Connections	Billed kWh	Billed kW (if applicable)	Monthly Service Charge	Distribution Volumetric Rate kWh	Distribution Volumetric Rate kW
RESIDENTIAL	\$/kWh	142,509	1,068,671,798		20.11	0.0082	0.0000
GENERAL SERVICE LESS THAN 50 KW	\$/kWh	12,999	371,911,863		32.88	0.0109	0.0000
GENERAL SERVICE 50 TO 4,999 KW	\$/kW	1,611	1,486,650,047	3,778,018	162.33	0.0000	2.7963
GENERAL SERVICE 50 TO 4,999 KW (COGENERATION)	\$/kW	4	34,191,555	65,844	2650.00	0.0000	4.6482
STANDBY POWER	\$/kW			154,800	0.00	0.0000	3.2101
LARGE USE	\$/kW	1	82,923,505	159,628	21350.00	0.0000	2.3178
STREET LIGHTING	\$/kW	35,912	19,502,488	54,607	1.71	0.0000	8.8279
SENTINEL LIGHTING	\$/kW	599	706,221	1,907	3.77	0.0000	12.4297
UNMETERED SCATTERED LOAD	\$/kWh	1,537	5,464,035		2.25	0.0195	0.0000

# Capital Module

## Applicable to ACM and ICM

London Hydro Inc.

Calculation of 2017 Revenue Requirement. No input required.

### 2017 Test Year Distribution Revenues

Rate Class	Billed Customers or Connections	Billed kWh	Billed kW (if applicable)	Monthly Service Charge	Distribution Volumetric Rate kWh	Distribution Volumetric Rate kW	Service Charge Revenue	Distribution Volumetric Rate Revenue kWh	Distribution Volumetric Rate Revenue kW	Revenue Requirement from Rates	Service Charge % Revenue	Distribution Volumetric Rate % kWh	Distribution Volumetric Rate % kW	Total % Revenue
	A	B	C	D	E	F	G = A * D * 12	H = B * E	I = C * F	J = G + H + I	K = G / J	L = H / J	M = I / J	N = J / R
RESIDENTIAL	142,509	1,068,671,798		20.11	0.0082	0.0000	34,390,272	8,763,109	0	43,153,381	79.7%	20.3%	0.0%	62.5%
GENERAL SERVICE LESS THAN 50 KW	12,999	371,911,863		32.88	0.0109	0.0000	5,128,885	4,053,839	0	9,182,725	55.9%	44.1%	0.0%	13.3%
GENERAL SERVICE 50 TO 4,999 KW	1,611	1,486,650,047	3,778,018	162.33	0.0000	2.7963	3,138,164	0	10,564,473	13,702,637	22.9%	0.0%	77.1%	19.9%
GENERAL SERVICE 50 TO 4,999 KW (COGENERATION)	4	34,191,555	65,844	2,650.00	0.0000	4.6482	127,200	0	306,056	433,256	29.4%	0.0%	70.6%	0.6%
STANDBY POWER			154,800	0.00	0.0000	3.2101	0	0	496,923	496,923	0.0%	0.0%	100.0%	0.7%
LARGE USE	1	82,923,505	159,628	21,350.00	0.0000	2.3178	256,200	0	369,986	626,186	40.9%	0.0%	59.1%	0.9%
STREET LIGHTING	35,912	19,502,488	54,607	1.71	0.0000	8.8279	736,914	0	482,065	1,218,979	60.5%	0.0%	39.5%	1.8%
SENTINEL LIGHTING	599	706,221	1,907	3.77	0.0000	12.4297	27,099	0	23,703	50,802	53.3%	0.0%	46.7%	0.1%
UNMETERED SCATTERED LOAD	1,537	5,464,035		2.25	0.0195	0.0000	41,499	106,549	0	148,048	28.0%	72.0%	0.0%	0.2%
<b>Total</b>	<b>195,172</b>	<b>3,070,021,512</b>	<b>4,214,804</b>				<b>43,846,233</b>	<b>12,923,497</b>	<b>12,243,207</b>	<b>69,012,936</b>				<b>100.0%</b>

# Capital Module

## Applicable to ACM and ICM

### Applicants Rate Base

#### Average Net Fixed Assets

Gross Fixed Assets - Re-based Opening  
 Add: CWIP Re-based Opening  
 Re-based Capital Additions  
 Re-based Capital Disposals  
 Re-based Capital Retirements  
 Deduct: CWIP Re-based Closing  
 Gross Fixed Assets - Re-based Closing  
 Average Gross Fixed Assets

### 2017 Test Year Distribution Revenues

\$ 451,867,413	A				
	B				
\$ 28,092,000	C				
	D				
-\$ 10,483,097	E				
-\$ 157,307	F				
\$ 469,319,009	G				
		\$ 460,593,211		H = ( A + G ) / 2	

Accumulated Depreciation - Re-based Opening  
 Re-based Depreciation Expense  
 Re-based Disposals  
 Re-based Retirements  
 Accumulated Depreciation - Re-based Closing  
 Average Accumulated Depreciation

\$ 193,199,445	I				
\$ 17,984,944	J				
	K				
-\$ 10,734,680	L				
\$ 200,449,709	M				
		\$ 196,824,577		N = ( I + M ) / 2	

#### Average Net Fixed Assets

\$ 263,768,634 O = H - N

#### Working Capital Allowance

Working Capital Allowance Base  
 Working Capital Allowance Rate

\$ 438,036,563	P				
8.7%	Q				

#### Working Capital Allowance

\$ 37,977,770 R = P \* Q

#### Rate Base

\$ 301,746,404 S = O + R

#### Return on Rate Base

Deemed ShortTerm Debt %  
 Deemed Long Term Debt %  
 Deemed Equity %

4.00%	T	\$ 12,069,856	W = S * T
56.00%	U	\$ 168,977,986	X = S * U
40.00%	V	\$ 120,698,562	Y = S * V

Short Term Interest  
 Long Term Interest  
 Return on Equity

1.65%	Z	\$ 199,153	AC = W * Z
2.71%	AA	\$ 4,582,246	AD = X * AA
9.19%	AB	\$ 11,092,198	AE = Y * AB

#### Return on Rate Base

\$ 15,873,596 AF = AC + AD + AE

#### Distribution Expenses

OM&A Expenses  
 Amortization  
 Ontario Capital Tax  
 Grossed Up PILs  
 Low Voltage  
 Transformer Allowance

\$ 38,797,000	AG				
\$ 17,128,312	AH				
	AI				
\$ 1,377,498	AJ				
	AK				
\$ 791,884	AL				
	AM				
	AN				
	AO				
		\$ 58,094,694		AP = SUM ( AG : AO )	

#### Revenue Offsets

Specific Service Charges  
 Late Payment Charges  
 Other Distribution Income  
 Other Income and Deductions

-\$ 1,689,119	AQ				
-\$ 1,967,000	AR				
-\$ 550,900	AS				
-\$ 757,145	AT				
		\$ 4,964,164		AU = SUM ( AQ : AT )	

#### Revenue Requirement from Distribution Rates

\$ 69,004,126 AV = AF + AP + AU

#### Rate Classes Revenue

##### Rate Classes Revenue - Total (Sheet 5)

\$ 69,012,936 AW

##### Difference

-\$ 8,810 AZ = AV - AW

##### Difference (Percentage - should be less than 1%)

-0.01% BA = AZ / AW

# Capital Module

## Applicable to ACM and ICM

London Hydro Inc.

Input the billing determinants associated with London Hydro Inc.'s 2015 Actual Distribution Revenues. This sheet calculates the DENOMINATOR portion of the growth factor calculation. Pseudo Revenue Requirement Calculation.

Rate Class	2015 Actual Distribution Revenues			2015 Base Rates										
	Billed Customers or Connections	Billed kWh	Billed kW	Monthly Service Charge	Distribution Volumetric Rate kWh	Distribution Volumetric Rate kW	Service Charge Revenue	Distribution Volumetric Rate Revenue kWh	Distribution Volumetric Rate Revenue kW	Total Revenue By Rate Class	Service Charge % Revenue	Distribution Volumetric Rate % Revenue kWh	Distribution Volumetric Rate % Revenue kW	Total % Revenue
	A	B	C	D	E	F	G = A * D * 12	H = B * E	I = C * F	J = G + H + I	K = G / J <sub>total</sub>	L = H / J <sub>total</sub>	M = I / J <sub>total</sub>	N = J / J <sub>total</sub>
RESIDENTIAL	139,861	1,084,665,542		20.11	0.0082	0.0000	33,751,257	8,894,257	0	42,645,514	48.6%	12.8%	0.0%	61.5%
GENERAL SERVICE LESS THAN 50 KW	12,485	399,647,917		32.88	0.0109	0.0000	4,926,082	4,356,162	0	9,282,244	7.1%	6.3%	0.0%	13.4%
GENERAL SERVICE 50 TO 4,999 KW	1,594	1,465,515,148	3,725,595	162.33	0.0000	2.7963	3,105,048	0	10,417,882	13,522,930	4.5%	0.0%	15.0%	19.5%
GENERAL SERVICE 50 TO 4,999 KW (COGENERATION)	4	38,831,481	75,192	2,650.00	0.0000	4.6482	127,200	0	349,506	476,706	0.2%	0.0%	0.5%	0.7%
STANDBY POWER			154,800	0.00	0.0000	3.2101	0	0	496,923	496,923	0.0%	0.0%	0.7%	0.7%
LARGE USE	3	137,445,055	284,637	21,350.00	0.0000	2.3178	768,600	0	659,732	1,428,332	1.1%	0.0%	1.0%	2.1%
STREET LIGHTING	35,359	24,640,359	69,126	1.71	0.0000	8.8279	725,567	0	610,237	1,335,804	1.0%	0.0%	0.9%	1.9%
SENTINEL LIGHTING	627	738,970	2,010	3.77	0.0000	12.4297	28,365	0	24,984	53,349	0.0%	0.0%	0.0%	0.1%
UNMETERED SCATTERED LOAD	1,522	5,522,828		2.25	0.0195	0.0000	41,094	107,695	0	148,789	0.1%	0.2%	0.0%	0.2%
<b>Total</b>	<b>191,455</b>	<b>3,157,007,301</b>	<b>4,311,360</b>				<b>43,473,213</b>	<b>13,358,115</b>	<b>12,559,265</b>	<b>69,390,592</b>				<b>100.0%</b>

# Capital Module

## Applicable to ACM and ICM

London Hydro Inc.

**Current Revenue from Rates**

This sheet is used to determine the applicant's most current allocation of revenues (after the most recent revenue to cost ratio adjustment, if applicable) to appropriately allocate the incremental revenue requirement to the classes.

Rate Class	Proposed Base Rates in Current CoS Application			2017 Test Year Distribution Revenues			Current Base Service Charge Revenue G = A * D * 12	Current Base Distribution Volumetric Rate kWh Revenue H = B * E	Current Base Distribution Volumetric Rate kW Revenue I = C * F	Total Current Base Revenue J = G + H + I	Service Charge % Total Revenue L = G / J <sub>total</sub>	Distribution Volumetric Rate % Total Revenue M = H / J <sub>total</sub>	Distribution Volumetric Rate % Total Revenue N = I / J <sub>total</sub>	Total % Revenue O = J / J <sub>total</sub>
	Monthly Service Charge A	Distribution Volumetric Rate kWh B	Distribution Volumetric Rate kW C	Re-based Billed Customers or Connections D	Re-based Billed kWh E	Re-based Billed kW F								
RESIDENTIAL	13.12	0.0155	0.0000	142,509	1,068,671,798		22,436,617	16,564,413	0	39,001,030	35.88%	26.49%	0.00%	62.4%
GENERAL SERVICE LESS THAN 50 KW	30.70	0.0099	0.0000	12,999	371,911,863		4,788,832	3,681,927	0	8,470,759	7.66%	5.89%	0.00%	13.5%
GENERAL SERVICE 50 TO 4,999 KW	150.00	0.0000	2.5038	1,611	1,486,650,047	3,778,018	2,899,800	0	9,459,403	12,359,203	4.64%	0.00%	15.13%	19.8%
GENERAL SERVICE 50 TO 4,999 KW (COGENERATION)	2403.08	0.0000	4.1978	4	34,191,555	65,844	115,348	0	276,400	391,748	0.18%	0.00%	0.44%	0.6%
STANDBY POWER	0.00	0.0000	2.9026			154,800	0	0	449,322	449,322	0.00%	0.00%	0.72%	0.7%
LARGE USE	19314.83	0.0000	2.0949	1	82,923,505	159,628	231,778	0	334,405	566,183	0.37%	0.00%	0.53%	0.9%
STREET LIGHTING	1.57	0.0000	8.1064	35,912	19,502,488	54,607	676,582	0	442,666	1,119,248	1.08%	0.00%	0.71%	1.8%
SENTINEL LIGHTING	3.31	0.0000	10.9336	599	706,221	1,907	23,792	0	20,850	44,643	0.04%	0.00%	0.03%	0.1%
UNMETERED SCATTERED LOAD	1.98	0.0171	0.0000	1,537	5,464,035		36,519	93,435	0	129,954	0.06%	0.15%	0.00%	0.2%
<b>Total</b>							<b>31,209,268</b>	<b>20,339,775</b>	<b>10,983,046</b>	<b>62,532,089</b>				<b>100.0%</b>



# Capital Module

## Applicable to ACM and ICM

London Hydro Inc.

No Input Required.

### Preliminary Threshold Calculation

$$\text{Threshold Value (\%)} = 1 + \left[ \left( \frac{RB}{d} \right) \times (g + PCI \times (1 + g)) \right] \times ((1 + g) \times (1 + PCI))^{n-1} + 10\%$$

<b>Year</b>	<b>2016</b>	
<b>Year in which Applicant is applying</b>	<b>COS</b>	<i>n</i>
<b>Price Cap Index</b>	<b>1.80%</b>	<i>PCI</i>
<b>Growth Factor Calculation</b>		
2017 Test Year Distribution Revenues	\$69,012,936	
2015 Actual Distribution Revenues	\$69,390,592	
<b>Growth Factor</b>	<b>-0.27%</b>	<i>g (Note 1)</i>
<b>Dead Band</b>	<b>10%</b>	
<b>Average Net Fixed Assets</b>		
Gross Fixed Assets Opening	\$ 451,867,413	
Add: CWIP Opening	\$ -	
Capital Additions	\$ 28,092,000	
Capital Disposals	\$ -	
Capital Retirements	-\$ 10,483,097	
Deduct: CWIP Closing	-\$ 157,307	
Gross Fixed Assets - Closing	\$ 469,319,009	
<b>Average Gross Fixed Assets</b>	<b>\$ 460,593,211</b>	
Accumulated Depreciation - Opening	\$ 193,199,445	
Depreciation Expense	\$ 17,984,944	
Disposals	\$ -	
Retirements	-\$ 10,734,680	
Accumulated Depreciation - Closing	\$ 200,449,709	
<b>Average Accumulated Depreciation</b>	<b>\$ 196,824,577</b>	
<b>Average Net Fixed Assets</b>	<b>\$ 263,768,634</b>	
<b>Working Capital Allowance</b>		
Working Capital Allowance Base	\$ 438,036,563	
Working Capital Allowance Rate	9%	
<b>Working Capital Allowance</b>	<b>\$ 37,977,770</b>	
<b>Rate Base</b>	<b>\$ 301,746,404</b>	<i>RB</i>
<b>Depreciation</b>	<b>\$ 17,984,944</b>	<i>d</i>
<b>Threshold Value (varies by Price Cap IR Year subsequent to CoS rebasing)</b>		
Price Cap IR Year 2018	136%	
Price Cap IR Year 2019	136%	
Price Cap IR Year 2020	136%	
Price Cap IR Year 2021	137%	
<b>Threshold CAPEX</b>		
Price Cap IR Year 2018	\$ 24,378,972	<i>Threshold Value × d</i>
Price Cap IR Year 2019	\$ 24,448,961	
Price Cap IR Year 2020	\$ 24,520,016	
Price Cap IR Year 2021	\$ 24,592,153	

**Note 1:** The growth factor *g* is annualized, depending on the number of years between the numerator and denominator for the calculation. Typically, for ACM review in a cost of service and in the fourth year of Price Cap IR, the ratio is divided by 2 to annualize it. No division is normally required for the first three years under Price Cap IR.

# Capital Module Applicable to ACM and ICM London Hydro Inc.

Identify ALL Proposed ACM projects and related CAPEX costs in the relevant years

	Cost of Service	Price Cap IR				Total
	Test Year 2017	Year 1 2018	Year 2 2019	Year 3 2020	Year 4 2021	
Distribution System Plan CAPEX	\$ 32,575,000	\$ 35,417,000	\$ 32,659,000	\$ 33,611,000	\$ 33,507,000	
Materiality Threshold		\$ 24,378,972	\$ 24,448,961	\$ 24,520,016	\$ 24,592,153	
Maximum Eligible Incremental Capital (Forecasted CAPEX less Threshold)		\$ 11,038,028	\$ 8,210,039	\$ 9,090,984	\$ 8,914,847	
Maximum Eligible Incremental Capital (Forecasted Capex less Threshold)		\$ 11,038,028	\$ 8,210,039	\$ 9,090,984	\$ 8,914,847	

*Proposed Capital Projects Eligible for ACM treatment*

Project Descriptions:	Cost of Service	Price Cap IR				Total
	Test Year 2017	Year 1 2018	Year 2 2019	Year 3 2020	Year 4 2021	
Nelson TS Capital Contribution		\$ 6,850,000			\$ 1,450,000	\$ 8,300,000
JD Edwards		\$ 2,000,000				\$ 2,000,000
HONI CCRA True-up's Talbot and Buchanan		\$ 1,000,000				\$ 1,000,000
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
						\$ -
Maximum Allowed Incremental Capital		\$ 9,850,000	\$ -	\$ -	\$ 1,450,000	



## **Appendix 2-5: Service Quality and Reliability Performance**

---

File Number: EB-2016-0091

Exhibit: 2

Tab: 3

Schedule: 1

Page:

Date: 8/26/2016

## Appendix 2-G Service Reliability and Quality Indicators 2011 - 2015

### Service Reliability

Index	Including outages caused by loss of supply					Excluding outages caused by loss of supply					Excluding Major Event Days				
	2011	2012	2013	2014	2015	2011	2012	2013	2014	2015	2011	2012	2013	2014	2015
SAIDI	1.860	0.900	1.020	1.110	1.060	1.670	0.890	0.990	0.980	1.040	1.860	0.900	0.853	1.110	0.950
SAIFI	2.360	1.420	1.380	1.620	1.370	2.140	1.300	1.240	1.210	1.220	2.360	1.420	1.227	1.620	1.220

### 5 Year Historical Average

SAIDI	1.190	1.114	1.135
SAIFI	1.630	1.422	1.569

SAIDI = System Average Interruption Duration Index

SAIFI = System Average Interruption Frequency Index

### Service Quality

Indicator	OEB Minimum Standard	2011	2012	2013	2014	2015
Low Voltage Connections	90.0%	97.6%	96.8%	99.9%	100.0%	97.6%
High Voltage Connections	90.0%	100.0%	100.0%	100.0%	n/a	100.0%
Telephone Accessibility	65.0%	67.3%	68.3%	67.1%	65.9%	68.0%
Appointments Met	90.0%	99.5%	99.9%	99.9%	99.3%	100.0%
Written Response to Enquires	80.0%	100.0%	100.0%	100.0%	100.0%	100.0%
Emergency Urban Response	80.0%	100.0%	99.2%	98.1%	99.1%	100.0%
Emergency Rural Response	80.0%	n/a	n/a	n/a	n/a	n/a
Telephone Call Abandon Rate	10.0%	2.1%	2.1%	2.4%	3.2%	2.6%
Appointment Scheduling	90.0%	93.4%	97.5%	96.7%	95.3%	98.6%
Rescheduling a Missed Appointment	100.0%	100.0%	100.0%	100.0%	100.0%	n/a
Reconnection Performance Standard	85.0%	96.2%	98.3%	98.6%	99.1%	99.1%



## **Appendix 2-6: Distribution System Plan**

---