



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18A2
Project Name: Battery Bank Replacement
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Battery Bank Replacement Program

Supporting Reference Material: 2017 Substation Assessment Report

Description: Battery banks installed in substations provide DC power to enable the operation of circuit breakers and relays during a power failure. The batteries are inspected annually and tested once every four years. Battery banks are replaced based on age and condition. This program to replace battery banks will continue 2018 through 2021.

PRIMARY DRIVER:	Reliability	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Safety			
CUSTOMERS IMPACTED:	650	2012	\$15,435	AREA/SCOPE One Substation One Substation
OEB CAPITAL REPORTING:	A2 - Battery Bank Replacements	2013	\$11,427	
LH PROJECT DRIVER:	REL	2014	\$11,019	
		2015	\$12,065	
		2016	\$13,518	
		2017	\$11,356	
		2018	\$15,000	
		2019	\$15,000	
		2020	\$15,000	
		2021	\$15,000	
		TOTAL COST ESTIMATE:		\$134,820
		LH SECTION #	110	



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18A2
Project Name: Battery Bank Replacement
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Battery Bank Replacement Program

Risks to Completion & Mitigation Plan: Risks to completion are minimal. This project is part of a program that has been successfully executed in each of the past five years. The availability of resources (internal labour) is sufficient to complete this project.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

Replacing battery banks enhances the reliability of protection relays, which ensures that faults are addressed in a manner that minimizes customer interruptions.

Safety

Replacing battery banks ensures that DC power will be available to operate feeder protections, which are required to isolate faults.

Cyber-Security, Privacy

Not Applicable

Co-ordination, Interoperability

Not Applicable

Economic Development

Not Applicable

Environmental Benefits

Not Applicable

IMPACT TO O&M COSTS:

Slight reduction by reducing the probability of unplanned failures through planned replacement.

ALTERNATIVES CONSIDERED:

Do nothing, however this alternative was rejected since it is believed that the costs of unplanned failures outweigh the cost of the program.

LINK TO STRATEGIC PLAN:

Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:

Customers were not directly engaged regarding this project, but recent surveys indicate customers value improvements to reliability (refer to DSP Section 3.2.4 Customer Engagement).





**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18A2
Project Name: Battery Bank Replacement
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Battery Bank Replacement Program

Additional Information:

Not Applicable

Prepared By: Ismail Sheikh, P.Eng.
Distribution Engineer

Approved By: William Milroy, P.Eng.
V.P. Engineering
& Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18A3
Project Name: Substation RTU Standardization
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Substation RTU Standardization Program

Supporting Reference Material: 2013 Substation Assessment Report

Description: London Hydro trialed a number of different substation remote terminal units (RTUs) before selecting a standard design in 2011. Many of the trial RTUs are no longer supported by the manufacturer and London Hydro has insufficient experience or spare components to sustain them.

To ensure that London Hydro is able to continuously support SCADA to enhance system reliability for the customers, a new program was developed to replace all unique substation RTUs. From 2018 through 2021 a program of RTU replacements will carry on at various substations.

PRIMARY DRIVER:	Interoperability	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Efficiency			
	Reliability	2012	COST	AREA/SCOPE
	Customer Value	2013	\$0	
		2014	\$0	
CUSTOMERS IMPACTED:	2	2015	\$30,000	2 Substations
		2016	\$38,050	2 Substations
		2017	\$30,000	2 Substations
		2018	\$80,000	2 Substations
		2019	\$80,000	2 Substations
OEB CAPITAL REPORTING:		2020	\$80,000	2 Substations
	A9 - Other	2021	\$80,000	2 Substations
		TOTAL COST ESTIMATE:		\$418,050
LH PROJECT DRIVER:	REL	LH SECTION #		110



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number:	18A3
Project Name:	Substation RTU Standardization
Start Date:	Jan-18
In-Service Date:	Dec-18

Project Title: Substation RTU Standardization Program

Risks to Completion & Mitigation Plan: Risks to completion are minimal. This project is part of a program that has been successfully executed in each of the past five years. The availability of resources (internal labour) is sufficient to complete this project.

EVALUATION OF OUTCOMES:	
Efficiency, Customer Value, Reliability	Standardizing RTUs generates efficiencies in employee training and spare inventory, while increasing reliability due to reduced repair times achieved due to greater staff familiarity with the equipment.
Safety	Not Applicable
Cyber-Security, Privacy	New equipment
Co-ordination, Interoperability	The RTUs will be secured in accordance with London Hydro's cyber security practices.
Economic Development	Not Applicable
Environmental Benefits	Not Applicable

IMPACT TO O&M COSTS:
Slight reduction as training costs decrease due to equipment standardization.

ALTERNATIVES CONSIDERED:
Do nothing, however this alternative was rejected since it does not address the need to be able to reliably maintain the SCADA system.

LINK TO STRATEGIC PLAN:
Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:
Customers were not directly engaged regarding this project, but recent surveys indicate customers value improvements in reliability (refer to DSP Section 3.2.4 Customer Engagement).





**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18A3
Project Name: Substation RTU Standardization
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Substation RTU Standardization Program

Additional Information:

Not Applicable

Prepared By: Ismail Sheikh, P.Eng.
Distribution Engineer

Approved By: William Milroy, P.Eng.
V.P. Engineering
& Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18A4
Project Name: Nelson TS Backup Transformation
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Installation of Step-Down Transformer at SUB-8 and provisioning for a Mobile Unit Substation (MUS) at SUB-11 for Nelson TS Backup

Supporting Reference Material: London Downtown Long Term 27.6 kV Supply and 13.8 kV Decommissioning Strategy
 London Downtown - 13.8 kV/27.6 kV Nelson TS - 5 Year Plan
 QSI: Monthly Reliability Performance Overview - August 2017

Description: London Downtown is presently supplied mainly through the older 13.8 kV Non-Network and Network systems via Nelson Transformer Station (TS). Nelson TS is a double DESN with the T1/T2 supplying the 3-wire Network system and the T3/T4 supplying the 4-wire Non-Network system. Hydro One is rebuilding the T1/T2 DESN to 27.6 kV standards and this new supply is expected to be in service by December 2018 while the T3/T4 DESN will be eliminated by end of 2020.

Due to increased failures of the T3/T4 DESN supply, the likelihood of a complete T3/T4 DESN outage has increased. The impact of a T3/T4 DESN outage would be significant and would affect the power supply to nearly 2,000 customers in the service territory for Nelson TS, leaving over 1,000 customers stranded for days or weeks.

This new project involves the installation of a backup stepdown transformer at SUB-8 and making a provision for a Mobile Unit Substation (MUS) at SUB-11 in order to resupply the 13.8 kV downtown load from the 27.6 kV system. Approximately 9 MVAs transformation combined from these two substation upgrades would be available for backing up existing 13.8 kV non-network load that relies solely on the T3/T4 bus.

PRIMARY DRIVER:	Reliability	COST ESTIMATE - BY YEAR	
OTHER DRIVERS:	Econ. Dev.	2012	
	Customer Value	2013	
		2014	
		2015	
CUSTOMERS IMPACTED:	2,000	2016	
		2017	
		2018	\$215,000 2 Substation upgrades
		2019	
OEB CAPITAL REPORTING:		2020	
		2021	
		TOTAL COST ESTIMATE:	\$215,000
LH PROJECT DRIVER:	REL	LH SECTION #	110



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18A4
Project Name: Nelson TS Backup Transformation
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Installation of Step-Down Transformer at SUB-8 and provisioning for a Mobile Unit Substation (MUS) at SUB-11 for Nelson TS Backup

Risks to Completion & Mitigation Plan: Risks to completion are minimal. The availability of resources (internal labour) is sufficient to complete this project.

EVALUATION OF OUTCOMES:	
Efficiency, Customer Value, Reliability	The alternate supplies will increase system reliability and reduce customer outage durations during system contingency scenarios.
Safety	Not Applicable
Cyber-Security, Privacy	Not Applicable
Co-ordination, Interoperability	This project will permit the resupply of Nelson TS load via Talbot TS for increased reliability and operational flexibility during contingencies.
Economic Development	An alternate power source ensures businesses stay operational in the Nelson TS service territory which includes downtown during contingencies.
Environmental Benefits	Not Applicable

IMPACT TO O&M COSTS:
Negligible.

ALTERNATIVES CONSIDERED:
Do nothing; however, this alternative was rejected due to the risk it would pose to supply reliability.

LINK TO STRATEGIC PLAN:
Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:
Customers were not directly engaged regarding this project, but recent surveys indicate customers value improvements to reliability (refer to DSP Section 3.2.4 Customer Engagement).





CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18A4
Project Name: Nelson TS Backup Transformation
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Installation of Step-Down Transformer at SUB-8 and provisioning for a Mobile Unit Substation (MUS) at SUB-11 for Nelson TS Backup

Additional Information:



Prepared By: Ismail Sheikh, P.Eng.
Distribution Engineer

Approved By: William Milroy, P.Eng.
V.P. Engineering
& Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18A5
Project Name: Station Insulator Replacement
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Replacement of Porcelain Station Insulators at Substations

Supporting Reference Material: 2017 Substation Assessment Report

Description: Porcelain insulators used on the structures inside some of London Hydro's substations are prone to failure similar to known issues with the line post insulators used on the overhead distribution system. This budget item will deal with porcelain insulators installed inside municipal substations as a measure of enhancing reliability and safety.

PRIMARY DRIVER:	Reliability	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Safety			
	Customer Value	2012	COST	AREA/SCOPE
		2013		
		2014		
		2015		
CUSTOMERS IMPACTED:	Various	2016		
		2017		
		2018	\$50,000	One Substation
		2019		
OEB CAPITAL REPORTING:		2020		
		2021		
		TOTAL COST ESTIMATE:		\$50,000
LH PROJECT DRIVER:	REL	LH SECTION #		110



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18A5
Project Name: Station Insulator Replacement
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Replacement of Porcelain Station Insulators at Substations

Risks to Completion & Mitigation Plan: Risks to completion are minimal. The availability of resources (internal labour) is sufficient to complete this project.

EVALUATION OF OUTCOMES:	
Efficiency, Customer Value, Reliability	Replacing porcelain insulators prone to failure at the substations will ensure power is distributed reliably to customers and will reduce outages that can be avoided.
Safety	Safety is the number one factor considered in addressing overhead system weaknesses since live contact can occur due to the failure mode in some equipment.
Cyber-Security, Privacy	Not applicable
Co-ordination, Interoperability	Not applicable
Economic Development	Improved reliability will contribute to overall attractiveness of London as a place to live and do business.
Environmental Benefits	Not applicable

IMPACT TO O&M COSTS:
 Slight reduction by reducing the probability of unplanned failures through planned replacement.

ALTERNATIVES CONSIDERED:
 Do nothing, however this alternative was rejected since it is believed that the costs of unplanned failures outweigh the cost of the program.

LINK TO STRATEGIC PLAN:
 Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:
 Customers were not directly engaged regarding this project, but recent surveys indicate customers value improvements to reliability (refer to DSP Section 3.2.4 Customer Engagement).





CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18A5
Project Name: Station Insulator Replacement
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Replacement of Porcelain Station Insulators at Substations

Additional Information:

Not Applicable

Prepared By: Ismail Sheikh, P.Eng.
Distribution Engineer

Approved By: William Milroy, P.Eng.
V.P. Engineering
& Operations



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18B1
Project Name: Cable Silicone Injection
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Silicone Injection of Underground Cable

Supporting Reference Material: Rehabilitation of Aging Underground Residential Distribution System: Addendum 2017
 SPOORE Analysis - Methodology and Outcome
 Electric Distribution System Asset Sustainment Plan: 2015-2029 (2014)

Description: Silicone injection technology increases the lifespan of polymeric cable by adding another 40 years of service. This project item covers the rehabilitation of medium-voltage polymeric cable by means of silicone injection in four (4) subdivisions serviced at 27.6 kV. The total cable length is estimated to be 22 km; all of the cable is 25+ years old. These subdivisions were selected using the SPOORE analysis, which encompasses reliability, safety, risk and aging of the underground cable. The analysis is based on a multi-year performance window which takes into account age and failures of cables and transformers, and the presence of transformer leakers.

The cable length addressed in this budget item is below the target of 46 km per year of rehabilitated cable that is outlined in the Asset Sustainment Plan. The reduction in budget is temporary in order to reallocate resources to address the increased scope and spending in Project 18C3 and 18F3 to accommodate Dundas Place project.

Four subdivisions were selected for silicone injection part of this budget item for a total of 22 km of cable to be rehabilitated.

The rehabilitation will also include anticipated replacement of 15 single-phase padmounted transformers (including live front transformers) that are deteriorated, leaking, or do not meet today's standard. The new transformers will be equipped with dual load break switches that provide operation flexibility, and are expected to reduce downtime for customers by allowing more effective switching.

PRIMARY DRIVER:	Reliability	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Efficiency	2012	\$792,460	2 Subdivisions
	Customer Value	2013	\$1,847,897	5 Subdivisions
	Reliability	2014	\$2,297,219	5 Subdivisions
		2015	\$1,937,060	8 Subdivisions
CUSTOMERS IMPACTED:	Approximately 1,500 Customers	2016	\$2,370,774	4 Subdivisions
		2017	\$2,553,843	6 Subdivisions
		2018	\$1,440,000	4 Subdivisions
		2019	\$1,910,000	4 Subdivisions
		2020	\$2,796,107	6 Subdivisions
		2021	\$3,455,733	6 Subdivisions
OEB CAPITAL REPORTING:				
B1: Silicone Injection of Underground Cable		TOTAL COST ESTIMATE:		\$21,401,093
LH PROJECT DRIVER:	REL	LH SECTION #	145	



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18B1
Project Name: Cable Silicone Injection
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Silicone Injection of Underground Cable

Risks to Completion & Mitigation Plan: Resource availability (internal and contract) is the biggest risk to completion. Mitigation plan includes a multi-year contract with external resources and regular coordination meetings with engineering and operations.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

Cable injection has been found to be more economical than cable replacement. Reliability will improve with fewer outages caused by cable failures. At the end, customers will receive better, reliable service.

Safety

Impact to safety is minimal with a slight decrease in risk to workers handling cables and other equipment.

Cyber-Security, Privacy

Not applicable

Co-ordination, Interoperability

Cable injection is a widely used solution for rejuvenating aging cable among utilities.

Economic Development

Improved reliability will contribute to overall attractiveness of London as a place to live and do business.

Environmental Benefits

Silicone injection is environmental friendly solution; the treatment compounds are not flammable and do not pose an environmental hazards.

IMPACT TO O&M COSTS:

Annual operating and maintenance costs will have a slight reduction due to fewer outages related to cable failures.

ALTERNATIVES CONSIDERED:


Complete replacement of cables is more expensive, especially if the cables are direct buried and directional boring is required to install ducts.

LINK TO STRATEGIC PLAN:

Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:

Customers were not directly contacted regarding this project but recent surveys indicate that customers value improvements in reliability (refer to DSP Section 3.2.4 Customer Engagement).






CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18B1
Project Name: Cable Silicone Injection
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Silicone Injection of Underground Cable

Additional Information:

Huron Village: 4.4 km, 0 TEs



Oakridge Park West: 4.8 km, 5 TEs



Gainsborough Meadows Phase 2: 4.0 km, 4TEs



Warbler Woods: 8.6 km, 6 TEs



Prepared By: Rodney Doyle, P.Eng.
Senior Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18B2
Project Name: Subdivision Rehabilitation
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Subdivision Conversions / Rebuilds with Silicone Injection

Supporting Reference Material: Rehabilitation of Aging Underground Residential Distribution System: Addendum 2017
 SPOORE Analysis - Methodology and Outcome
 Electric Distribution System Asset Sustainment Plan: 2015-2029 (2014)

Description: The selection was based on the comprehensive SPOORE analysis which encompasses elements such as reliability, safety, risk and aging of underground cable. The analysis is based on a multi-year performance window.

PRIMARY DRIVER:	Reliability	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Efficiency	2012	\$2,051,900	3 Subdivisions
	Customer Value	2013	\$1,830,355	2 Subdivisions
		2014	\$1,014,866	4 Subdivisions
		2015	\$1,302,031	1 Subdivision (deferred)
CUSTOMERS IMPACTED:	Approximately 100 customers	2016	\$1,050,862	1 Subdivision
		2017	\$31,639	--
		2018	\$70,000	1 Subdivision
		2019	\$1,334,000	1 Subdivision
		2020	\$0	1 Subdivision
OEB CAPITAL REPORTING:		2021	\$780,000	2 Subdivisions
B2: Subdivision Conversions / Rebuilds with Silicone Injection		TOTAL COST ESTIMATE:		\$9,465,653
LH PROJECT DRIVER:	REL	LH SECTION #	145	



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18B2
Project Name: Subdivision Rehabilitation
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Subdivision Conversions / Rebuilds with Silicone Injection

Risks to Completion & Mitigation Plan: Resource availability (internal and contract) is the biggest risk to completion. Mitigation plan includes a multi-year contract with external resources and regular co-ordination meetings with engineering and operations.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

Cable replacement is used only to replace the existing 5 kV and 15 kV rated cables and silicone injection is used to rejuvenate the existing 27.6 kV rated cable. By installing new cable/injecting the existing, reliability will improve with fewer outages caused by cable failure. Also, when converted to 27.6 kV, outages will be shorter in duration due to the availability of back up supplies for the 27.6 kV. This will result in better service to customers.

Safety

Impact to safety is minimal with a slight decrease in risk to workers handling cables and other equipment.

Cyber-Security, Privacy

Not applicable

Co-ordination, Interoperability

Not applicable

Economic Development

Improved reliability will contribute to overall attractiveness of London as a place to live and do business.

Environmental Benefits

Not applicable

IMPACT TO O&M COSTS:

Annual operating and maintenance costs will have a slight reduction due to fewer outages related to cable failures.

ALTERNATIVES CONSIDERED:


Not applicable

LINK TO STRATEGIC PLAN:

Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:

Customers were not directly contacted regarding this project but recent surveys indicate that customers value improvements in reliability (refer to DSP Section 3.2.4 Customer Engagement).





CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL


Project Number: 18B2
Project Name: Subdivision Rehabilitation
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Subdivision Conversions / Rebuilds with Silicone Injection

Additional Information:

Sun Valley (4.16 kV Supply)

Sun Valley is a very small subdivision located west of Wonderland Road, nestled between Riverside Drive and Thames River. Approximately 100 customers are supplied via 0.85 km of underground primary cable that has been in service for 40+ years. The cable is rated 28 kV but energized at 4.16 kV. The cable will be treated with silicone injection and then re-energized. There are four (4) single-phase padmounted transformers in Sun Valley, of which 3 are live-fronts; all transformers will be replaced. The area will have one new section of primary cable installed to add an existing radial transformer to the loop.



Prepared By: Rodney Doyle, P.Eng.
Senior Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18B3
Project Name: Replacement/Removals of SE's
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Replacement of Air Insulated Sectionalizing Enclosures

Supporting Reference Material:

Distribution Reliability Report: Performance Review and a New Perspective for In-service 27.6 kV Three-Phase Air Insulated Sectionalizing Enclosures (2006)
 Electric Distribution System Asset Sustainment Plan: 2015-2029 (2014)
 2016 Quality of Supply Report

Description:

Earlier research and analysis into the failures of air insulated switching enclosures on the 27.6 kV system led to the internal publication of an in-depth report at London Hydro in 2006. The findings and recommendations from that report have helped with targeting the elimination of the most prone-to-failure units. The work conducted over more than ten years has shown a remarkable positive impact in performance and failures have dropped. From the time the higher-risk units started to be changed out (2006) to-date, more than 80% of the units have been addressed either by elimination or replacement with a Load Center (LC).

Although London Hydro's plan is to continue to address, on average, 6-8 SE's every year, the reduction in this budget section is temporary in order to reallocate resources to address the increased scope and spending in Projects 18C3 and 18F3 to accommodate Dundas Place project. London Hydro will return to its 6-8 SE's per year in 2020. At this pace, all the three-phase SE's remaining in service would be addressed in the following 4-5 years.

PRIMARY DRIVER:	Reliability	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Safety	2012	\$492,254	10 units
	Customer Value	2013	\$512,101	9 units
	Efficiency	2014	\$350,101	6 units
		2015	\$219,588	2 units
CUSTOMERS IMPACTED:	Approximately 1,000 Customers	2016	\$258,757	11 units
		2017	\$358,480	4 units
		2018	\$180,000	1 unit
		2019	\$689,500	10 units
		2020	\$636,000	9 units
OEB CAPITAL REPORTING:		2021	\$99,500	3 units
B3 - Replace Air Insulated SE's		TOTAL COST ESTIMATE:		\$3,796,281
LH PROJECT DRIVER:	REL	LH SECTION #		145



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18B3
Project Name: Replacement/Removals of SE's
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Replacement of Air Insulated Sectionalizing Enclosures

Risks to Completion & Mitigation Plan: Risks to completion are low. This project is part of a program that has been successfully executed in each of the past ten years. The availability of resources (internal and contract) is sufficient to complete this project.

EVALUATION OF OUTCOMES:	
Efficiency, Customer Value, Reliability	The removal or replacement of air-insulated switching enclosures (SE) with Load Centers (LC) will lead to fewer outages caused by SE failures. It is expected that customers will receive a more reliable supply.
Safety	Replacing air-insulated switching enclosures (live-front) with solid dielectric load centers (dead-front) will have a positive impact to the system with a considerable decrease in the risk of flashovers experienced.
Cyber-Security, Privacy	Not applicable
Co-ordination, Interoperability	Load Centers became London Hydro standard for distribution switchgear (200A and 600A).
Economic Development	Improved reliability will contribute to overall attractiveness of London as a place to live and do business.
Environmental Benefits	Not applicable

IMPACT TO O&M COSTS:
 Annual operating and maintenance costs will have a slight reduction due to fewer outages as a result of SE failures.

ALTERNATIVES CONSIDERED:
 Not applicable

LINK TO STRATEGIC PLAN:
 Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:
 Customers were not directly contacted regarding this project but recent surveys indicate that customers value improvements in reliability (refer to DSP Section 3.2.4 Customer Engagement).





CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18B3
Project Name: Replacement/Removals of SE's
Start Date: Jan-18
In-Service Date: Dec-18


Project Title: Replacement of Air Insulated Sectionalizing Enclosures

Additional Information:

In the last decade London Hydro has addressed three-phase air-insulated switchgear on the 27.6 kV distribution system that were underperforming according to the report issued in 2006. At the end of 2017, of the 148 switching enclosures (SE's) audited at the start of the program, 122 SE's were addressed by removing 64 from the system and replacing 58 with Load Centers (LC's).

This year's budget will address a 600 amp switchgear installed on a main feeder (SE 185 - formerly refurbished with silicone insulators) by replacing it with an automated Load Centre, to introduce an additional remote sectionalizing device on 4M15.

27.6 kV Switchgear Status - 2017



Prepared By: Rodney Doyle, P.Eng.
Senior Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18B4
Project Name: Transformer Replacement
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Defective/Leaking Transformer Replacements

Supporting Reference Material: Electric Distribution System Asset Sustainment Plan: 2015 to 2029 (2014) OEB Annual Audits

Description: London Hydro field staff conduct annual audits of padmounted transformers in accordance with the requirements of the Ontario Energy Board. These audits are meant to identify defective or depreciated transformers, as well as transformers which may be weeping oil around the primary and secondary bushings. These matters are usually caused by transformer aging and the degradation of the sealing gaskets, or as a result of rusted bottom cabinets from salty sidewalks.

This project covers the cost to identify and replace fully depreciated and leaking transformers. This budget item also includes funding for the replacement of transformers that have failed in the field and require replacement. This budget item has traditionally also included replacement of polemount units that are leaking or are being found defective in the field throughout the year.

The dollars invested 2018 through 2021 are in line with the recommendations of the Asset Sustainment Plan to gradually address the aging population of padmounted transformers.

PRIMARY DRIVER:	Environmental	COST ESTIMATE - BY YEAR	
		COST	AREA/SCOPE
OTHER DRIVERS:	Safety	2012	\$1,047,618
	Reliability	2013	\$892,191
		2014	\$737,297
		2015	\$1,493,000
CUSTOMERS IMPACTED:	Estimated 900-1200	2016	\$1,161,332
		2017	\$866,890
		2018	\$1,150,000
		2019	\$800,000
		2020	\$800,000
		2021	\$800,000
OEB CAPITAL REPORTING		TOTAL COST ESTIMATE:	\$9,748,328
B4 - Replacement of Defective/Leaking Transformers			
LH PROJECT DRIVER:	SAF	LH SECTION #	145



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18B4
Project Name: Transformer Replacements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Defective/Leaking Transformer Replacements

Risks to Completion & Mitigation Plan: Resource availability is the biggest risk to completion; London Hydro, if necessary, uses the contractor that performs cable silicone injection to address the units identified in need of replacement in subdivisions.


EVALUATION OF OUTCOMES:	Efficiency, Customer Value, Reliability	Reliability is inherently improved by timely replacement of padmounted transformers that can be on the verge of failure or affect the environment. This measure is in line with the asset renewal process described by London Hydro in its 15-year Asset Sustainment Plan.
	Safety	This item contributes greatly to safety as rusted cabinets (see photo below) may no longer be tamper proof and, hence, become a hazard to public and employees for electric contact.
	Cyber-Security, Privacy	Not applicable
	Co-ordination, Interoperability	Discussions with utilities may influence manufacturers to modify the design of transformer cabinets to be more durable to weather, salt and contamination.
	Economic Development	Improved reliability will contribute to the overall attractiveness of London as a place to live and do business.
	Environmental Benefits	Potentially leaking oil from transformers can enter the ground and contaminate the soil affecting the environment. This measure demonstrates vigilance to the environmental benefits.

IMPACT TO O&M COSTS:
 Fewer outages will occur due to transformer failures, with a potential reduction in annual operating and maintenance costs.

ALTERNATIVES CONSIDERED:
 Allowing deteriorated transformers to run to failure can cause additional outages in subdivisions where other components of the system have improved their reliability. addressed.

LINK TO STRATEGIC PLAN:
 Section 6.2.1 - Emphasis on Reliability and Safety

CUSTOMER ENGAGEMENT:
 Customers are not directly contacted for this project but surveys indicate increased customer value with improved reliability (refer to DSP Section 3.2.4 Customer Engagement).





CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18B4
Project Name: Transformer Replacements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Defective/Leaking Transformer Replacements

Additional Information:

London Hydro performs OEB audits on the condition of all the padmounted transformers in our system every three years. These audits help identify potentially defective/end-of-life or leaking transformers for replacement. London Hydro takes its environmental responsibilities seriously and, as such, continues to invest capital dollars into the identification and removal of these problematic transformers. This budget item also includes funding for the replacement of transformers that have failed in the field or require immediate replacement, prioritized according to audit results.

The cost to replace a typical padmounted transformer ranges between \$7,500 and \$20,000 depending on the transformer type and size. On average, London Hydro has been replacing approximately 60-80 padmount units in one year, in addition to the polemount units that needed to be changed out in emergency. This proposed budget is slightly higher than in previous years; with the increased amount of rehabilitation work in underground subdivisions, more units are identified in need of replacement apart from the annual OEB audits.

Prepared By: Sunny Patel, P.Eng.
Rodney Doyle, P.Eng.

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18B5
Project Name: Secondary Pedestal Replacements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Replacement of Deteriorated Secondary Pedestals

Supporting Reference Material: Electric Distribution System Asset Sustainment Plan: 2015-2019 (2014) Annual OEB Field Audits

Description: London Hydro has a secondary underground distribution system that includes approximately 900 single-phase, low voltage junction pedestals, typically used in residential areas. These pedestals (located in frontyard or backyard) house low voltage electrical connections, from one common bus cable to several service cables in order to supply multiple premises. A large majority of these units are in excess of 30-40 years old and are considered at the end of life. The outdated metal enclosures are often corroded. It has also been found that the connections and barriers within the existing units are beginning to fail, posing safety risks. Many of the pedestals however have not been opened or worked on since the original installation and problems appear when staff have to conduct secondary cable repairs.

This budget item covers the replacement of the most deteriorated units with new non-metallic pedestals. Areas where problems have been experienced in the past, as well as newly discovered units that present safety concerns will be addressed first. This project is supported by the Asset Sustainment Plan that anticipates the need for the secondary system renewal.

PRIMARY DRIVER:	Safety	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Reliability	2012	\$33,610	17 Units
	Customer Value	2013	\$20,456	12 Units
		2014	\$22,015	12 Units
		2015	\$25,836	12 Units
CUSTOMERS IMPACTED:	Estimated 150	2016	\$41,719	12 Units
		2017	\$32,148	10 Units
		2018	\$20,000	9 Units
		2019	\$20,000	
OEB CAPITAL REPORTING:		2020	\$20,000	
B7 - Misc. Subdivision Projects		2021	\$21,000	
		TOTAL COST ESTIMATE:		\$256,784
LH PROJECT DRIVER:	REL	LH SECTION #		145



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18B5
Project Name: Secondary Pedestal Replacements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Replacement of Deteriorated Secondary Pedestals

Risks to Completion & Mitigation Plan: The identification of deteriorated secondary pedestals happens as crews respond to power outages on the secondary system; there is no proactive search to prioritize replacements. This process may result in additional pedestals remaining in the system that could potentially be unsafe. Considering an increase for this budget item in the near future may achieve more of the necessary replacements.

EVALUATION OF OUTCOMES:	
Efficiency, Customer Value, Reliability	Pedestals can be located on the front yard or back yard of residential properties. Deteriorated pedestals often are rusty, crooked or dismantled and beside becoming an unsafe electrical enclosure, their failure usually affects more than one household for a longer duration.
Safety	This item contributes greatly to safety as pedestal deterioration can inadvertently expose live conductors to staff and to public.
Cyber-Security, Privacy	Not applicable
Co-ordination, Interoperability	Not applicable
Economic Development	Improved reliability will contribute to the overall attractiveness of London as a place to live and do business.
Environmental Benefits	There are no direct environmental benefits associated with this program. New plastic pedestals (on the right) replace old metallic units (on the left) that could however be recycled.

IMPACT TO O&M COSTS:
 Less power interruptions may occur as a result of eliminating bad pedestals, with a potential reduction in annual operating and maintenance costs.

ALTERNATIVES CONSIDERED:
 Allowing deteriorated pedestals to run to failure could increase their life time; however, associated safety concerns lead to replacement sooner rather than later.

LINK TO STRATEGIC PLAN:
 Section 6.2.1 - Emphasis on Reliability and Safety

CUSTOMER ENGAGEMENT:
 Customers are not directly contacted for this project but surveys indicate increased customer value with improved reliability (refer to DSP Section 3.2.4 Customer Engagement).





CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18B5
Project Name: Secondary Pedestal Replacements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Replacement of Deteriorated Secondary Pedestals

Additional Information:

The underground residential distribution system at London Hydro began to develop in mid 1960's. With service cables approaching 50-55 years old, associated pedestals of likely the same age are still in service. London Hydro is collecting information on the demographics of the secondary system; future plans may be formulated to begin mass replacement as some services reach end of life. This rebuild process would encompass the elimination of most of the old pedestals, as such no separate plan is needed to address this aging equipment type.

Prepared By: Rodney Doyle, P.Eng.
Senior Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18B6
Project Name: Vault Rebuilds
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Vault Transformer Replacements

Supporting Reference Material: Electric Distribution System Asset Sustainment Plan: 2015-2029 (2014)
 London Downtown Long-Term 27.6 kV Supply and 13.8 kV Decommissioning Strategy
 4.16 kV Aging Infrastructure System Planning Report (2011), Appendix D
 OEB Audits conducted by field staff

Description: The Asset Sustainment report identified various indoor transformer vaults as being in poor condition. These vaults were also inspected by London Hydro staff.

These indoor transformer vaults contain dry-type transformers that are more than forty years old. Our operations staff has identified these locations as having chronic water problems that could result in equipment failure. This budget item will allow for the replacement of these dry-type transformers with padmount or pole mount transformers located outside the vaults. It will also allow for the installation and termination of secondary cables from the new transformation to the new disconnects inside the vaults.

As part of this project, transformer vault designated as TV 895, located at 112 King Edward Ave will be eliminated and the 66kW load will be converted to 27.6 kV distribution.

PRIMARY DRIVER:	Safety	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Environmental	2012	\$134,849	6 vaults
	Customer Value	2013	\$216,173	3 vaults
		2014	\$91,031	4 vaults
		2015	\$170,696	5 vaults
CUSTOMERS IMPACTED:	1	2016	\$69,589	3 vaults (2 deferred)
		2017	\$176,364	3 vaults
		2018	\$57,000	1 vault
		2019	\$331,000	
OEB CAPITAL REPORTING:		2020	\$174,000	
B5 - Rebuild or Convert Vault Areas		2021	\$288,000	
			TOTAL COST ESTIMATE:	\$1,708,702
LH PROJECT DRIVER:	SAF	LH SECTION #		145



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18B6
Project Name: Vault Rebuilds
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Vault Transformer Replacements

Risks to Completion & Mitigation Plan:

Transformer vaults are usually located on customer-owned premises, such as in apartment building basements, school vaults etc; therefore, London Hydro requires permission from the owner to upgrade the service; mitigation plan is to present the options to the customer and engage the customer in the decision-making process; we will need to ensure the availability of resources to match outage timing dictated by the owner; mitigation plan is in close co-ordination with the owner to ensure schedule compatibility.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

London Hydro coordinates vault transformer replacements with overhead voltage conversion projects so that the customers are less affected by power interruptions and can further benefit from increased reliability of supply. Removing transformer from customer premises mitigates liability and provides room for the customer.

Safety

Vault transformer replacements achieve the elimination of dry-type transformers, which can be unsafe when maintenance is performed on them since energized components can come in contact with the ground and accumulated water, which also causes corrosion.

Cyber-Security, Privacy

Not applicable

Co-ordination, Interoperability

Co-ordination will be required with customers on whose premises the equipment is found.

Economic Development

Improved reliability will contribute to the overall attractiveness of London as a place in which to live and do business.

Environmental Benefits

Environmental benefits that can be the result of such replacements include the recycling of the metal components from these old installations.

IMPACT TO O&M COSTS:

Fewer outages can be expected after the supply systems are upgraded to current standards and, hence, the annual operating and maintenance costs may be reduced.

ALTERNATIVES CONSIDERED:


Leave transformers in service; however, this option is, is not acceptable as they have reached their end of life and can no longer be properly and safely maintained.

LINK TO STRATEGIC PLAN:

Section 6.2.1 - Emphasis on Reliability and Safety

CUSTOMER ENGAGEMENT:

London Hydro initiates contact with the owner to explain work and explore viable options for vault replacement; London Hydro co-ordinates service interruptions, site restoration and overall schedule.





CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18B6
Project Name: Vault Rebuilds
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Vault Transformer Replacements

Additional Information:



The highlighted segment shows transformer vault TV 895, supplied off the existing overhead 4.16 kV distribution system.

This project will coordinate with the rebuilding and conversion of the surrounding overhead distribution under Project 18G5.

Although transformer customer information shows one general service at 112 King Edward Avenue, there are 36 tenants within the large three-storey walk up.



Dry Type Transformers

Water traces on the floor

Prepared By: Rodney Doyle, P.Eng.
Senior Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM SERVICE**

Project Number: 18B7
Project Name: Backup Supply Installation
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Installation of Backup Supply

Supporting Reference Material: 2016 Quality of Supply Report

Description: London Hydro has started to experience outages in the residential underground subdivisions that were serviced in the past via a radial underground system. This configuration leaves London Hydro's control room operators with no options to restore power quickly during outages resulting from equipment failure.

This budget item provides for additional supply in one of those subdivisions thereby providing our operators with an alternate source from which they can restore power. This work will greatly improve the speed that power can be restored to these areas and enhance the reliability of supply.

PRIMARY DRIVER:	Customer Value	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Reliability			
CUSTOMERS IMPACTED:	235	2012	COST \$94,421	AREA/SCOPE
		2013	\$44,325	
		2014	\$40,547	
		2015	\$171,253	
		2016	\$40,072	
		2017	\$70,040	
		2018	\$20,000	
		2019	\$0	
		2020	\$0	
		2021	\$0	
OEB CAPITAL REPORTING		TOTAL COST ESTIMATE: \$480,658		
B7 - Misc. Subdivision Projects				
LH PROJECT DRIVER:	REL	LH SECTION #	145	



CAPITAL PROJECT SUMMARY SHEET SYSTEM SERVICE

Project Number: 18B7
Project Name: Backup Supply Installation
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Installation of Backup Supply

Risks to Completion & Mitigation Plan: Risk to completion is low. This project is part of a program that has been successfully executed in each of the past six years. The availability of resources (internal and contract) is sufficient to complete this project.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

Backup supply provides the opportunity of quicker power restoration in the event of a permanent fault in the underground system, with minimum impact on the customers load. This provides increased reliability for home owners and minimizes power interruptions.

Safety

There is no direct implication to safety from this program

Cyber-Security, Privacy

Not applicable

Co-ordination, Interoperability

Not applicable

Economic Development

Improved reliability will contribute to the overall attractiveness of London as a place to live and do business

Environmental Benefits

There is no direct impact on environmental benefits. However, shorter power restoration reduces crews' time in the field and hence, reduced emissions from operating trucks.

IMPACT TO O&M COSTS:

Less power interruptions have the potential for a reduction in annual operating and maintenance costs.

ALTERNATIVES CONSIDERED:


Customers can be supplied by radials but most faults in the underground system are permanent and repairs can last extended periods of time during which customers can experience long power outages unless backup supply is in place.

LINK TO STRATEGIC PLAN:

Section 6.2.1 - Emphasis on Reliability and Safety

CUSTOMER ENGAGEMENT:

Customers are not directly contacted for this project but surveys indicate increased customer value with improved reliability (refer to DSP Section 3.2.4 Customer Engagement).





CAPITAL PROJECT SUMMARY SHEET SYSTEM SERVICE


Project Number: 18B7
Project Name: Backup Supply Installation
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Installation of Backup Supply

Additional Information:


The blue phase (highlighted yellow) within the Belmont Subdivision does not have an alternate supply. Furthermore, three 3-phase transformers (circled yellow), rely on the same radial blue phase supply. The blue phase conductor at switchgear LC 4411 has only one source. If a cable fault occurred on it, interrupting the blue phase supply at LC 4411, then 222 residential customers, one public school and 12 general commercial customers would experience a long duration outage.


The scope of this project is to bring in another blue phase supply that bypasses LC 4411, which will mitigate the above risk by having a backup supply.



Prepared By: Rodney Doyle, P.Eng.
Senior Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations







CAPITAL PROJECT SUMMARY SHEET SYSTEM SERVICE

Project Number: 18B8
Project Name: Fault Indicator Installations
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Installation of Fault Indication in Padmounted Transformers

Supporting Reference Material: 2016 Quality of Supply Report

Description: Determining the location of faulted equipment on underground residential distribution systems can result in extended outage duration in the absence of fault indication devices. In areas where transformers do not have fault indicators, crews must search for visible failure signs inside each transformer and, if there are none, the cable between every two transformers must be tested to determine the location of the fault.

Modern fault indication technology allows for a quick assessment, without inspecting every transformer from the inside, in order to determine the location of a faulted segment and then isolate it. The power can be restored to the affected customers in a much shorter duration, relying on the indication provided by the transformers that "saw" fault current.

This item includes the installation of approximately 57 fault indicators in selected areas where transformer or cable failures have already been experienced. There exist a small number of transformers where fault indicators are already present; this project will provide fault indication at every transformer location, thus shortening the troubleshooting time for the crews and the outage duration for the customers in those subdivisions. These subdivisions are:
 1. White Oaks North 2. Lambeth area 3. Sevilla Park 4. Various Locations

PRIMARY DRIVER:	Efficiency	COST ESTIMATE - BY YEAR	
Modern			
OTHER DRIVERS:	Reliability	COST	AREA/SCOPE
	Customer Value	2012	\$14,902
		2013	\$17,316
		2014	\$12,102
		2015	\$12,000
		2016	\$15,036
		2017	\$16,235
		2018	\$20,000
		2019	\$20,000
		2020	\$20,000
		2021	\$21,000
CUSTOMERS IMPACTED:	Estimated 750		
			48 units
			48 units
			56 units
			65 units
			57 units
OEB CAPITAL REPORTING:			
	B7 -Misc. Subdivision Projects		
		TOTAL COST ESTIMATE:	\$168,591
LH PROJECT DRIVER:	REL	LH SECTION #	145



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM SERVICE**

Project Number: 18B8
Project Name: Fault Indicator Installations
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Installation of Fault Indication in Padmounted Transformers

Risks to Completion & Mitigation Plan:

Risk to completion is low. This project is part of a program that has been successfully executed in each of the past ten years. The availability of resources (internal labour) is sufficient to complete this project.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability	Shorter outages are achieved when fault indication is present in the underground distribution system. Older transformers can benefit of being retrofitted with fault indication. Select areas are covered based on subdivision performance and rehabilitation plans.
Safety	No direct impact for safety but locating a fault by patrolling the main road without accessing every transformer case exerts less physical effort.
Cyber-Security, Privacy	Not applicable
Co-ordination, Interoperability	Not applicable
Economic Development	Improved reliability will contribute to overall attractiveness of London as a place to live and do business.
Environmental Benefits	There are no direct environmental benefits. However, shorter troubleshooting time can result in operating the trucks for shorter durations, hence gas emissions are reduced.

IMPACT TO O&M COSTS:

Annual operating and maintenance costs will have a slight reduction due to reduced crew time responding to an outage.

ALTERNATIVES CONSIDERED:


Newer transformers with fault indication are currently installed in areas where the infrastructure is rebuilt/converted.

LINK TO STRATEGIC PLAN:

Section 6.2.1 - Emphasis on Reliability and Safety

CUSTOMER ENGAGEMENT:

Customers are not directly contacted for this project type but surveys indicate increased customer value with improved reliability (refer to DSP Section 3.2.4 Customer Engagement).






CAPITAL PROJECT SUMMARY SHEET SYSTEM SERVICE

Project Number: 18B8
Project Name: Fault Indicator Installations
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Installation of Fault Indication in Padmounted Transformers

Additional Information:

Sevilla Park: 17 units



Prepared By: Rodney Doyle, P.Eng.
Senior Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18B9
Project Name: 4.16 kV Underground Conversion
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Zone B and Zone C Underground Conversions

Supporting Reference Material: 4.16 kV Aging Infrastructure System Planning Report (2011), Appendix D
 Electric Distribution System Asset Sustainment Plan: 2015-2029 (2014)

Description: The Asset Sustainment Plan Report identified various parts of the system in this area as being in poor condition. The deficiencies related to the age of the equipment may adversely impact the reliability of supply as well as public and employee safety. The poles and associated hardware are approximately 50 years old. As well, the underground systems in these areas are in poor condition. The area will be converted from the 4.16 kV distribution system to the 27.6 kV distribution system as per the directive outlined in the 4.16 kV Aging Infrastructure System Planning Report.

PRIMARY DRIVER:	Reliability	COST ESTIMATE - BY YEAR	
OTHER DRIVERS:	Efficiency	2012	COST 3 TV's
	Customer Value	2013	\$103,296 9 TV's
		2014	\$400,236 2 TV's, 5 TE's & 1 SUB
		2015	\$328,092 2 TV's & 7 TE's
CUSTOMERS IMPACTED:	127	2016	\$431,033 7 TE's / 0.81 km primary
		2017	\$49,450 7 TE's/ 1.08 km primary
		2018	\$55,363 5 TEs / 0.51 km primary
		2019	\$139,000
		2020	\$42,000
OEB CAPITAL REPORTING:	B6 - Underground Conversions	2021	\$327,000
			\$448,000
		TOTAL COST ESTIMATE:	\$2,323,470
LH PROJECT DRIVER:	REL	LH SECTION #	145



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18B9
Project Name: 4.16 kV Underground Conversion
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Zone B and Zone C Underground Conversions

Risks to Completion & Mitigation Plan:

Risk to completion is low. Resources must be secured to co-ordinate timing with the overhead line conversion projects under Project 17G5. This project is part of a program that has been successfully executed in each of the past six years. The availability of resources (internal and contract) is sufficient to complete this project.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

Voltage conversion by zones is intended to off load multiple substations that provide backup to each other during the same time interval, so decommissioning is made possible without jeopardizing the ability to reliably supply these customers. Underground and overhead work is also co-ordinated for the most optimal system reconfiguration.

Safety

Safety of the operation staff is being improved throughout voltage conversion of underground plant since many of the existing padmount transformers are live front style, where the energized connections are exposed (see picture) and a risk of flashover exists when they are operated.

Cyber-Security, Privacy

Not applicable

Co-ordination, Interoperability

Co-ordination is required with overhead line projects in Section 17G5. New underground plant placement will be co-ordinated with other utilities.

Economic Development

Improved reliability will contribute to the overall attractiveness of London as a place in which to live and do business.

Environmental Benefits

Environmental benefits include elimination of very deteriorated transformers which could be leaking oil into the ground before being exchanged or removed.

IMPACT TO O&M COSTS:

Fewer outages can be expected as the supply changes to the new 27.6kV new system, resulting in a reduction in annual operating and maintenance costs.

ALTERNATIVES CONSIDERED:


Leave plant in service; however, this option is not acceptable as the plant reached its end of life and can no longer be properly and safely maintained

LINK TO STRATEGIC PLAN:

Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:

Property owners are contacted for discussion regarding pole relocations, new routing of underground cables, restoration, etc. Customers are provided with utility contact names after high level notifications regarding project scope.





CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18B9
Project Name: 4.16 kV Underground Conversion
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Zone B and Zone C Underground Conversions


Additional Information:

The initiatives outlined in the 4.16 kV Aging Infrastructure System Planning Report require converting all 4.16 kV load within Zone C, which covers the service territories for Substations 15, 40, 21 and 16. In addition, the proposed voltage conversion area requires rebuilding and converting deteriorating underground systems and transformer vaults, thus meeting the criteria outlined in the Asset Sustainment Plan Report. The deficiencies related to the age of the equipment may adversely impact the reliability of supply as well as public and employee safety, since some of the transformers are located in confined spaces within the customer's building.

The highlighted areas in the images below show the scope of underground conversions scheduled under Project 18B9. These areas coordinate with the overhead distribution being converted under Project 18G5.

**84-96 King Edward St.
TEs: 47, 48 & 49**

**409 Thompson Rd.
TEs: 4790 & 4791**



Prepared By: Rodney Doyle, P.Eng.
Senior Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18B10
Project Name: 13.8 kV Underground Conversion
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: 13.8 kV Underground Conversions of Non-Network Load and Customer Owned Substations

Supporting Reference Material: London Downtown - 13.8 kV/27.6 kV Nelson TS - 5 Year Plan

Description: The initiatives outlined in the "London Downtown - 13.8 kV/27.6 kV Nelson TS - 5 Year Plan" require converting the load on the 13.8 kV non-network system. In addition, the proposed voltage conversion area also requires the conversion of customer owned substations (CS).

The budget section includes work at the following locations:

- CS 296 - 382 Waterloo Street (YMCA)
- CS 315 - 675, 685 & 695 Richmond Street (Richmond Square).
- CS 277 - 11 Maitland Street (London Linen Services) - Coordinate with Project 18G4
- NT 84 - 383 Richmond Street (Royal Bank Building) - Coordinate with Project 18F3 (Dundas Place rebuild)
- Three-phase loop along Wellington Road between Bathurst Street and South Street containing 7 TEs and 4 SEs (the Wellington "Gateway")

It is anticipated that 4,482 kW of load will be converted from 13.8 kV distribution to 27.6 kV distribution. Projects and associated costs in this section vary annually based on timing of Customer conversion schedules and related 13.8 kV supply system conversions. The planned completion of the entire program is 2020.

PRIMARY DRIVER:	Reliability	COST ESTIMATE - BY YEAR		
		COST	AREA/SCOPE	
OTHER DRIVERS:	Customer Value	2012	\$0	
		2013	\$0	
		2014	\$0	
		2015	\$299,310	6 TE's & 1 SE
CUSTOMERS IMPACTED:	423	2016	\$803,314	14 TE's
		2017	\$741,551	5 TE's
		2018	\$1,310,000	3 CS, 7 TEs & 4 SEs
		2019	\$1,340,000	5 CS & 3 SE's
		2020	\$2,169,000	5 CS & 1 NT
		2021	\$0	
OEB CAPITAL REPORTING:		TOTAL COST ESTIMATE:		
B6 - Underground Conversions		\$6,663,175		
LH PROJECT DRIVER:	REL	LH SECTION #	145	



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18B10
Project Name: 13.8 kV Underground Conversion
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: 13.8 kV Underground Conversions of Non-Network Load and Customer Owned Substations

Risks to Completion & Mitigation Plan: Risks to completion are anticipated to be low. Availability of resources to match timing with the overhead line conversion projects will be addressed by securing resources (internal or contract) in advance. The only other risk that could potentially affect this project is getting approval from an owner to convert the customer's station, in which case we would install a step down transformer at a suitable location and leave the customer's service on 13.8 kV.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

Downtown's load serviced at 13.8kV is being converted to 27.6 kV by co-ordinating the overhead portion with the underground work. At the same time, the current 27.6 kV supply to the city core will be connected through new station ties connecting to existing commercial load, as well as future developments in the most reliable way. Efficiency is gained by eliminating multiple cables energized at multiple voltages and running only one 27.6 kV voltage system.

Safety

There are no direct safety issues associated with this project. However, obsolete customer-owned equipment is replaced with a more accessible and safer to operate automated system, such as load centres.

Cyber-Security, Privacy

Not applicable

Co-ordination, Interoperability

Various projects co-ordinate with other 13.8kV conversions (18C2, 18G4 or 18F3) and will require co-ordination with property owners.

Economic Development

Modern and reliable supply systems in the downtown core will encourage the development of new businesses, and thereby contribute to making London a prosperous city.

Environmental Benefits

The City of London is considering rapid transit in the years to come, a new advanced, green transportation system that will move through a revitalized downtown. London Hydro's enhanced electric supply will be able to accomodate all the new load emerging from this.

IMPACT TO O&M COSTS:

The modern and enhanced power supply in the downtown core energized at only 27.6 kV, coupled with a backup supply provided by new feeder ties, should contribute to decreased operating and maintenance costs throughout the year.

ALTERNATIVES CONSIDERED:

The non-network 13.8kV supply from the Nelson transformer station will no longer be available since Hydro One is rebuilding the station over the next five years. The load could be gradually transferred to the 27.6kV via stepdown transformation; capacity and reliability, however, could be at risk with downtown expansion.

LINK TO STRATEGIC PLAN:

Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:

Planned collaboration with building and property owners, as well as early stage involvement of customers is quintessential to the success of these projects. Engineering and Operations staff ensure proper communications at every stage.

Customer Substation CS 315:
675, 685 & 695 Richmond St.





**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18B10
Project Name: 13.8 kV Underground Conversion
Start Date: Jan-18
In-Service Date: Dec-18


Project Title: 13.8 kV Underground Conversions of Non-Network Load and Customer Owned Substations

Additional Information:

The initiatives outlined in the London Downtown - 13.8 kV/27.6 kV Nelson T: - 5 Year Planreport require converting all 13.8 kV load by year 2020 when Hydro One eliminates the only transformer station supplying this voltage. Converting the downtown load from 13.8 kV distribution, that had only one supply source, to the 27.6 kV distribution system, that has multiple supply sources, ensures a more reliable system to the city of London's core area and also aids in optimizing switching and load transferring amongst the other 27.6 kV stations.

Some of the benefits of the conversion work include:

- Two customer substation conversions eliminate primary switchgear which poses maintenance and liability issues between London Hydro and the customer owned distribution (NT 84 and CS 315).
- One customer substation distributes primary to three properties. Converting this one supply to three individual services will eliminate distribution trespass and reduce system losses (CS 315).
- The area known as Wellington Gateway (see adjacent image) involves the conversion of seven three-phase padmount transformers (TEs) and four switching enclosures (SEs) which are actively replaced on the 27.6 kV system.
- Conversion of a submersible transformer to London Hydro's newly created switchable vault transformer (NT 84).





**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM SERVICE**

Project Number: 18B11
Project Name: Outage Restoration Improvements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Adding Switchable Padmounted Transformers for Residential Supply

Supporting Reference Material: 2016 Quality of Supply Report

Description: Determining the location of faulted equipment on underground residential distribution systems, depending on how many fault indicators exist on a circuit, will affect the outage time for all the customers interrupted due to the fault. More so, if switchable padmounted transformers are not present, isolating a fault location can involve multiple operations and longer outage time for customers who could otherwise be restored sooner. In areas where older transformers do not permit isolating themselves from a loop one at a time, crews must isolate entire strings of transformers (from riser to open point) in order to isolate the faulted transformer or cable section and re-energize the healthy portion of the circuit.

Modern switchable transformers have two medium-voltage switches that permit the unit to be isolated upstream or downstream or completely removed from the loop before lifting the elbows. This new budget item aims to replace some of the live-front transformers or older non-switchable units that do not have this flexibility built in. By deploying more switchable padmounted transformers in subdivisions, the power can be restored to some of the unaffected customers in a much shorter duration.

It is anticipated that six (6) units will be installed in place of existing live-front transformers. This practice will continue with the goal of eliminating at least all live-front transformers, which also pose a safety hazard when operated due to the exposed energized components.

PRIMARY DRIVER: Modern	Efficiency	COST ESTIMATE - BY YEAR	
OTHER DRIVERS:	Reliability	2012	
	Customer Value	2013	
		2014	
		2015	
CUSTOMERS IMPACTED:	Estimated 100	2016	
		2017	
OEB CAPITAL REPORTING: B7 -Misc. Subdivision Projects		2018	\$50,000
		2019	
		2020	
		2021	
		TOTAL COST ESTIMATE:	
LH PROJECT DRIVER:	REL	LH SECTION #	145



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM SERVICE**

Project Number: 18B11
Project Name: Outage Restoration Improvements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Adding Switchable Padmounted Transformers for Residential Supply

Risks to Completion & Mitigation Plan:

Risk to completion is low. Although this is a newly added project, the availability of resources (internal labour) is adequate to complete the work.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

Shorter outages are achieved when fault indication is present in the underground distribution system. Switchable transformers present this feature by means of a "signaling light" and they also can be switched out from a circuit one at a time due to the two switching elements installed (referred to as "dash 1" and "dash 2").

Safety

The impact on safety is exercised by removing from service live-front units and replacing them with switchable transformers.

Cyber-Security, Privacy

Not applicable

Co-ordination, Interoperability

Not applicable

Economic Development

Improved reliability will contribute to overall attractiveness of London as a place to live and do business.

Environmental Benefits

There are no direct environmental benefits. However, shorter troubleshooting time can result in operating the trucks for shorter durations, hence gas emissions are reduced.

IMPACT TO O&M COSTS:

Annual operating and maintenance costs will have a slight reduction due to reduced crew time responding to an outage.

ALTERNATIVES CONSIDERED:


Newer switchable transformers are currently installed in areas where the infrastructure is rebuilt/converted.

LINK TO STRATEGIC PLAN:

Section 6.2.1 - Emphasis on Reliability and Safety

CUSTOMER ENGAGEMENT:

Customers are not directly contacted for this project type but surveys indicate increased customer value with improved reliability (refer to DSP Section 3.2.4 Customer Engagement).



Internal Electrical Arrangement of Fusing and Switching Elements



CAPITAL PROJECT SUMMARY SHEET SYSTEM SERVICE


Project Number: 18B11
Project Name: Outage Restoration Improvements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Adding Switchable Padmounted Transformers for Residential Supply

Additional Information:

Installation of switchable transformers in subdivisions allows for faster fault restoration. Once a fault has been identified, the fault location can be isolated quicker while using switchable transformers, and more customers affected initially can be restored sooner.

Below is a map that shows the transformers that were selected for replacement next year (in yellow). All the units are live-front transformers and by replacing them with switchable transformers, sectionalizing will become possible.



Prepared By: Rodney Doyle, P.Eng.
Senior Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM SERVICE**

Project Number: 18B12
Project Name: Civil Works for Improved Outage Restoration
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Installing Spare Duct for Improved Restoration Time at Multiunit Radial Customers

Supporting Reference Material: 2016 Quality of Supply Report

Description: London Hydro has increasingly started to experience outages on older underground cable supplying multi-unit radial customers (e.g. commercial developments, apartment buildings). When the cable is not ducted or no available spare duct exists, outage times tend to be very long (up to 8 hours or higher) because the fault needs to be located and fixed before re-energization.

This budget item provides for additional civil work to improve the speed at which power can be restored to these customers and enhance the reliability of supply by installing new spare duct.

PRIMARY DRIVER:	Customer Value	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Reliability	2012		
		2013		
		2014		
		2015		
CUSTOMERS IMPACTED:	Various	2016		
		2017		
		2018	\$50,000	
OEB CAPITAL REPORTING	B7 - Misc. Subdivision Projects	2019		
		2020		
		2021		
		TOTAL COST ESTIMATE:		\$50,000
LH PROJECT DRIVER:	REL	LH SECTION #	145	



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM SERVICE**

Project Number: 18B12
Project Name: Civil Works for Improved Outage Restoration
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Installing Spare Duct for Improved Restoration Time at Multiunit Radial Customers

Risks to Completion &

Mitigation Plan: Risk to completion is low. Although this is a newly added project, the availability of resources (internal labour) is adequate to complete the work.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

Spare ducts for radially fed customers provide the opportunity of quicker power restoration by pulling new cable in the event of a permanent fault in the underground system, which takes longer to repair. This is also a program that can facilitate the next step of asset renewal when these type of aged cables will be due for replacement.

Safety

There is no direct implication to safety from this program

Cyber-Security, Privacy

Not applicable

Co-ordination, Interoperability

Not applicable

Economic Development

Improved reliability will contribute to the overall attractiveness of London as a place to live and do business

Environmental Benefits

There is no direct impact on environmental benefits. However, shorter power restoration reduces crews' time in the field and hence, reduced emissions from operating trucks.

IMPACT TO O&M COSTS:

Less power interruptions have the potential for a reduction in annual operating and maintenance costs.

ALTERNATIVES CONSIDERED:

Customers can be supplied by radials but most faults in the underground system are permanent and repairs can last extended periods of time during which customers can experience long power outages unless failed cable can easily be replaced by new cable.

LINK TO STRATEGIC PLAN:

Section 6.2.1 - Emphasis on Reliability and Safety

CUSTOMER ENGAGEMENT:

Customers are not directly contacted for this project but surveys indicate increased customer value with improved reliability (refer to DSP Section 3.2.4 Customer Engagement).



CAPITAL PROJECT
SUMMARY SHEET
SYSTEM SERVICE

Project Number: 18B12
Project Name: Civil Works for Improved Outage Restoration
Start Date: Jan-18
In-Service Date: Dec-18


Project Title: Installing Spare Duct for Improved Restoration Time at Multiunit Radial Customers


Additional Information:

This item will target larger multiunit radial customers where the underground supply is direct buried, which can significantly prolong the duration of an outage having to repair the faulted cable. By providing a spare duct, restoration time can be improved as the underground crews have a means to replace the cable instead of locating the fault, digging up and splicing the phase that faulted. Our GIS system will be used to create a report of locations where cable is aged (25+ years old), it is a radial feed to a multiunit apartment building, direct buried. The selection will be made based on performance experienced over the course of the last few years for radial underground customers where risk of cable failure is higher.

Prepared By: Rodney Doyle, P.Eng.
Senior Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations







CAPITAL PROJECT SUMMARY SHEET

SYSTEM SERVICE

Project Number: 18C1
Project Name: 27.6 kV Supply to Core
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Main Feeder Backup Supply to Core (Electrical)

Supporting Reference Material: London Downtown Long Term 27.6 kV Supply and 13.8 kV Decommissioning Strategy
 London Downtown - 13.8 kV/27.6 kV Nelson TS - 5 Year Plan
 QSI: Monthly Reliability Performance Overview - August 2017

Description: London Downtown is presently supplied mainly through the older 13.8 kV Non-Network and Network systems via Nelson Transformer Station (TS). Nelson TS is a double DESN with the T1/T2 supplying the 3-wire Network system, and the T3/T4 supplying the 4-wire Non-Network system. Hydro One is rebuilding the T1/T2 DESN to 27.6 kV standards and this new supply is expected to be in service by December 2018 while the T3/T4 DESN will be eliminated by end of 2020.

In preparation for the new 27.6 kV Nelson TS in-service date, this project intends to install three (3) new 27.6 kV circuits from the new Nelson TS to supply the downtown ring-bus and offload Talbot TS that presently supplies the ring.

The new Nelson 27.6 kV supply to the downtown core will provide many benefits:

- increase adequacy and security of supply;
- enable the connection of distributed generation in the core;
- potential to replace aging infrastructure including elimination of lead cable, and
- assist with voltage conversion of the 4-wire Non-Network system load to 27.6 kV, in preparation for the T3/T4 DESN phased out.

This project is expected to impact over 4,000 customers in the service territory for Nelson TS.

In addition to the above the 26M47 egress cable from Talbot TS, although 28 years old, has had numerous faults and it needs replacing, based on recent inspections revealing indication of excessive heating. This project impacts over 1400 customers.

PRIMARY DRIVER:	Reliability	COST ESTIMATE - BY YEAR	
		COST	AREA/SCOPE
OTHER DRIVERS:	Reliability	2012	
	Safety	2013	\$1,124,173
	Customer Value	2014	\$319,016
	Econ. Dev.	2015	\$153,939
CUSTOMERS IMPACTED:		2016	\$1,145,424
		2017	\$3,442,000
	5,000+	2018	\$1,710,000
		2019	\$0
		2020	\$0
OEB CAPITAL REPORTING:		2021	\$0
C1 - Reinforcement		TOTAL COST ESTIMATE: \$7,894,552	
LH PROJECT DRIVER:	RNF	LH SECTION #	140



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18C1
Project Name: 27.6 kV Supply to Core
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Main Feeder Backup Supply to Core (Electrical)

Risks to Completion & Mitigation Plan: Risks that could potentially affect this project significantly include unknown underground conditions such as collapsed ducts and unforeseen City of London projects. If these situations arise, alternative routes will have to be re-evaluated.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

The new feeders from Nelson TS will increase system reliability and reduce customer outage durations during system contingency scenarios. As well, the additional feeders to the core permits the renewal and upgrade of old deteriorated electrical infrastructure.

Safety

Not Applicable

Cyber-Security, Privacy

Not Applicable

Co-ordination, Interoperability

This project will permit the interconnection of Nelson TS and Talbot TS for increased reliability and operational flexibility during contingencies.

Economic Development

Additional capacity to support the economic development initiatives of the City of London and its intensification plans as outlined in the City's London Plan. Also permits the connection of generation.

Environmental Benefits

Penetration of 27.6 kV supply to the core facilitates the removal of aging infrastructure containing lead.

IMPACT TO O&M COSTS:

There may be a slight reduction in the long run as the additional equipment facilitates renewal of old infrastructure leading to outages.

ALTERNATIVES CONSIDERED:

Do nothing; however, this alternative was rejected due to the risk it would pose to supply reliability.

LINK TO STRATEGIC PLAN:

Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:

Customers were not directly engaged regarding this project, but recent surveys indicate customers value improvements to reliability (refer to DSP Section 3.2.4 Customer Engagement).



Nelson TS
New feeders to Sub 11 and downtown to offload Talbot TS



Sub 11
Supplies downtown currently from Talbot TS



CAPITAL PROJECT SUMMARY SHEET SYSTEM SERVICE

Project Number: 18C1
Project Name: 27.6 kV Supply to Core
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Main Feeder Backup Supply to Core (Electrical)

Additional Information:


New 27.6 kV Nelson TS Feeders (coordinate with Project 18C3)

The new feeder routing is as illustrated:

- 1) Red Circuit: 1st of two new main supplies to Sub 11.
 - 2) Green Circuit: 2nd of two new main supplies to Sub 11.
- Note: Red and Green circuits offload Sub 11 from Talbot TS.
 Sub 11 new supply from Nelson TS.
 Sub 11 supplies downtown core ringbus.
- 3) Blue Circuit: Offloads Talbot TS 26M48 feeder
- Note: Blue circuit will permit the 26M48 (with reduced load) to backup Talbot TS 26M51 feeder. Both feeders supply non-ringbus downtown load.

26M47 Cable Egress Replacement:

Its route highlighted below amounts to approximately 3 km of egress. This egress cable was originally installed in 1990. Over the past ten years, it has experienced seven faults. The results of recent inspections indicate evidence of excessive heating, and due to the number of faults London Hydro Engineers have deemed this cable to have reached the end of its useful service life and planned for its replacement.



Prepared By: Rodney Doyle, P.Eng.
 Senior Distribution Engineer

Approved By: William Milroy, P.Eng.
 Chief Engineer &
 V.P. of Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18C2
Project Name: 13.8 kV Conversion Main Feeders
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: 13.8 kV Conversion of Main Feeders

Supporting Reference Material: London Downtown - 13.8 kV/27.6 kV Nelson TS - 5 Year Plan

Description: A multi-year voltage conversion of 13.8 kV loads to 27.6 kV will facilitate the removal of aging distribution infrastructure, as well as address the long term strategic plans described in the London Downtown - 13.8 kV/27.6 kV Nelson TS - 5 Year Plan report which recommends the conversion of the non-network downtown core to 27.6 kV supply.

The work proposed is the fourth year of a multi-year strategic plan to resupply non-network 13.8 kV loads at 27.6 kV supply. This work is also co-ordinated with other plans that will address the age and condition of the existing 13.8 kV Nelson TS supply from Hydro One.

PRIMARY DRIVER:	Reliability	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Efficiency			
	Econ. Dev.	2012	COST	AREA/SCOPE
		2013	\$0	
		2014	\$545,748	
		2015	\$470,000	
CUSTOMERS IMPACTED:	240	2016	\$667,000	1,400 kW
		2017	\$472,200	2,092 kW
		2018	\$805,000	1,860 kW
		2019	\$275,000	
OEB CAPITAL REPORTING:		2020	\$275,000	
C3 - Conversions		2021	\$0	
		TOTAL COST ESTIMATE:		\$3,509,948
LH PROJECT DRIVER:	RNF	LH SECTION #	140	



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18C2
Project Name: 13.8 kV Conversion Main Feeders
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: 13.8 kV Conversion of Main Feeders

Risks to Completion & Mitigation Plan:

Availability of resources to match timing with the 13.8 kV underground plant conversion projects; mitigation plan is close co-ordination with the overhead line projects and securing resources (internal or contract) to ensure completion.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

The conversion of the main 13.8 kV non-network feeders will be completed according to the multi-year plan to off load Nelson TS. In following the plan, the non-network load will gradually be switched over to the much more reliable 27.6 kV system, with increased alternatives for backup during contingencies. Older infrastructure will also be eliminated in co-ordination with voltage conversion of the loads supplied by the 13.8 kV overhead system.

Safety

In converting 13.8 kV main feeders, any depreciated plant, such as poles, will be eliminated from the system, increasing safety overall.

Cyber-Security, Privacy

Not applicable

Co-ordination, Interoperability

Concurrent with executing the negotiated Connection Cost Recovery Agreement (CCRA) with Hydro One for the upgrade of Nelson TS, London Hydro was engaged with the IESO, the OPA, and Hydro One on the OEB's Regional Planning Process (RPP).

Economic Development

Improved reliability will contribute to overall attractiveness of London as a place in which to live and do business

Environmental Benefits

There are no direct environmental benefits associated with this project; some material (e.g., wire) may be recycled in the process.

IMPACT TO O&M COSTS:

Annual operating and maintenance costs may be reduced due to fewer outages related to a newly converted system.

ALTERNATIVES CONSIDERED:

Voltage conversion of all 13.8 kV non-network load must be completed by 2020. An evaluation of the challenges encountered in this project leaves as an option some temporary supply via step-down transformation at selected locations where load still needs to be supplied at 13.8 kV.

LINK TO STRATEGIC PLAN:

Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:

At the design stage, when changing the physical layout of the distribution system, property owners may be invited to discuss placement options of poles, potential new routing, etc.





CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL


Project Number: 18C2
Project Name: 13.8 kV Conversion
Main Feeders
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: 13.8 kV Conversion of Main Feeders

Additional Information:

The initiatives outlined in the London Downtown - 13.8 kV/27.6 kV Nelson TS - 5 Year Plan report require converting all 13.8 kV load by year 2020 when Hydro One eliminates the only transformer station supplying this voltage. Converting the downtown from 13.8 kV distribution, that had only one supply source, to the 27.6 kV distribution system, that has multiple supply sources, ensures a more reliable system to London's core area and also aids in optimizing switching and load transferring amongst the other 27.6 kV stations.

Under this project item it is anticipated that approximately 1,860 kW of 13.8 kV load will be converted to the 27.6 kV distribution system. The general project area covers the overhead plant as illustrated below (in yellow) including preliminary work for the mobile transformer at Sub-8. Upon successful conversion of the planned load, it is anticipated there will be an additional 574 kW of 13.8 kV main feeder load remaining to convert by year 2020.



Prepared By: Sunny Patel, P.Eng.
Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



CAPITAL PROJECT SUMMARY SHEET SYSTEM SERVICE

Project Number: 18C3
Project Name: Civil Structure Installation
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Installation of Civil Structure

Supporting Reference Material: City of London: The London Plan

Description: The City of London will be conducting extensive civil infrastructure rehabilitation along the following streets:

- 1) Dundas Street: from Wellington Road to the Thames River (construction phased over 2 years)
- 2) York Street: from Colborne Street to Thames River (construction phased over 3 years)
- 3) Talbot Street: from Kent Street to Fullerton Street

All projects will start in early 2018. In conjunction with the City's projects, London Hydro will replace most of its existing concrete encased duct and maintenance hole systems, whose audits revealed the structural integrity is at, or nearing, its useful lifespan.

In collaboration with Project 18F3, London Hydro will rebuild and modernize the existing electrical distribution system along Dundas Street to a 27.6 kV system; York and Talbot Street projects will replace existing structure and reroute existing cables. The installation of these civil infrastructures will also permit London Hydro to install future main feeder circuits and provide the City's Core with the 27.6 kV supply.

Additionally, in collaboration with Project 18F1, London Hydro will require to construct new concrete encased duct and maintenance hole systems at the new Nelson Tranformer Station to permit the egress of the new feeders.

PRIMARY DRIVER:	Co-ordination	COST ESTIMATE - BY YEAR	
OTHER DRIVERS:	Efficiency	2012	COST
	Reliability	2013	AREA/SCOPE
	Econ. Dev.	2014	\$0
	Environmental	2015	\$0
CUSTOMERS IMPACTED:	Various	2016	\$1,005,000
		2017	\$1,835,000
		2018	\$690,000
		2019	\$1,600,000
		2020	\$3,850,000
		2021	\$1,200,000
OEB CAPITAL REPORTING:		2020	\$200,000
C1 - Reinforcements		2021	\$1,200,000
		TOTAL COST ESTIMATE:	
		\$11,580,000	
LH PROJECT DRIVER:	RNF	LH SECTION #	141



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18C3
Project Name: Civil Structure Installation
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Civil Structure Installation

Risks to Completion & Mitigation Plan: Availability of resources to match timing dictated by the City; mitigation plan is close co-ordination with the City to ensure schedules are compatible and to secure resources (contract) in a joint tender with the City. This is a very complex project that requires much planning and design time; mitigation plan is to press the City to commit to the project at least one year in advance to provide sufficient time for planning and design.

EVALUATION OF OUTCOMES:	
Efficiency, Customer Value, Reliability	This project involves the replacement of the old duct and maintenance holes and electrical equipment that are nearing the end of useful life with new duct structure and maintenance holes, modernized electrical equipment and 27.6 kV feeders. The efficiency is gained by removing multiple cables supplied by various systems and installing and operating only 27.6 kV feeders.
Safety	The safety component relies on the fact that new maintenance holes will provide a safer environment for our employees to access and perform work.
Cyber-Security, Privacy	Not applicable
Co-ordination, Interoperability	This project is co-ordinated with the City of London and other utilities to minimize costs and for efficient completion of civil infrastructure installation.
Economic Development	Additional capacity in the core supports the economic development initiatives of the City of London and its intensification plans as outlined in the City's London Plan.
Environmental Benefits	Environmental benefits are related to future new cable installations that will allow London Hydro to eliminate lead cable present in the downtown supply system.

IMPACT TO O&M COSTS:
 New civil infrastructure installations permit London Hydro to find new routes for underground supply cable, which can free up and allow decommissioning of other old structures that would otherwise require maintenance to remain in service.

ALTERNATIVES CONSIDERED:
 London Hydro can commit to projects related to civil infrastructure installation on its own, using its own contractors at the time when projects evolve. This is a much more costly option than co-ordinating with the City.

LINK TO STRATEGIC PLAN:
 Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:
 Multiple parties are involved in discussion throughout this project, in co-ordination with the City of London, property owners, commercial customers and other parties affected (e.g. other utilities).






CAPITAL PROJECT SUMMARY SHEET SYSTEM SERVICE

Project Number: 18C3
Project Name: Civil Structure Installation
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Installation of Civil Structure

Additional Information:

The scope for civil structure installations by street are highlighted below. Costs include depopulating cable from vaults.



Prepared By: Rodney Doyle, P.Eng.
Senior Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18C4
Project Name: Main Feeder Ties
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: New 27.6 kV Main Feeder Ties

Supporting Reference Material: London Area Regional Infrastructure Plan (2017)
 Electric Distribution System Asset Sustainment Plan: 2015-2029 (2014)

Description: Significant residential and commercial development in the city's North-West end has resulted in load growth exceeding reliable operating limits on the existing distribution feeders. Presently, Wonderland TS is being utilized to support this additional load growth, however, load must be reduced as this station is operating above its 10-day Limited Time Rating (LTR) as identified in the Regional Planning exercises with Hydro One and the IESO.

This project involves building a new feeder circuit from Talbot TS to support the load growth in the North-West and assist in reducing load on Wonderland TS. Minimal new pole construction will be required as this feeder build will leverage the spare provisions on existing poles.

PRIMARY DRIVER:	Reliability	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Efficiency	2012	COST	AREA/SCOPE
	Customer Value	2013	\$0	
	Econ. Dev.	2014	\$0	
CUSTOMERS IMPACTED:	6,000+	2015	\$776,043	
		2016	\$1,623,919	685kW converted
		2017	\$85,576	
		2018	\$150,000	1 Project
		2019	\$653,000	
		2020	\$650,000	295kW converted
OEB CAPITAL REPORTING:		2021	\$2,100,000	
C4 - Main Feeder		TOTAL COST ESTIMATE:		\$6,038,538
LH PROJECT DRIVER:	RNF	LH SECTION #		140



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18C4
Project Name: Main Feeder Ties
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: New 27.6 kV Main Feeder Ties

Risks to Completion & Mitigation Plan:

Risks to completion are limited. The availability of resources (internal and contractor) is sufficient to complete this project.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

This project is initiated as a result of a System Planning directive to provide load support in the North-West end of the City and to Wonderland TS. Customers will benefit from the additional capacity and reliable supply to support load growth and increase reconfiguration options under system contingencies.

Safety

Not applicable

Cyber-Security, Privacy

Not applicable

Co-ordination, Interoperability

Not applicable

Economic Development

Additional capacity and improved reliability will contribute to overall attractiveness of London as a place in which to live and do business.

Environmental Benefits

Not applicable

IMPACT TO O&M COSTS:

Remain the same or increase slightly due to the newly constructed backbone system.

ALTERNATIVES CONSIDERED:

Do nothing, however this alternative was rejected since the existing distribution system is operating at the edge of its reliable limits due to increased loads as a result of the commercial and residential development experienced in the North-West.

LINK TO STRATEGIC PLAN:

Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:

Customers were not directly engaged regarding this project, but recent surveys indicate customers value improvements to reliability (refer to DSP Section 3.2.4 Customer Engagement).





CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18C4
Project Name: Main Feeder Ties
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: New 27.6 kV Main Feeder Ties

Additional Information:

This new feeder tie will generally run along:

- 1) Oxford St. between Wharnccliffe Rd. and Wonderland Rd.,
- 2) Wonderland Rd. between Oxford St. and Sarnia Rd.,
- 3) Sarnia Rd. between Wonderland Rd. and Hyde Park Rd.

This feeder build will offload the 26M54 and provide a feeder tie to Wonderland TS to permit greater load transfer capability within the city's rapidly developing North-West end. This build will also facilitate feeder reconfiguration to better balance loading and improve reliability.

Prepared By: Sunny Patel, P.Eng.
Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18CC1
Project Name: Nelson TS
Start Date: Jan-18
In-Service Date: 2018

Project Title: Neslon TS Conversion to 27.6 kV Hydro One Payments

Supporting Reference Material:
 1) London Downtown Long Term 27.6kV Supply and 13.8kV Decommissioning Strategy
 2) London Downtown - 13.8kV/27.6kV Nelson TS - 5 Year Plan

Description: This project is established to track the required payments to Hydro One for the decommissioning of the 13.8kV Substation and the conversion of the Substation to 27.6kV. This project assumes that we expend/borrow the \$2,000,000 evenly. Also, since the OEB provides the CWIP rates quarterly the \$2M is broken down into \$500k quarters.

The AFUDC expenses that would hit the books quarterly for each year as well as a running Project Total for the Capitalized interest is show below..

2.70%	2.70%	2.70%	2.70%	365			
	Pmt	Int	Balance				
8/31/15	1,600,000		1,600,000				
9/30/15		3,551	1,603,551	30			
12/31/15		10,913	1,614,464	92		14,000	2015 Total AFUDC
3/15/16	1,750,000		3,364,464				
3/31/16		12,939	3,377,403	91	16		
6/30/16		22,735	3,400,138	91			
9/30/16		23,140	3,423,277	92			
12/31/16		23,297	3,446,574	92		82,000	2016 Total AFUDC
3/15/17	1,750,000		5,196,574				
3/31/17		25,017	5,221,591	90	16		
6/30/17		35,149	5,256,740	91			
9/30/17		35,775	5,292,515	92			
12/31/17		36,018	5,328,533	92		132,000	2017 Total AFUDC
3/15/18	1,750,000		7,078,533				
3/31/18		37,546	7,116,079	90	16		
6/30/18		47,902	7,163,981	91			2018 Total AFUDC
7/31/18			7,163,981				
8/31/18			7,163,981				
9/30/18		-	7,163,981	92			
10/31/18			7,163,981				
11/30/18			7,163,981				
12/31/18		-	7,163,981	92		85,000	
	6,850,000	313,981				313,000	Total Project AFUDC
3/15/21	1,450,000						Final Payment

PRIMARY DRIVER:	Reliability	COST ESTIMATE - BY YEAR <table border="0"> <thead> <tr> <th></th> <th>COST</th> <th>AREA/SCOPE</th> </tr> </thead> <tbody> <tr> <td>2012</td> <td></td> <td></td> </tr> <tr> <td>2013</td> <td></td> <td></td> </tr> <tr> <td>2014</td> <td></td> <td></td> </tr> <tr> <td>2015</td> <td>\$1,614,464</td> <td></td> </tr> <tr> <td>2016</td> <td>\$1,832,111</td> <td></td> </tr> <tr> <td>2017</td> <td>\$1,881,959</td> <td></td> </tr> <tr> <td>2018</td> <td>\$1,835,000</td> <td></td> </tr> <tr> <td>2019</td> <td>\$250,000</td> <td></td> </tr> <tr> <td>2020</td> <td></td> <td></td> </tr> <tr> <td>2021</td> <td>\$1,450,000</td> <td></td> </tr> <tr> <td colspan="2">TOTAL COST ESTIMATE:</td> <td>\$8,863,534</td> </tr> </tbody> </table>		COST	AREA/SCOPE	2012			2013			2014			2015	\$1,614,464		2016	\$1,832,111		2017	\$1,881,959		2018	\$1,835,000		2019	\$250,000		2020			2021	\$1,450,000		TOTAL COST ESTIMATE:		\$8,863,534
	COST		AREA/SCOPE																																			
2012																																						
2013																																						
2014																																						
2015	\$1,614,464																																					
2016	\$1,832,111																																					
2017	\$1,881,959																																					
2018	\$1,835,000																																					
2019	\$250,000																																					
2020																																						
2021	\$1,450,000																																					
TOTAL COST ESTIMATE:		\$8,863,534																																				
OTHER DRIVERS:	Customer Value Econ. Dev. Environmental																																					
CUSTOMERS IMPACTED:	Directly: 2,000 Indirectly: 4,000																																					
OEB CAPITAL REPORTING:	C1 - Reinforcements																																					
LH PROJECT DRIVER:	RNF	LH SECTION # 140																																				



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18CC1
Project Name: Nelson TS
Start Date: Jan-18
In-Service Date: 2018

Project Title: Neslon TS Conversion to 27.6 kV Hydro One Payments

Risks to Completion & Mitigation Plan:

EVALUATION OF OUTCOMES:

<p>Efficiency, Customer Value, Reliability</p>	<p>As a result of this project, the adequacy and security of supply to the downtown will increase as it will providing additional capacity for growth.</p>
<p>Safety</p>	<p>Not Applicable</p>
<p>Cyber-Security, Privacy</p>	<p>Not Applicable</p>
<p>Co-ordination, Interoperability</p>	<p>Not Applicable</p>
<p>Economic Development</p>	<p>Additional capacity in the core supports the economic development initiatives of the City of London and its intensification plans as outlined in the City's London Plan.</p>
<p>Environmental Benefits</p>	<p>Penetration of the 27.6kV supply to the core facilitates the removal of aging infrastructure containing lead.</p>

IMPACT TO O&M COSTS:

There may be a slight reduction in the long run as the additional equipment facilitates renewal of old infrastructure leading to fewer outages.

ALTERNATIVES CONSIDERED:

Considered Do Nothing option along with other options for routing and placement of Load Centres to arrive at a cost efficient and optimal solution.

LINK TO STRATEGIC PLAN:

Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:

Customers were not directly engaged regarding this project, but recent surveys indicate customers value improvements to reliability (refer to DSP Section 3.2.4 Customer Engagement).

INSERT PICTURE HERE



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18CC1
Project Name: Nelson TS
Start Date: Jan-18
In-Service Date: 2018

Project Title: Neslon TS Conversion to 27.6 kV Hydro One Payments

Additional Information:

Part 4: Manner of Payment

The Customer shall make the following progress payments (plus HST) towards the Facilities Upgrade Contribution by on or before the Payment Milestone Date specified below. Hydro One will invoice the Customer for each progress payment 30 days prior to the Payment Milestone Date.

Progress Payment No.	Payment Milestone Date	Total Payment Required (plus HST)
1	June 15, 2015	\$1,600,000 plus HST in the amount of \$208,000*
2	March 15, 2016	\$1,750,000 plus HST in the amount of \$227,500*
3	March 15, 2017	\$1,750,000 plus HST in the amount of \$227,500*
4	March 15, 2018	\$1,750,000 plus HST in the amount of \$227,500*
5	Earlier of March 15, 2021 or 3 months prior to the date scheduled by Hydro One to commence decommissioning of the T3/T4 DESN***	\$1,450,000 plus HST in the amount of \$188,500**

Should the Customer default in paying any amount to Hydro One, Hydro One reserves the right to add the AFUDC as it deems necessary.

* Progress payments 1-4 are collectively, the First Reconciliation Customer Progress Payments

** Progress payment 5 is the Second Reconciliation Customer Payment.

*** The Customer acknowledges and agrees that if Hydro One is able to commence the decommissioning of the T3/T4 DESN prior to March 15, 2021, the Customer is required to make the Second Reconciliation Customer Payment by no later than 3 months prior to the date that Hydro One has scheduled for Hydro One to commence the decommissioning work. Hydro One shall notify the Customer, in writing, should Hydro One be able to schedule the commencement of the decommissioning work prior to March 15, 2021.

Prepared By:

Approved By: Ken Walsh, P.Eng.
Chief Engineer &
V.P. of Operations



CAPITAL PROJECT SUMMARY SHEET SYSTEM ACCESS

Project Number: 18D1
Project Name: City of London (Road Authority) Relocations
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: City of London (Road Authority) Relocations

Supporting Reference Material:

Infrastructure Replacement List (2014-2023), City of London
 2014 Transportation Development Charge - Background Study, City of London (May 2014)
 2030 Transportation Master Plan - SmartMoves (May 2013)
 London Rapid Transit (SHIFT)
 Public Service Works on Highways Act

Description:

This project involves the relocation of London Hydro Infrastructure located on the road allowance. These relocations are initiated by the Road Authority (City of London) and are necessary in order to accommodate planned modifications to the roadway.

The terms and conditions under which these relocations occur are specified in the Public Service Works on Highways Act enacted by the Provincial Government. The Act gives a Road Authority the power to ensure that all operating corporations entitled to the use of the road allowance cooperate with the Road Authority to execute any required modifications to the profile of the road allowance in a timely manner. The Act states that an Operating Corporation (London Hydro Inc.) must modify or relocate their plant on the road allowance to accommodate the Road Authority's improvements or alterations within a specified time period. The Act also outlines the mechanism for the apportionment of costs for these required works. Typically the Operating Corporation is permitted to recover 50% of the labour and vehicle costs from the Road Authority.

PRIMARY DRIVER:	Co-ordination	COST ESTIMATE - BY YEAR	
OTHER DRIVERS:	Econ. Dev.	2012	\$1,589,553
	Customer Value	2013	\$991,465
	Safety	2014	\$1,928,812
		2015	\$1,520,000
CUSTOMERS IMPACTED:	Various	2016	\$3,025,000
		2017	\$3,066,121
		2018	\$4,330,100
		2019	\$1,695,000
		2020	\$1,670,000
		2021	\$730,000
OEB CAPITAL REPORTING		TOTAL COST ESTIMATE:	\$20,546,051
D1 - City Road Authority Relocates			
LH PROJECT DRIVER:	COL	LH SECTION #	133



CAPITAL PROJECT SUMMARY SHEET SYSTEM ACCESS

Project Number: 18D1
Project Name: City of London (Road Authority) Relocations
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: City of London (Road Authority) Relocations

Risks to Completion & Mitigation Plan: Availability of resources to match timing dictated by the City of London; mitigation plan is close co-ordination with the City to ensure schedules are compatible; some projects may require new infrastructure to be designed, ordered, constructed; mitigation plan is to push the City to commit to projects at least one year in advance to provide ample lead time for planning.


EVALUATION OF OUTCOMES:	
Efficiency, Customer Value, Reliability	Past projects have demonstrated it is most efficient to build new infrastructure at the new location, rather than attempt relocating the existing infrastructure; this results in newer infrastructure which will be more reliable.
Safety	Renewed infrastructure and new design standards improve the safety of the distribution system
Cyber-Security, Privacy	Not Applicable
Co-ordination, Interoperability	Significant co-ordination is required with the municipality and other utilities; where possible, a single contractor is used to install civil works
Economic Development	Municipal road widenings are part of the City's overall economic development plan to enhance growth, and this project supports that plan.
Environmental Benefits	Not Applicable

IMPACT TO O&M COSTS:
 Annual operating and maintenance costs may be reduced since newly installed infrastructure will experience fewer outages.

ALTERNATIVES CONSIDERED:
 In most cases there are no alternatives; if possible, design alternatives that reduce impact to utility plant are considered.

LINK TO STRATEGIC PLAN:
 6.2.1 - Emphasis on Reliability - Growth

CUSTOMER ENGAGEMENT:
 The City of London leads customer interaction on road widening projects; London Hydro initiates contact with customers to explain the driver for hydro work, potential service interruptions, surface restoration responsibilities, and overall schedule.





CAPITAL PROJECT SUMMARY SHEET SYSTEM ACCESS


Project Number: 18D1
Project Name: City of London (Road Authority) Relocations
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: City of London (Road Authority) Relocations

Additional Information:

The city works are externally driven and mostly attributed to growth. The City of London is following a multi-year plan to meet the City's growing transportation needs and new developments. Working in collaboration with the City and other utilities, infrastructure assets are relocated in advance of city works, typically one to two years ahead of time.

The 2018 budget for this section is higher than in previous years. These increased expenditures are attributed to aggressive city plans, which are outlined in documents such as: "2030 Transportation Master Plan - Smart Moves (May 2013)", "London Rapid Transit (SHIFT)", and "2014 Transportation Development Charge Background Study, City of London (May 2014)".



City of London 2014 Transportation Development Charge Background Study

Legend

- Rail Line
- City of London Limits
- Water
- Urban Growth Boundary
- Road Improvements**
- Work Type**
- 2 to 4 Lanes
- 2 Lane Upgrade
- 3 to 4 Lanes
- 4 to 6 Lanes
- New Interchange/Improvements
- Intersection Improvements
- BRT (Optimization)
- New 2 Lane
- New 4 Lane
- Optimization
- Overpass
- Widen for BRT (4-6 lanes)

Figure ES-2:

**Major Transportation
Roadworks**

Prepared By: Sunny Patel, P.Eng.
Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM ACCESS**

Project Number: 18E1
Project Name: Expansions and Relocations
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Developer Driven Distribution Circuits Expansions and Relocations

Supporting Reference Material: London Hydro Conditions of Service (August 2017)

Description: This budget item includes extension of the existing high voltage overhead or underground distribution system in order to accommodate new customer developments as they are added to London's service area. This budget item includes all costs associated with the construction of these extensions. At present time we are not aware of any expansion projects. Historically we build at least one expansion per year and the allocated budget is for those potential expansions.

This item also includes the relocation of existing London Hydro plant for accommodating new developments within the city limits. These relocations are required when items such as new proposed driveways and turn lanes for new developments are in conflict with the existing hydro plant. This budget item includes all costs associated with the relocation.

PRIMARY DRIVER:	Customer Value	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Econ. Dev.			
CUSTOMERS IMPACTED:	Various	2012	COST \$474,285	AREA/SCOPE
		2013	\$721,224	
		2014	\$346,785	
		2015	\$461,286	
		2016	\$683,035	
		2017	\$901,549	
		2018	\$350,000	
		2019	\$999,200	
		2020	\$1,300,800	
		2021	\$200,000	
OEB CAPITAL REPORTING		TOTAL COST ESTIMATE:		\$6,438,164
E1 - Developer Expansions and Relocations				
LH PROJECT DRIVER:	DEV	LH SECTION #	131	



CAPITAL PROJECT SUMMARY SHEET SYSTEM ACCESS

Project Number: 18E1
Project Name: Expansions and Relocations
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Developer Driven Distribution Circuit Expansions and Relocations

Risks to Completion & Mitigation Plan: Availability of resources to match timing required by the developer; mitigation plan is close coordination with the developer and securing resources (internal or contract) to ensure completion.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

Expansion for new developments within the city of London reinforces the distribution system and often represent opportunities to reconfigure infrastructure and increase automation, which enhances the reliability of the power supply to customers.

Safety

There are no direct implications to safety as a result of this project

Cyber-Security, Privacy

Not Applicable

Co-ordination, Interoperability

London Hydro responds to customers' requests for service or relocation of plant to support new developments.

Economic Development

Adequate supply capacity supports the economic development initiatives in the city of London and the intensification plans outlined in the City's London Plan.

Environmental Benefits

There are no direct environmental benefits associated with this project.

IMPACT TO O&M COSTS:

Not Applicable

ALTERNATIVES CONSIDERED:


Customer development added to London Hydro's service area must be supplied with service upon request.

LINK TO STRATEGIC PLAN:

6.2.1 - Emphasis on Reliability - Growth

CUSTOMER ENGAGEMENT:

This project is a direct result of customer applications to receive service in territories where London Hydro lacks the infrastructure. Customers make decisions on the type of the expansion (overhead or underground) required.





CAPITAL PROJECT SUMMARY SHEET SYSTEM ACCESS

Project Number: 18E1
Project Name: Expansions and Relocations
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Developer Driven Distribution Circuits Expansions and Relocations

Additional Information:

This project involves the installation and/or modification of electrical equipment that is used in supplying customers' installations. It also includes the work associated with upgrading existing installations.

The London Hydro Conditions of Service details how capital contributions are assessed for these installations.

At the present time, London Hydro is not aware of any specific expansions that will be required in 2018. The \$350,000 budget allocated for expansions and relocations has historically been the amount required to cover projects yet to be determined by developers.

Prepared By: Sunny Patel, P.Eng.
Distribution Engineer

Approved By: William Milroy, P.Eng.
V.P. Engineering
& Operations



CAPITAL PROJECT SUMMARY SHEET SYSTEM ACCESS

Project Number: 18E2
Project Name: Secondary Service Upgrades
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Residential Secondary Service Upgrades

Supporting Reference Material: London Hydro Conditions of Service (August 2017): Service Upgrades - Residential (Sec.2.2.4 & Appendix B)

Description: This budget item is for the replacement of existing overhead low voltage service conductors with larger capacity conductor. These connections are typically required when customers increase their electrical service demands. This budget item includes all costs associated with these basic service upgrades. For an upgrade to a service level higher than the basic connection, London Hydro may charge a reasonable fee for the portion of the upgrade beyond basic service.

PRIMARY DRIVER:	Customer Value	COST ESTIMATE - BY YEAR		
			COST	AREA/SCOPE
OTHER DRIVERS:	Econ. Dev.	2012	\$340,484	
		2013	\$314,266	
		2014	\$342,587	
		2015	\$395,395	
CUSTOMERS IMPACTED:	Various	2016	\$445,300	various
		2017	\$390,944	various
		2018	\$363,000	various
		2019	\$370,000	
OEB CAPITAL REPORTING:		2020	\$377,000	
E2 - Residential Secondary Service Upgrade		2021	\$384,000	
		TOTAL COST ESTIMATE:		\$3,722,976
LH PROJECT DRIVER:	DEV	LH SECTION #	131	



CAPITAL PROJECT SUMMARY SHEET SYSTEM ACCESS

Project Number: 18E2
Project Name: Secondary Service Upgrades
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Residential Secondary Service Upgrades

Risks to Completion & Mitigation Plan: Risks to completion are minimal. This project is part of a program that is successfully executed each year. The availability of resources (internal labour) is sufficient to complete this project.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability	Replacement of aged, undersized secondary services is supported by the Asset Sustainment Plan, which projects that assets reaching end of life should be replaced before affecting reliability or jeopardizing safety.
Safety	Upgrading substandard or inadequate installation of residential electric service contributes to an improvement in safety overall.
Cyber-Security, Privacy	Not Applicable
Co-ordination, Interoperability	Not Applicable
Economic Development	Improved service will contribute to the overall attractiveness of London as a place in which to live and do business.
Environmental Benefits	There are no direct environmental benefits associated with this work.

IMPACT TO O&M COSTS:
 Fewer outages may be experienced on the secondary system when older installations are upgraded, resulting in lower operating and maintenance costs.

ALTERNATIVES CONSIDERED:
 The Distribution System Code requires every LDC to provide basic electric service to all residential customers. These upgrades bring all installations up to current standards.

LINK TO STRATEGIC PLAN:
 6.2.1 - Emphasis on Reliability - Asset Management

CUSTOMER ENGAGEMENT:
 Upgrades to residential secondary services are initiated by customers; London Hydro upgrades the infrastructure in response to the customer request.





CAPITAL PROJECT SUMMARY SHEET SYSTEM ACCESS

Project Number: 18E2
Project Name: Secondary Service Upgrades
Start Date: Jan-18
In-Service Date: Dec-18


Project Title: Residential Secondary Service Upgrades

Additional Information:

This project involves the replacement of overhead low voltage electrical services to residential dwellings. There is no charge from London Hydro to the customers for these upgrades as they are part of London Hydro's basic connection for overhead residential customers as defined in the Distribution System Code.

These upgrades are initiated by customers that require an increase to their electrical service size. These requests may be due to issues such as the addition of new load in their home or due to an insurance company requiring the service to be upgraded to a minimal size and configuration.

From a budgeting perspective, the annual expenditures are estimated based on past history. A graph is provided below which illustrates the level of required expenditures within London Hydro's service territory between 2003 and 2017.



Prepared By: Sunny Patel, P.Eng.
Distribution Engineer

Approved By: William Milroy, P.Eng.
V.P. Engineering
& Operations



CAPITAL PROJECT SUMMARY SHEET SYSTEM ACCESS

Project Number: 18E3
Project Name: Residential Underground Servicing
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: New Single Family Residential Underground Distribution

Supporting Reference Material: CMHC Housing Market Outlook for London Reports (2016)
 CMHC Housing Forecast Data
 London Hydro Conditions of Service (August 2017)

Description: This item involves the installation of single family residential underground distribution systems to provide service as needed to developers.

It is noted that market conditions can create large fluctuations in expenditures from year to year. This item is solely dependent on market conditions. This section will contain several different projects of varying magnitude depending on customer requirements.

PRIMARY DRIVER:	Customer Value	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Econ. Dev.	2012	\$2,480,430	AREA/SCOPE
		2013	\$1,513,249	
		2014	\$2,881,332	
		2015	\$2,340,507	
CUSTOMERS IMPACTED:	Various	2016	\$2,896,629	
		2017	\$4,760,309	
		2018	\$3,325,000	
		2019	\$1,440,000	
OEB CAPITAL REPORTING:	E3 - Single Family Residential UG	2020	\$1,470,000	
		2021	\$1,494,000	
		TOTAL COST ESTIMATE:		\$24,601,456
LH PROJECT DRIVER:	DEV	LH SECTION #	142	



CAPITAL PROJECT SUMMARY SHEET SYSTEM ACCESS

Project Number: 18E3
Project Name: Residential Underground Servicing
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: New Single Family Residential Underground Distribution

Risks to Completion & Mitigation Plan: Resource availability to match customer's requested service date is the biggest risk to completion. Mitigation plan includes close co-ordination between engineering and operations staff to determine the projects that need to be completed by external resources and secure the external resources (contractor) well in advance of the requested project start date

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

With the economic growth expected in the City of London, new developments will be built. London Hydro utilizes these opportunities to expand the underground distribution system infrastructure, reconfigure the system, and increase automation, which will provide the customers with reliable power supply.

Safety

There is no direct implication to safety as a result of this project.

Cyber-Security, Privacy

Not applicable

Co-ordination, Interoperability

London Hydro responds to developer's requests for new services to support new developments in the City of London.

Economic Development

London is growing and new residential subdivisions will be built to accommodate the growth. London Hydro will ensure that adequate supply capacity supports the economic development initiatives in the City of London and its growth plans as outlined in the City's "The London Plan".

Environmental Benefits

There are no direct environmental benefits as a result of this project.

IMPACT TO O&M COSTS:

Not applicable

ALTERNATIVES CONSIDERED:

There is no alternative consideration; new houses added to London Hydro's with service area must be supplied with service upon request.

LINK TO STRATEGIC PLAN:

6.2.1 - Emphasis on Reliability - Growth

CUSTOMER ENGAGEMENT:

This project is a direct result of customer applications to install services in new subdivision developments where London Hydro lacks the underground infrastructure. This project is closely co-ordinated with the customer and developers.






CAPITAL PROJECT SUMMARY SHEET SYSTEM ACCESS

Project Number: 18E3
Project Name: Residential Underground Servicing
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: New Single Family Residential Underground Distribution




The graph to the left shows historical and projected spending in the residential underground budget section (including 2017 year-end forecast).

Forecast Summary London CMA Fall 2016									
	2013	2014	2015	2016(F)		2017(F)		2018(F)	
				(L)	(H)	(L)	(H)	(L)	(H)
New Home Market									
Starts:									
Single-Detached	1,153	1,116	1,046	1,300	1,400	1,250	1,450	1,100	1,350
Multiples	1,010	867	1,058	1,300	1,450	1,100	1,400	1,000	1,400
Starts - Total	2,163	1,983	2,104	2,600	2,900	2,300	2,800	2,050	2,700

The table to the left shows CMHC historical and 2018 projected single lot housing developments for London, trending slightly lower than 2017.

Figure 2.4: Forecasted Residential Unit Demand –Spatial Allocations (Built and Greenfield Area), 2011-2031



The map to the left shows vacant land inventory for residential growth.

Prepared By: Rick Stainthorpe CET, PMP
 Director Logistics & Operations Support

Approved By: William Milroy, P.Eng.
 V.P. Engineering & Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM ACCESS**

Project Number: 18E4
Project Name: Multi-Housing Servicing
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: New Multi-Housing Underground Distribution

Supporting Reference Material: CMHC Housing Market Outlook for London Reports (2016)
 CMHC Housing Forecast Data
 London Hydro Conditions of Service (August 2017)

Description: This item involves the installation of multi-housing (primarily townhouses and condominiums) underground distribution systems to provide service as needed to developers.

This item is solely dependent on market conditions. This section will contain several different projects of varying magnitude depending on customer requirements.

PRIMARY DRIVER:	Customer Value	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Econ. Dev.			
CUSTOMERS IMPACTED:	Various	2012	COST \$633,113	AREA/SCOPE
		2013	\$993,045	
		2014	\$831,460	
		2015	\$1,867,370	
		2016	\$1,226,389	
		2017	\$2,578,480	
		2018	\$2,043,000	
		2019	\$940,000	
		2020	\$955,000	
		2021	\$974,000	
OEB CAPITAL REPORTING:		TOTAL COST ESTIMATE: \$13,041,857		
E4 - Multi-Family Residential UG				
LH PROJECT DRIVER:	DEV	LH SECTION #	143	



CAPITAL PROJECT SUMMARY SHEET SYSTEM ACCESS

Project Number: 18E4
Project Name: Multi-Housing Servicing
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: New Multi-Housing Underground Distribution

Risks to Completion & Mitigation Plan: Resource availability to match customer's requested service date is the biggest risk to completion. Mitigation plan includes close co-ordination between engineering and operations staff to determine the projects that need to be completed by external resources and secure the external resources (contractor) well in advance of the requested project start date.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

With the economic growth expected in the City of London, new developments will be built. London Hydro utilizes these opportunities to expand the underground distribution system infrastructure, reconfigure the system, and increase automation, which will provide the customers with reliable power supply.

Safety

There is no direct implication to safety as a result of this project.

Cyber-Security, Privacy

Not applicable

Co-ordination, Interoperability

London Hydro responds to developer's requests for new services to support new developments in the City of London.

Economic Development

London is growing and new multi-housing projects will be developed; London Hydro will ensure that adequate supply capacity supports the economic development initiatives in the City of London and its growth plans as outlined in the City's "The London Plan" plan.

Environmental Benefits

There are no direct environmental benefits as a result of this project.

IMPACT TO O&M COSTS:

Not applicable

ALTERNATIVES CONSIDERED:

There is no alternative consideration; new multi-housing developments added to London Hydro's service area must be supplied service upon request.

LINK TO STRATEGIC PLAN:

6.2.1 - Emphasis on Reliability - Growth

CUSTOMER ENGAGEMENT:

This project is a direct result of customer applications to install services in new subdivision developments where London Hydro lacks the underground infrastructure. This project is closely co-ordinated with the customer and developers.





CAPITAL PROJECT SUMMARY SHEET SYSTEM ACCESS

Project Number: 18E4
Project Name: Multi-Housing Servicing
Start Date: Jan-18
In-Service Date: Dec-18


Project Title: New Multi-Housing Underground Distribution

Additional Information:

The "London Hydro Conditions of Service" document details how capital contributions are assessed for these installations.

From a budgeting perspective, the annual expenditures are estimated based on a number of factors including: past history, City of London development forecasts, market reviews, including Canada Mortgage and Housing Corporation, and customer inquiries. Examples of the various documents created and reviewed are shown. This information is updated each year and the forecasts and budgets are adjusted accordingly.

This collection of information is part of a larger library that is used in the preparation of the 25 year load forecast.



The graph to the left shows historical and projected spending in the multi-housing budget section (with a forecast for 2017 year-end)

Forecast Summary London CMA Fall 2016									
	2013	2014	2015	2016(F)		2017(F)		2018(F)	
				(L)	(H)	(L)	(H)	(L)	(H)
New Home Market									
Starts:									
Single-Detached	1,153	1,116	1,046	1,300	1,400	1,250	1,450	1,100	1,350
Multiples	1,010	867	1,058	1,300	1,450	1,100	1,400	1,000	1,400
Starts - Total	2,163	1,983	2,104	2,600	2,900	2,300	2,800	2,050	2,700

The table to the left shows CMHC historical and 2018 projected apartment and multi-housing start developments for London (available at the time of preparing this document).

Note that apartment developments are included in 18E5 Commercial Development budget section.

Prepared By: Rick Stainthorpe CET, PMP
 Director Logistics & Operations Support

Approved By: William Milroy, P.Eng.
 Chief Engineer & V.P. of Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM ACCESS**

Project Number: 18E5
Project Name: Commercial Distribution
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: New Commercial Distribution Services

Supporting Reference Material: London Hydro Conditions of Service (August 2017)
 City of London: The London Plan

Description: This item is for the installation of commercial overhead and underground distribution systems to provide service as required by customers. This item is solely based on market conditions.

 This budget is based on past historical expenditure patterns and past history, City of London development forecasts, market reviews, and customer inquiries.

PRIMARY DRIVER:	Customer Value	COST ESTIMATE - BY YEAR	
OTHER DRIVERS:	Econ. Dev.	2012	COST AREA/SCOPE
		2013	\$2,439,282
		2014	\$2,310,586
		2015	\$2,044,678
		2016	\$1,900,000
CUSTOMERS IMPACTED:	Various	2017	\$1,940,000
		2018	\$2,830,198
		2019	\$2,991,000
		2020	\$2,030,000
OEB CAPITAL REPORTING:		2021	\$2,070,000
			\$2,111,000
E5 - Commercial Distribution Services		TOTAL COST ESTIMATE:	\$22,666,744
LH PROJECT DRIVER:	DEV	LH SECTION #	144



CAPITAL PROJECT SUMMARY SHEET SYSTEM ACCESS

Project Number: 18E5
Project Name: Commercial Distribution
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: New Commercial Distribution Services

Risks to Completion & Mitigation Plan: Resource availability to match customers' requested service dates is the biggest risk to completion. Mitigation plan includes close co-ordination between engineering and operations staff to determine the projects that need to be completed by external resources and secure the external resources (contractor) well in advance of the requested project service date.


EVALUATION OF OUTCOMES:	
Efficiency, Customer Value, Reliability	With the economic growth expected in the City of London, new commercial and industrial projects will be developed requiring London Hydro to expand its overhead/underground infrastructure. This expansion will reinforce the distribution system and offers opportunities for reconfiguration and increased automation, which provide the customers with reliable power supply.
Safety	There is no direct implication to safety as a result of this project.
Cyber-Security, Privacy	Not applicable
Co-ordination, Interoperability	London Hydro co-ordinates with and responds to customer requests for new installations or modifying current installations.
Economic Development	Commercial and industrial customers play a big role in the economic growth of the City of London. London Hydro will ensure that adequate supply capacity supports the economic development initiatives in the City of London and its growth plans as outlined in the City's "The London Plan" plan.
Environmental Benefits	There are no direct environmental benefits as a result of this project.

IMPACT TO O&M COSTS:
Not applicable

ALTERNATIVES CONSIDERED:
There is no alternative consideration; new commercial and industrial customers added to London Hydro's service area must be supplied service upon request.

LINK TO STRATEGIC PLAN:
6.2.1 - Emphasis on Reliability - Growth

CUSTOMER ENGAGEMENT:
This project is a direct result of customer applications to install services in proposed commercial and industrial locations. This project is closely co-ordinated with the customer and for developers.





CAPITAL PROJECT SUMMARY SHEET

SYSTEM ACCESS

Project Number: 18E5
Project Name: Commercial Distribution
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: New Commercial Distribution Services

Additional Information:

This project involves the installation and/or modification of electrical equipment that is used to supply commercial (including apartments) and industrial customers' installations. It also includes the work associated with upgrading existing installations to meet the demands and requirements for the new loads.



The "London Hydro Conditions of Service" document outlines how capital contributions are calculated for these installations.

From a budgeting perspective, the annual expenditures are estimated based on a number of factors including past history, City of London development forecasts, market reviews, and customer inquiries. Examples of the various documents created and reviewed are shown. This information is updated each year and the forecasts and budgets are adjusted accordingly.

This collection of information is part of a larger library that is used in the preparation of the 25 year load forecast.

The graph to the right shows historical spending in New Commercial Servicing plus 2018 projection trending lower from the previous 2 years.

Commercial Servicing
Historical Spending and Future Years Projection



Prepared By:

Rick Stainthorpe CET, PMP
Director Logistics & Operations Support
William Milroy, P.Eng.
Chief Engineer & V.P. of Operations

Approved By:



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18F1
Project Name: Network Vaults/ Manholes /Transformer Replacements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Network Vaults / Manholes / Transformer Replacements

Supporting Reference Material: Summary Report of Structures Inventory: Maintenance Holes & Network Transformer Vaults (2012)
 Electric Distribution System Asset Sustainment Plan: 2015-2029 (2014)

Description: This item involves the design and installation of structural entities such as concrete manholes, vaults, roof slabs and steel vault grating, as well as replacement of network transformers, protectors and other electrical components associated with the structure replacement.

In 2012, London Hydro conducted an extensive inspection of the civil structures on its distribution system. London Hydro retained four engineering consultants to complete inspection and assess the condition of the below grade structures: network transformers vaults and maintenance holes. The total number of inspected structures consisted of 32 network transformer vaults and 553 maintenance holes. The report summarized the following items: inventory breakdown, structure condition ratings, inventory replacement cost value, recommendations for next inspection cycle and anticipated life expectancy.

Each year, we select manholes and vaults for inspection based on two criteria. One is the recommended re-inspect year by engineering consultants. In 2017, we also took structural rating into consideration as the 2nd criteria because a large number of structures were due for a default 5-year inspection. We postponed the inspection for those structures in good condition. In addition, for the never-inspected population, we selected the structures based on their age. By 2017, we have finished the inspection for all manholes and vaults which are 50 years old from this group. We have been replacing manholes and roof slabs since the report was published and we are all up to date with replacements to 2017.

In 2018, London Hydro will replace various maintenance hole (MH) roofslabs, repair walls to MHs and vaults, and rebuild at least one MH and a vault. London Hydro will also replace network transformers and their relays as part of 13.8 kV conversion that coordinates with the City of London's Dundas St. project.

PRIMARY DRIVER:	Safety	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Reliability			
	Efficiency	2012	COST	AREA/SCOPE
		2013	\$904,397	13 Projects
		2014	\$555,280	9 Projects
		2015	\$1,297,346	9 Projects
CUSTOMERS IMPACTED:	Various	2016	\$1,500,000	12 Projects
		2017	\$1,000,000	10 Projects
		2018	\$1,581,189	12 Projects
		2019	\$1,130,000	10 Projects
		2020	\$950,000	
		2021	\$1,050,000	
OEB CAPITAL REPORTING:		TOTAL COST ESTIMATE:		\$11,018,212
F1- Replacements of Network Vaults/ Manholes /Transformers				
LH PROJECT DRIVER:	SAF	LH SECTION #	141	



CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL

Project Number: 18F1
Project Name: Network Vaults/ Manholes /Transformer Replacements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Network Vaults / Maintenance Holes / Transformer Replacements

Risks to Completion & Mitigation Plan: Resource availability is the biggest risk to completion. Mitigation plan includes close co-ordination between engineering and operations staff to determine the projects that need to be completed by external resources and secure the external resources (contractor) well in advance of the project start date.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

The network system housed by the duct and maintenance hole system downtown is gradually being reshaped, with sections of cable abandoned due to reduced loads, and some structures are being retired when redundant. Network transformers are often refurbished when work takes place in the vault housing them, or completely eliminated according to customer needs identified by system planning.

Safety

Working safely in below grade structures is a high priority at London Hydro. This project ensures that operators continue to be able to use confined spaces to conduct work in a very safe manner.

Cyber-Security, Privacy

Not applicable

Co-ordination, Interoperability

Not applicable

Economic Development

Maintaining the infrastructure in the downtown core supports economic development as London Hydro continues to have the ability to support emerging loads in the most reliable way.

Environmental Benefits

Environmental benefits that are a direct result of this project include the elimination of segments of paper-insulated-lead-covered (PILC) cable which has become obsolete at London Hydro due to safety and environmental concerns.

IMPACT TO O&M COSTS:

A slight reduction in the operating and maintenance costs can be realized as a result of renewing this type of infrastructure.

ALTERNATIVES CONSIDERED:

London Hydro engineers do not have in-house expertise regarding civil work. Civil engineering consultants have been contracted to advise on the state of this infrastructure and have made recommendations that needed to be followed.

LINK TO STRATEGIC PLAN:

6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:

London Hydro engages City of London and businesses that are directly affected when such large scope reconstruction projects take place.





CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18F1
Project Name: Network Vaults/ Manholes /Transformer Replacements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Network Vaults / Manholes / Transformer Replacements

Additional Information:

London Hydro owns a large number of older maintenance holes (MH) and vaults, a few of them dating from the early 1920's. The condition assessment performed on this infrastructure several years ago indicates some structures are no longer safe to be in use. This item will resolve safety and reliability issues resulting from these inspections and in compliance with the Asset Sustainment Plan.

This budget item also includes the cost for replacing the electrical components associated with the structure replacements. Complete reconstruction is very complex and can reach exorbitant costs. Therefore, London Hydro's approach is to re-inspect civil structures as appropriate and perform remedy work, prioritizing replacements only if necessary and in co-ordination with other work on the network.

Based on London Hydro's 2017 structural audit, the following is proposed for 2018 construction:

- Roof slab replacements for MHs: 62, 269, 356, 501 and 558.
- Roof slab and wall repairs to MH 624 and Vault 084.
- Rebuild MHs 255 and 466. Options may include abandoning the structures or perform remedy work to delay replacement.
- Rebuild an existing vault or install a new vault.

Prepared By: Rodney Doyle, P.Eng.
Senior Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18F2
Project Name: Primary & Secondary Cable Replacement
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Primary & Secondary Cable Replacement

Supporting Reference Material: Electric Distribution System Asset Sustainment Plan: 2015-2029 (2014)

Description: London Hydro utilizes approximately 2,000 km of primary cable in its distribution system and 22 km of low-voltage main secondary cable in the downtown service territory. Although London Hydro is continuously assessing and replacing cables through capital projects, some cables fail unexpectedly and require immediate replacement. This project provides funding to replace such cables.

PRIMARY DRIVER:	Reliability	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Efficiency	2012	\$462,053	AREA/SCOPE
		2013	\$199,082	
		2014	\$384,081	
		2015	\$50,095	
CUSTOMERS IMPACTED:	Various	2016	\$147,985	
		2017	\$266,879	
		2018	\$130,000	
		2019	\$380,000	
		2020	\$380,000	
OEB CAPITAL REPORTING:		2021	\$380,000	
F2 - Replacement of Primary & Secondary Cables		TOTAL COST ESTIMATE:		\$2,780,175
LH PROJECT DRIVER:	REL	LH SECTION #		150



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18F2
Project Name: Primary & Secondary Cable Replacement
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Primary & Secondary Cable Replacement

Risks to Completion & Mitigation Plan: The risks to completion are minimal. An inventory of spare material is maintained based on historical experience and labour allocation is prioritized based on the operational risk associated with cable failures.

EVALUATION OF OUTCOMES:	
Efficiency, Customer Value, Reliability	Replacing failed cables ensures that customers receive a reliable supply of electricity.
Safety	Not Applicable
Cyber-Security, Privacy	Not Applicable
Co-ordination, Interoperability	Not Applicable
Economic Development	Not Applicable
Environmental Benefits	The failed cables being replaced often contain lead, while the new cables do not contain lead.

IMPACT TO O&M COSTS:
 There may be a slight reduction due to the reduced labour required to splice modern polymer-based cables.

ALTERNATIVES CONSIDERED:
 Do nothing, however this alternative was rejected due to the risk it would pose to supply reliability.

LINK TO STRATEGIC PLAN:
 Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:
 Customers were not directly engaged regarding this project, but recent surveys indicate customers value improvements to reliability (refer to DSP Section 3.2.4 Customer Engagement).






CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18F2
Project Name: Primary & Secondary Cable Replacement
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Primary & Secondary Cable Replacement

Additional Information:

A historical trend was used to estimate the required level funding for future failure replacements. The graph below illustrates that historical expenditures have been as high as \$500,000 and as low as \$100,000. For year 2018 we budgeted \$130,000.



Prepared By: Rodney Doyle, P.Eng.
Senior Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18F3
Project Name: Manhole Cable Rebuilds
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Manhole Cable Rebuilds

Supporting Reference Material: Electric Distribution System Asset Sustainment Plan: 2015-2029 (2014)

Description: London's downtown core is largely supplied from the 13.8 kV network system by an extensive low voltage network grid stepping down via network transformers. The network has traditionally been supplied by PILC (paper insulated lead cable). The primary cables and the low voltage network grid cables are installed in a common duct and manhole system that has become very crowded over the past fifty years. This item includes replacement of lead primary cables with new EPR insulated flat strap cables (lead free alternative cable), replacement of secondary cables, and reconfiguration of cables within crowded manholes that are difficult to work in. By doing this work we will eliminate unused cables, clear up hazards and make space available for future cable installations.

This budget will also cover the installation of cable protecting fuses in the mains of the low voltage grid to reduce the high fault energies released when a fault occurs. These fuse elements limit the fault energy and so, they decrease the probability of catastrophic failures substantially.

City of London will be conducting extensive civil infrastructure rehabilitation in the core starting in 2018: Dundas Street from Wellington Road to the Thames River (phased over 2 years), and York Street from Colborne Street to Thames River (phased over 3 years). In conjunction with the City of London's projects, London Hydro is replacing most of the civil structures (refer to Project 18C3). As a consequence, the associated electrical distribution within these structures will require replacement. The new electrical system will be converted to the 27.6 kV system, which will support the decommissioning of the 13.8 kV Nelson transformer station in 2020, and will help modernize our city's core electrical supply.

PRIMARY DRIVER:	Safety	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Reliability			
	Efficiency	2012	\$145,750	AREA/SCOPE
		2013	\$239,326	
		2014	\$142,461	
		2015	\$150,000	
CUSTOMERS IMPACTED:	No Direct Impact to Customers	2016	\$617,965	
		2017	\$128,535	
		2018	\$1,960,000	
		2019	\$200,000	
OEB CAPITAL REPORTING:		2020	\$200,000	
		2021	\$150,000	
F4 - Manhole Cable Rebuilds/Fuse Install		TOTAL COST ESTIMATE:		\$3,934,037
LH PROJECT DRIVER:	SAF	LH SECTION #		150



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18F3
Project Name: Manhole Cable Rebuilds
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Maintenance Hole Cable Rebuilds

Risks to Completion & Mitigation Plan: Resource availability is the biggest risk to completion. Mitigation plan includes close coordination between engineering and operations staff to determine the projects that need to be completed by external resources and securing the external resources (contractor) well in advance of the project start date.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

Cable rebuilds are usually planned when a civil component of the maintenance hole is in decent condition and cables need to be rebuilt to enable safe access and work. Old primary and secondary cables are replaced with new cables and also re-routed along the maintenance hole walls. New installations will increase overall system reliability. In addition, unused cables are eliminated making space for future installations.

Safety

Many of hazards associated with confined spaces are eliminated during cable rebuilds; also adding protection in the low voltage secondaries increases safety and prevents catastrophic failures.

Cyber-Security, Privacy

Not applicable

Co-ordination, Interoperability

Co-ordination with the City and customers is necessary when cable rebuild work happens to properly regulate the traffic and to co-ordinate outages.

Economic Development

Not Applicable

Environmental Benefits

Lead cable elimination is very beneficial to the environment as this material is a designated substance and has been found to be potentially harmful.

IMPACT TO O&M COSTS:

Maintenance costs may be reduced when cables in maintenance holes are rebuilt since, during outages, accessibility is improved, and, therefore, the work may take less time.

ALTERNATIVES CONSIDERED:


The possibility exists to leave these maintenance hole cables untouched but the complexity of the system can become problematic with the need to pull new cable in place of the old lead cable.

LINK TO STRATEGIC PLAN:

6.2.1 - Emphasis on Reliability - Asset Management

CUSTOMER ENGAGEMENT:

London Hydro engages City of London and businesses that are directly affected when such large scope reconstruction projects take place.





CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18F3
Project Name: Manhole Cable Rebuilds
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Manhole Cable Rebuilds



Additional Information:

The duct and maintenance hole system in the downtown contains approximately 40 km of primary 13.8 kV network and non-network feeder cables, in addition to approximately 25 km of copper secondary main feeder cables of the low voltage network grid. The system also houses 27.6 kV feeder cables. London Hydro has installed approximately 3,000 cable protecting fuses on the low voltage network grid system over the last several years to address the safety issues that are inherent in a closed loop system of this design.

The electrical work proposed for 2018 associated with maintenance hole rebuilds coordinates with London Hydro's replacement of aging civil structure under Project 18C3. It comes as a consequence of the City of London's reconstruction of:

- 1) Dundas Street, between the Thames River to Richmond Street and
- 2) York Street between Thames River to Talbot Street.

Below images show the before and after network circuit reconfiguration and voltage conversion within Phase 1 of the Dundas



The image on the left shows the current network system along Dundas Street (between Talbot to Richmond Streets).

The image on the right shows the reconfigured system serviced at 27.6 kV outlined in grey.

Prepared By: Rodney Doyle, P.Eng.
Senior Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18F4
Project Name: Explosion-Limiting MH Covers
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Explosion-Limiting Maintenance Cover Installations

Supporting Reference Material: Technical Risk Assessment - Manholes and Vaults, AESI, 2013

Description: Explosions in manholes are low probability/high impact events. The energy released in a major manhole explosion can launch an 80 kilogram cast-iron manhole cover 15 meters or more. Such explosions are typically caused by the ignition of combustible gases that accumulate in manholes due to overheating cable insulation, or non-London Hydro sources such as natural gas leaks and dumped chemicals. It may also be possible for high-current arcs to cause manhole explosions when combustible gases are not present.

To reduce the potential impact of manhole explosions, London Hydro will install manhole covers designed to provide a controlled release of pressure during explosions. By latching the manhole cover to the manhole frame and designing exhaust ports into the bottom of the cover, explosion-limiting manhole covers lift only a few inches during an explosion and create an air-dam that limits the force of the explosion.

PRIMARY DRIVER:	Safety	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:		2012	COST	AREA/SCOPE
		2013	\$0	
		2014	\$0	
		2015	\$0	
CUSTOMERS IMPACTED:		2016	\$100,000	80 Covers
		2017	\$100,000	80 Covers
		2018	\$25,000	20 Covers
		2019	\$25,000	20 Covers
		2020	\$25,000	20 Covers
OEB CAPITAL REPORTING:	F4 - Manhole Cable Rebuilds/Fuse Install	2021	\$25,000	20 Covers
		TOTAL COST ESTIMATE:		\$300,000
LH PROJECT DRIVER:	SAF	LH SECTION #	150	



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18F4
Project Name: Explosion-Limiting MH Covers
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Explosion-Limiting Maintenance Cover Installations

Risks to Completion & Mitigation Plan: The risks to completion for this project are minimal. A materials standard has been approved by the Standards department and minimal labour is required to install the new covers.


EVALUATION OF OUTCOMES:	
Efficiency, Customer Value, Reliability	Not Applicable
Safety	In the event of an explosion inside a manhole, public safety will be enhanced.
Cyber-Security, Privacy	Not Applicable
Co-ordination, Interoperability	Not Applicable
Economic Development	Not Applicable
Environmental Benefits	Not Applicable

IMPACT TO O&M COSTS:
Not Applicable

ALTERNATIVES CONSIDERED:
Do nothing, however this alternative was rejected because it does not enhance public safety.

LINK TO STRATEGIC PLAN:
6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT
Customers were not directly engaged regarding this project, but recent surveys indicate customers value improvements to safety (refer to DSP Section 3.2.4 Customer Engagement).





**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18F4
Project Name: Explosion-Limiting MH Covers
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Explosion-Limiting Maintenance Cover Installations

Additional Information:

Not Applicable

Prepared By: Hassan El-Madhoun, P.Eng.
Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18G1
Project Name: Pole Replacements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Replacement of Deteriorated Poles

Supporting Reference Material: Annual Sound and Bore Pole Test Results
 Electric Distribution System Asset Sustainment Plan: 2015-2030 (2014)

Description: Each year London Hydro tests an average of 3,000-4,000 London Hydro owned poles. During the years 2010-2016, London Hydro tested 22,432 unique poles of a population of almost 28,000 owned poles. As a result of these pole tests, an average of 37 poles are recommended for treatment or replacement each year. London Hydro has completed testing all poles identified as being in poor or fair condition, as well as all poles identified to have been in-service for over 20 years.

The testing involves performing a visual check of the pole and its equipment, hammering the pole to listen for hollow sounds (referred to as "sound test"), as well as obtaining a core material sample from the base of the pole when required.

This capital project is intended to cover the costs of replacing depreciated poles recommended for treatment/replacement - approximately 35-40 poles can be replaced with this budget.

PRIMARY DRIVER:	Safety	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Reliability	2012	\$354,585	various
		2013	\$267,987	various
		2014	\$250,393	various
		2015	\$482,980	various
CUSTOMERS IMPACTED:	Various	2016	\$347,053	various
		2017	\$555,988	various
		2018	\$300,000	various
		2019	\$300,000	various
		2020	\$300,000	various
		2021	\$300,000	various
OEB CAPITAL REPORTING:		TOTAL COST ESTIMATE: \$3,458,986		
G1 - Poles - Fully Depreciated or Fire Risk				
LH PROJECT DRIVER:	SAF	LH SECTION #	132	



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18G1
Project Name: Pole Replacements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Replacement of Deteriorated Poles

Risks to Completion & Mitigation Plan:

Risks to completion are minimal. This project is part of a program that is successfully executed each year. The availability of resources (internal and contractor) is sufficient to complete this project.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability	This project has a direct impact on safety and system reliability. Replacing depreciated poles will protect expensive assets (e.g., transformers and switches) supported by the poles as well as reducing the risk of experiencing power outages; hence, adding value to customers.
Safety	This program is aimed at replacing fully depreciated poles; fully depreciated poles are at high risk of failure especially during heavy storms conditions.
Cyber-Security, Privacy	Not applicable
Co-ordination, Interoperability	Limited co-ordination required; most poles are replaced like-for-like without affecting adjacent pole lines and/or projects. Transfer of third party attachments requires some co-ordination with the asset owner
Economic Development	Limited impact
Environmental Benefits	Not applicable

IMPACT TO O&M COSTS:

Depreciated poles typically support older distribution assets. Upgrading these poles will address these depreciated assets as well; hence, reducing unplanned outages and O&M costs.

ALTERNATIVES CONSIDERED:


Limited consideration; poles that are deemed fully depreciated via poles testing must be replaced immediately.

LINK TO STRATEGIC PLAN:

6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:

Limited engagement with customer is required as most poles are mostly replaced like-for-like.





CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18G1
Project Name: Pole Replacements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Replacement of Deteriorated Poles


Additional Information:

This project involves replacement of the deteriorating wooden poles that were tested and recommended for replacement.

London Hydro's system contains over 27,750 London Hydro owned poles. Approximately 98% of the poles on London Hydro's system are made of wood. In 1998, London Hydro introduced the pole testing program as part of our condition based assessment. All poles that are older than 20 years are tested every 5 years. Pole testing is done on an annual basis and capital budgeting are based on historical expenditure.

The graph below summarizes the condition of 22,432 poles tested between the years 2010-2016. Based on past testing results, about 1% of poles tested required immediate replacement - that is approximately an average of 30 poles per year. The graph test data also shows that there are poles that have been in-service for over 50 years (estimated time span for useful life) and not yet fully depreciated. Depending on the pole test results, these older poles are tested more frequently, as a due diligence, and to maximize their in-service lifespan. Standard CAN/CSA 22.3 requires all wood poles with 60% (or less) strength remaining to be reinforced or replaced.

Results for 22,432 poles tested between 2010-2016



Prepared By: Sunny Patel, P.Eng.
Distribution Engineer

Approved By: William Milroy, P.Eng.
V.P. Engineering & Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18G2
Project Name: Pole Fire Mitigation
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Replacement of Poles Susceptible to Pole Fires

Supporting Reference Material: Mitigating Pole Fires on London Hydro's Distribution System Report
 Electric Distribution System Asset Sustainment Plan: 2015-2029 (2014)

Description: Pole fires occur in specific older types of overhead construction with wood crossarms and pin type insulators. In these types of construction, leakage current tracks over deteriorated insulators and becomes concentrated in places where bolts and steel brackets interface with the wood resulting in fires.

Several years ago London Hydro instituted the pole fire replacement program and to-date has completed 86% of the projects.

The areas designated for replacement consist of the plant built more that 40 years ago and identified in the above reports as requiring replacement. This plant consists of outdated and aged materials and construction techniques that are more prone to failure than those used today.

This budget item will rebuild the pole line along Newbold Street between Hargrieve Road and Bradley Avenue. In addition, the pole line feeding Argyle Mall will be addressed by this item as the poles are currently susceptible to fires.

PRIMARY DRIVER:	Reliability	COST ESTIMATE - BY YEAR	
OTHER DRIVERS:	Safety	2012	COST
CUSTOMERS IMPACTED:	Various	2013	AREA/SCOPE
OEB CAPITAL REPORTING:		2014	
G1 - Poles - Fully Depreciated or Fire Risk		2015	
LH PROJECT DRIVER:	REL	2016	1 Street
		2017	2 Streets
		2018	2 Streets
		2019	
		2020	
		2021	
		TOTAL COST ESTIMATE:	\$2,023,959
		LH SECTION #	132



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18G2
Project Name: Pole Fire Mitigation
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Replacement of Poles Susceptible to Pole Fires

Risks to Completion & Mitigation Plan: Risk to completion is low. This project is part of a program that has been successfully executed each year since 2001. The availability of resources (internal and contract) is sufficient to complete this project


EVALUATION OF OUTCOMES:	
Efficiency, Customer Value, Reliability	By replacing poles that were identified as risk of pole fires, London Hydro reinforces the overhead system infrastructure providing increased reliability, while eliminating outdated plant and reconfiguring the distribution system to supply customers more efficiently.
Safety	Safety increases when configurations that are susceptible to fire are eliminated from the system by removing possible hazardous conditions associated with pole fires.
Cyber-Security, Privacy	Not applicable
Co-ordination, Interoperability	Minimum co-ordination is required to transfer 3rd party attachments owned by other utilities that share our poles.
Economic Development	Improved reliability will contribute to the overall attractiveness of London as a place in which to live and do business.
Environmental Benefits	Not applicable

IMPACT TO O&M COSTS:
Fewer outages may be experienced after eliminating pole fire risks, hence reducing overall operating and maintenance costs.

ALTERNATIVES CONSIDERED:
Deferring these pole replacements until they reach end of life is an option; however, risk factors affecting safety and reliability warrant their replacement as per this program's time line.

LINK TO STRATEGIC PLAN:
Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:
Customers were not directly contacted regarding this project but recent surveys indicate that customers value improvements in reliability (refer to DSP Section 3.2.4 Customer Engagement).






CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18G2
Project Name: Pole Fire Mitigation
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Replacement of Poles Susceptible to Pole Fires

Additional Information:

The general project area for this year is shown below with the streets planned for rebuild highlighted in yellow. The replacement program will continue on an annual basis until the time that all pole fire prone poles are replaced.



Prepared By: Sunny Patel, P.Eng.
Distribution Engineer

Approved By: William Milroy, P.Eng.
V.P. Engineering
& Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18G4
Project Name: 13.8 kV Overhead Conversion
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: 13.8 kV Overhead Conversions

Supporting Reference Material: London Downtown - 13.8 kV/27.6 kV Nelson TS - 5 Year Plan

Description: A multi-year voltage conversion of 13.8 kV loads to 27.6 kV will facilitate the removal of aging distribution infrastructure, as well as address the long term strategic plans described in the London Downtown - 13.8 kV/27.6 kV Nelson TS - 5 Year Plan report which recommends the conversion of the non-network downtown core to 27.6 kV supply.

The work proposed is the fourth year of a multi-year strategic plan to resupply non-network 13.8 kV loads at 27.6 kV supply. This work is also co-ordinated with other plans that will address the age and condition of the existing 13.8 kV Nelson TS supply from Hydro One.

Some of this work will require coordination with neighbouring 13.8 kV underground conversions under Project 18B10 and coordination with neighbouring 13.8 kV overhead feeder conversions under Project 18C2.

PRIMARY DRIVER:	Reliability	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Efficiency	2012		
	Customer Value	2013		
	Safety	2014		
	Econ. Dev.	2015	\$568,217	3 Streets
CUSTOMERS IMPACTED:	277	2016	\$402,216	4 Streets
		2017	\$241,520	4 Streets
		2018	\$243,000	5 Streets
		2019	\$445,000	
		2020	\$32,000	
		2021	\$0	
CAPITAL REPORTING:		TOTAL COST ESTIMATE:		
G5 - Overhead Voltage Conversion		\$1,931,953		
LH PROJECT DRIVER:	RNF	LH SECTION #	132	



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18G4
Project Name: 13.8 kV Overhead Conversion
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: 13.8 kV Overhead Conversions

Risks to Completion & Mitigation Plan:

Availability of resources to match timing with the overhead line and underground projects under Projects 18C2 and 18B10; mitigation plan is close co-ordination with these projects and securing resources (internal or contract) to ensure completion.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

In accordance with the multi-year plan to off load Nelson TS, the non-network load currently supplied at 13.8 kV will gradually be switched over to the much more reliable 27.6 kV system, with increased alternatives for backup during contingencies. Older infrastructure may also be addressed during voltage conversion of 13.8 kV overhead lateral circuits. This project is coordinated with conversion of related underground 13.8 kV loads.

Safety

In converting 13.8 kV overhead plant, any depreciated equipment such as poles will be eliminated from the system, increasing overall safety.

Cyber-Security, Privacy

Not applicable

Co-ordination, Interoperability

Not applicable

Economic Development

Improved reliability will contribute to overall attractiveness of London as a place in which to live and do business.

Environmental Benefits

There are no direct environmental benefits associated with this project; some material (e.g., wire) may be recycled in the process.

IMPACT TO O&M COSTS:

Annual operating and maintenance costs may be reduced due to possibly fewer outages on newer infrastructure.

ALTERNATIVES CONSIDERED:

Voltage conversion of all 13.8 kV non-network load must be completed by 2020. An evaluation of the challenges encountered in this project leaves as an option some temporary supply via step-down transformation at selected locations where load still needs to be supplied at 13.8 kV.

LINK TO STRATEGIC PLAN:

Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:

At the design stage, when changing the physical layout of the distribution system, property owners may be invited to discuss placement options of poles, potential new routing, etc.





CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL


Project Number: 18G4
Project Name: 13.8 kV Overhead Conversion
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: 13.8 kV Overhead Conversions

Additional Information:

The initiatives outlined in the London Downtown - 13.8 kV/27.6 kV Nelson TS - 5 Year Plan report require converting all 13.8 kV load by year 2020 when Hydro One eliminates the only transformer station supplying this voltage. Converting the downtown from 13.8 kV distribution, that had only one supply source, to the 27.6 kV distribution system, that has multiple supply sources, ensures a more reliable system to the city of London's core area and also aids in optimizing switching and load transferring amongst the other 27.6 kV stations.

Under this project it is anticipated that approximately 682 kW of 13.8 kV load will be converted to the 27.6 kV distribution system. The general project area is shown below with the streets planned for load conversion highlighted in yellow. Upon successful conversion of the planned load, it is anticipated there will be an additional 1,529 kW of 13.8 kV overhead load remaining to convert by year 2020.



Prepared By: Sunny Patel, P.Eng.
Distribution Engineer

Approved By: Bill Milroy, P.Eng.
V.P. Engineering & Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18G5
Project Name: 4.16 kV Overhead Conversion
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Sub 18 & 54 (Zone B), Sub 21 & 40 (Zone C) Overhead Conversion

Supporting Reference Material: 4.16 kV Aging Infrastructure System Planning Report (2011)
 4.16 kV Aging Infrastructure System Planning Report - Amendment (2015)
 Electric Distribution System Asset Sustainment Plan: 2015-2029 (2014)

Description: The initiatives outlined in the 4.16 kV Aging Infrastructure System Planning Report require rebuilding and converting all the 4.16 kV plant within three specified areas, identified as Zones A, B & C. In addition, the proposed rebuilds replace deteriorating infrastructure meeting the criteria outlined in the Asset Sustainment Plan Report.

Some of this work will require coordination with neighbouring 4.16 kV underground conversions under Project 18B9 and coordination with transformer vault replacements under Project 18B6.

PRIMARY DRIVER:	Reliability	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Efficiency			
	Safety	2012	\$800,399	AREA/SCOPE 1,583 kW Converted 1,238 kW Converted 1,864 kW Converted
	Customer Value	2013	\$2,968,682	
		2014	\$3,075,859	
		2015	\$2,550,000	
CUSTOMERS IMPACTED:	874	2016	\$2,525,000	
		2017	\$2,965,000	
		2018	\$2,360,000	
		2019	\$3,902,600	
		2020	\$4,501,200	
		2021	\$575,300	
OEB CAPITAL REPORTING:		TOTAL COST ESTIMATE:		\$26,224,040
G5 - Overhead Voltage Conversion				
LH PROJECT DRIVER:	REL	LH SECTION #		132



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18G5
Project Name: 4.16 kV Overhead Conversion
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Sub 18 & 54 (Zone B), Sub 21 & 40 (Zone C) Overhead Conversion

Risks to Completion & Mitigation Plan: Risk to completion is low. Resources must be secured to coordinate timing with underground conversion projects under Project 18B9. This project is part of a program that has been successfully executed in each of the past six years. The availability of resources (internal and contract) is sufficient to complete this project.

EVALUATION OF OUTCOMES:	
Efficiency, Customer Value, Reliability	Conversion by zones allows us to offload multiple substations that provide backup to each other during the same time interval, so decommissioning is possible without jeopardizing the ability to reliably supply these customers.
Safety	Removing high voltage overhead lines from residential backyards improves safety for both the public and staff. Safety of the public and staff is also improved throughout voltage conversion of loads supplied by old overhead plant since some in-service installations are substandard, such as positek fused transformers and open bus (see picture below).
Cyber-Security, Privacy	Not applicable
Co-ordination, Interoperability	Not applicable
Economic Development	Improved reliability will contribute to the overall attractiveness of London as a place in which to live and do business.
Environmental Benefits	Environmental benefits include elimination of deteriorated polemount transformers, which might have bushings that are leaking oil.

IMPACT TO O&M COSTS:
Fewer outages can be expected as the supply changes to the 27.6 kV new supply system, leading to a benefit for the annual operating and maintenance costs.

ALTERNATIVES CONSIDERED:
Some of the overhead infrastructure installed on the 4.16 kV is as old as 60 years and has passed end of life. Rebuilding it at 4.16 kV would deviate from the 4 kV plan of converting overhead areas by zone, which is necessary in order to offload old 4.16 kV substations that would otherwise also needed to be rebuilt.

LINK TO STRATEGIC PLAN:
Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:
Customers that maybe affected are usually contacted for discussion regarding pole relocations, anchoring, ground restoration, etc. Utility contact names are provided to customers who may have concerns.





CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL


Project Number: 18G5
Project Name: 4.16 kV Overhead Conversion
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Sub 18 & 54 (Zone B), Sub 21 & 40 (Zone C) Overhead Conversion

Additional Information:

The initiatives outlined in the 4.16 kV Aging Infrastructure System Planning Report require converting all 4.16 kV within Zone B, with Zone B being the service territories for Substations 18, 48, 54 and 92. In addition, the proposed voltage conversion area requires rebuilding and converting deteriorating underground systems and transformer vaults; thus, meeting the criteria outlined in the Asset Sustainment Plan Report. The deficiencies related to the age of the equipment may adversely impact the reliability of supply as well as public and employee safety since some of the transformers are located in confined spaces within the customer's building.

Under this project it is anticipated that approximately 1,864 kW of 4.16 kV load will be converted to the 27.6 kV distribution system. The general project area is shown below with the streets planned for load conversion highlighted in yellow.



Prepared By: Sunny Patel, P.Eng.
Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18G6, 18G7, 18G8
Project Name: Overhead System Safety Enhancements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Replacement of Automatic Splices, Replacement of Porcelain Insulators, and Installation of Copper-Clad Steel (CCS) Grounds

Supporting Reference Material: Reliability Incident Report - August 2013, Automatic Splice Failure; Kinectrics Reports: Forensic Analysis of Canadian Porcelain Line Post Insulators (2014); AESI Report: Copper-Clad Steel - An Alternative for Copper Grounding Conductors

Description:

Safety has been recognized to be at risk when energized conductors come in contact with the ground or other equipment. Multiple incidents of conductor breakage occurring in the past in an automatic splice suggests that these non-standard aerial connectors may not be very secure and, therefore, safe. Ongoing system audits identify locations of such splices. This budget item deals with ensuring the mechanical strength in the overhead lines by addressing risk from using these automatic splices.

Up to 2,300 porcelain line post insulators were replaced in 2016 and 2017, as a result of a system wide program of eliminating this equipment from many manufacturers, which over time has exhibited extremely poor reliability. Small probability/ high impact events on overbuild lines have had consequences, therefore, elimination of these porcelain insulators had priority. This budget item will deal with additional porcelain insulators installed on the 27.6 kV system across the city, as a measure of enhancing safety on the aerial system.

An additional element essential to the safe and reliable operation of a distribution system is proper grounding. The integrity of the grounding system has been compromised over time as grounding conductors have been stolen or cut at the base of the poles. The new standard copper-clad steel conductor adopted by London Hydro as replacement for traditional copper grounds makes it possible for crews to re-establish lasting system grounding connections. Several grids will be selected for grounding repairs in this budget item.

PRIMARY DRIVER:	Safety	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Reliability	2012	\$130,729	various grids
	Customer Value	2013	\$72,056	various grids
	Econ. Dev.	2014	\$772,265	various grids
CUSTOMERS IMPACTED:	Various	2015	\$950,000	various grids
		2016	\$880,000	various grids
		2017	\$281,258	various grids
		2018	\$380,000	various grids
		2019	\$660,000	
OEB CAPITAL REPORTING:	G2 - Arrestor/Insulator/Other	2020	\$285,000	
		2021	\$235,000	
		TOTAL COST ESTIMATE:		\$4,646,308
LH PROJECT DRIVER:	SAF	LH SECTION #		132



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18G6, 18G7, 18G8
Project Name: Overhead System Safety Enhancements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Replacement of Automatic Splices, Replacement of Porcelain Insulators, and Installation of Copper-Clad Steel (CCS) Grounds

Risks to Completion & Mitigation Plan: Availability of resources and co-ordination of the potential outages may slow down the progress of these projects; the mitigation plan is to closely monitor projects' progress and secure external resources (contractor), if required.


EVALUATION OF OUTCOMES:	
Efficiency, Customer Value, Reliability	A robust and secure overhead distribution system will improve the overall system operation by ensuring the reliable distribution of power to customers and by reducing outages that can be avoided.
Safety	Safety is the number one factor considered in addressing overhead system weaknesses since live contact can occur when equipment fails.
Cyber-Security, Privacy	Not applicable
Co-ordination, Interoperability	Certain practices and standards have been adopted by multiple utilities in the province through the exchange of performance standards, expertise and the availability of new certified equipment and technologies (e.g., copperclad conductor).
Economic Development	Improved reliability will contribute to the overall attractiveness of London as a place in which to live and do business.
Environmental Benefits	Not applicable

IMPACT TO O&M COSTS:
Fewer outages due to faults on the overhead system may result in a slight reduction in annual operating and maintenance costs.

ALTERNATIVES CONSIDERED:
Equipment at risk can remain in service but could compromise performance and increase safety risks.

LINK TO STRATEGIC PLAN:
6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:
Customers were not directly contacted regarding this project but recent surveys indicate customers value improvements in reliability (refer to DSP Section 3.2.4 Customer Engagement).





CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18G6, 18G7, 18G8
Project Name: Overhead System Safety Enhancements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Replacement of Automatic Splices, Replacement of Porcelain Insulators, and Installation of Copper-Clad Steel (CCS) Grounds

Additional Information:

Outages resulting from the failure of a component on the overhead system usually result in the interruption of power on an entire feeder, which supplies, on average, several thousand customers. While automated equipment exists in the system to detect and isolate the faulted segment, the necessary repairs can still create prolonged outages, depending on the damage. The following equipment types will be addressed in this budget item.

- 1) Certain risk can arise when an automated splice installed on a main 600 amp circuit fails and the conductor breaks inside the splice. Such splices have been identified on segments of circuits that run across a highway; those splices will be replaced with priority and, as more are identified, risks will be mitigated, prioritized by location or grid.
- 2) Failed porcelain insulators installed on the main circuits have proven to create dangerous situations wherein their breakage can cause separate phases to swing onto one another or make contact with the ground. All the remaining porcelain insulators installed on the 27.6 kV system are being located through audits and their replacement will be staged over the next several years.
- 3) Installation of the new standard copper-clad steel ground conductors will continue in the city where grounding at poles have been compromised. This budget item covers the installation of new grounds at approximately 240 poles.

Prepared By: Sunny Patel, P.Eng.
Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18G9
Project Name: Overhead System Safety Enhancements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Sectionalizing Switch Installations

Supporting Reference Material: Firon Industries Report re: TW28900S Switch Failure (August 2007)

Description: We have experienced reoccurring failures of in-line switches over the years that have caused large outages due to the mode of failure. This budget is for forensic analysis to determine patterns and modes of failure, and then replacement is planned across the system on the 27.6 kV lines to prevent larger scale outages.

PRIMARY DRIVER:	Safety	COST ESTIMATE - BY YEAR	
OTHER DRIVERS:	Reliability	2012	\$0
	Customer Value	2013	\$0
		2014	\$0
		2015	\$276
CUSTOMERS IMPACTED:	Various	2016	\$190,094
		2017	\$1,140
		2018	\$100,000
		2019	\$0
		2020	\$0
OEB CAPITAL REPORTING:	G9	2021	\$0
		TOTAL COST ESTIMATE: \$291,510	
LH PROJECT DRIVER:	SAF	LH SECTION #	132



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18G9
Project Name: Overhead System Safety Enhancements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Sectionalizing Switch Installations

Risks to Completion & Mitigation Plan: Availability of resources to complete replacements and repairs of various aerial system components can slow down these enhancements. At the same time, some planned outages can be necessary to complete work. Priority is given to projects that can impact safety and reliability the most according to locations, severity of faults and risks.

EVALUATION OF OUTCOMES:	
Efficiency, Customer Value, Reliability	A robust and secure overhead distribution system will improve the overall system operation by reliably distributing power to customers and reducing outages that can be avoided.
Safety	Safety is the number one factor considered in addressing overhead system weaknesses since live contact can occur due to the failure mode in some equipment.
Cyber-Security, Privacy	Not applicable
Co-ordination, Interoperability	Certain practices and standards have been adopted by multiple utilities in the province through exchange of performance standards, expertise and the availability of new certified equipment and technologies (i.e., copperclad conductor).
Economic Development	Improved reliability will contribute to overall attractiveness of London as a place to live and do business.
Environmental Benefits	No direct environmental benefits come from this project type.

IMPACT TO O&M COSTS:
Fewer outages due to faults on the overhead system may have a slight reduction in annual operating and maintenance costs

ALTERNATIVES CONSIDERED:
Equipment can remain in service at risk but performance could decrease and there are safety risks associated based on previous failure events.

LINK TO STRATEGIC PLAN:
Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:
Customers were not directly contacted regarding this project but recent surveys indicate customers value improvements in reliability (insert reference to Cust. Engagement section)



CAPITAL PROJECT SUMMARY SHEET SYSTEM RENEWAL

Project Number: 18G9
Project Name: Overhead System Safety Enhancements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Sectionalizing Switch Installations

Additional Information:

Outages resulting from failure of a component on the overhead system usually result in the interruption of power on an entire feeder, which supplies, on average, several thousand customers. While automated equipment exists in the system to detect and isolate the faulted segment, the necessary repairs can still create prolonged outages, depending on the damage. Overhead Line switches that have been determined to cause these types of outages will be identified and replaced under this section.

Prepared By: Sunny Patel, P.Eng.
Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18G10
Project Name: Overhead System Safety Enhancements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Pole Reinforcement

Supporting Reference Material: Monthly Report (03) Mar 2017

Description:

This is a new capital project intended to cover the costs of reinforcing certain poles supporting 27.6 kV overhead distribution systems. The selection was based on poles that have a three-phase pole-mounted transformer bank of larger than 100 kVA units. Upon field audits, a sample of the inspected poles were deemed to require additional support or total replacement in order to safely support the large transformer banks installed.

Each of the poles identified at potential risk will be investigated using non-linear guying analysis program (SpidaCalc) to identify any deficiencies in the existing installations. Up to 80 poles will be reinforced with additional guy wires or replaced as part of this budget item. This program may continue in the following years if system audits will reveal additional such locations that need to be addressed for safety.

PRIMARY DRIVER:	Safety	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Reliability			
	Customer Value	2012	COST	AREA/SCOPE
		2013		
		2014		
		2015		
CUSTOMERS IMPACTED:	Various	2016		
		2017		
		2018	\$75,000	various
		2019		
		2020		
OEB CAPITAL REPORTING:		2021		
	G10	TOTAL COST ESTIMATE:		\$75,000
LH PROJECT DRIVER:	SAF	LH SECTION #		132



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18G10
Project Name: Overhead System Safety Enhancements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Pole Reinforcement

Risks to Completion & Mitigation Plan: Availability of resources to complete replacements and repairs of various aerial system components can slow down these enhancements. At the same time, some planned outages can be necessary to complete work. Priority is given to projects that can impact safety and reliability the most according to locations, severity of faults and risks.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

A robust and secure overhead distribution system will improve the overall system operation by reliably distributing power to customers and reducing outages that can be avoided.

Safety

Safety is the number one factor considered in addressing overhead system weaknesses since live contact can occur due to the failure mode in some equipment.

Cyber-Security, Privacy

Not applicable

Co-ordination, Interoperability

Certain practices and standards have been adopted by multiple utilities in the province through exchange of performance standards, expertise and the availability of new certified equipment and technologies (i.e., copperclad conductor).

Economic Development

Improved reliability will contribute to overall attractiveness of London as a place to live and do business.

Environmental Benefits

No direct environmental benefits come from this project type.

IMPACT TO O&M COSTS:

Fewer outages due to faults on the overhead system may have a slight reduction in annual operating and maintenance costs

ALTERNATIVES CONSIDERED:

Equipment can remain in service at risk but performance could decrease and there are safety risks associated based on previous failure events.

LINK TO STRATEGIC PLAN:

Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:

Customers were not directly contacted regarding this project but recent surveys indicate customers value improvements in reliability (insert reference to Cust. Engagement section)





**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM RENEWAL**

Project Number: 18G10
Project Name: Overhead System Safety Enhancements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Pole Reinforcement

Additional Information:

Not applicable.

Prepared By: Sunny Patel, P.Eng.
Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM SERVICE**

Project Number: 18H1
Project Name: Recloser Installations
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Recloser Installation Program

Supporting Reference Material: Use of Reclosers on London Hydro's Electrical System, 1995
 2016 Quality of Supply Report
 Feeder Segmentation Proposals, 2015

Description: The installation of SCADA-controlled switches or reclosers reduces the duration and frequency of outages that customers experience. London Hydro has installed approximately 160 SCADA-controlled devices and plans to continue installing reclosers until all customers have been sectionalized into groups of approximately 1000.

In 2018, four new reclosers will be installed at locations that enhance system segmentation.

PRIMARY DRIVER:	Reliability	COST ESTIMATE - BY YEAR		
			COST	AREA/SCOPE
OTHER DRIVERS:	Efficiency	2012	\$173,246	3 Locations
		2013	\$184,026	3 Locations
		2014	\$236,482	5 Locations
		2015	\$195,000	4 Locations
CUSTOMERS IMPACTED:	Various	2016	\$133,200	3 Locations
		2017	\$230,135	5 Locations
		2018	\$245,000	4 Locations
		2019	\$195,000	3 Locations
OEB CAPITAL REPORTING:		2020	\$195,000	3 Locations
H1 - Recloser Installations		2021	\$195,000	3 Locations
		TOTAL COST ESTIMATE:		\$1,982,089
LH PROJECT DRIVER:	REL	LH SECTION #		250



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM SERVICE**

Project Number: 18H1
Project Name: Recloser Installations
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Recloser Installation Program

Risks to Completion & Mitigation Plan: The risks to completion are minimal. This project is part of a program that has been successfully executed in each of the past five years.

EVALUATION OF OUTCOMES:	
Efficiency, Customer Value, Reliability	By increasing the segmentation of the distribution system, customers will experience fewer faults and crews will be able to find faults more expediently.
Safety	Not Applicable
Cyber-Security, Privacy	The remote terminal units will be secured in accordance with London Hydro's cyber security practices.
Co-ordination, Interoperability	Not Applicable
Economic Development	Improved reliability will contribute to the overall attractiveness of London as a place to live and to conduct business.
Environmental Benefits	Not Applicable

IMPACT TO O&M COSTS:
Operating costs related to finding faults will be reduced, while maintenance costs will increase due to the additional assets.

ALTERNATIVES CONSIDERED:
Do nothing, however this alternative was rejected because it will not enhance the reliability of supply provided to customers.

LINK TO STRATEGIC PLAN:
Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:
Customers were not directly engaged regarding this project, but recent surveys indicate customers value improvements in reliability (refer to DSP Section 3.2.4 Customer Engagement).





**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM SERVICE**

Project Number: 18H1
Project Name: Recloser Installations
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Recloser Installation Program

Additional Information:

Not Applicable

Prepared By: Hassan El-Madhoun, P.Eng.
Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



CAPITAL PROJECT SUMMARY SHEET SYSTEM SERVICE

Project Number: 18H2, 18H3, 18H4, 18H5, 18H6
Project Name: SCADA Enhancements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: SCADA Enhancements

**Supporting
Reference
Material:**

Electric Distribution System Asset Sustainment Plan: 2015-2029 (2014)

Description:

A reliable SCADA system is required to efficiently monitor and control the distribution system. The SCADA projects will enhance components of the system that are either technically obsolete or inefficient to maintain. Specifically, the projects will increase the reliability of remote terminal units (RTUs), modernize communications protocols and mediums, secure data against cyber threats, and develop system intelligence tools that enable automation.

PRIMARY DRIVER:	Reliability	COST ESTIMATE - BY YEAR		
OTHER DRIVERS:	Efficiency	2012	COST	AREA/SCOPE
	Reliability	2013	\$150,000	
		2014	\$240,000	
		2015	\$360,000	
CUSTOMERS IMPACTED:		2016	\$300,000	
		2017	\$280,000	SCADA
		2018	\$289,424	SCADA
		2019	\$395,000	SCADA
		2020	\$280,000	
OEB CAPITAL REPORTING:		2021	\$300,000	
			\$280,000	
	H2 - RTU Replacement Program	TOTAL COST ESTIMATE:		\$2,874,424
LH PROJECT DRIVER:	REL	LH SECTION #	250	



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM SERVICE**

Project Number: 18H2, 18H3, 18H4, 18H5, 18H6
Project Name: SCADA Enhancements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: SCADA Enhancements

Risks to Completion & Mitigation Plan:

The risks to completion are minimal. Most of the SCADA enhancement projects are part of programs that have successfully been completed in previous years. Should project requirements exceed internal capabilities, working relationships with external resources have been established.

EVALUATION OF OUTCOMES:

Efficiency, Customer Value, Reliability

A modern, secure and robust SCADA system will the overall system operation by reliably providing real-time data to the Control Centre and historical data for engineering analysis.

Safety

Increased central visibility will improve London Hydro's ability to expeditiously respond to developing emergency situations.

Cyber-Security, Privacy

Modern equipment will enhance London Hydro's ability to prevent the electrical supply from being compromised by cyber attacks.

Co-ordination, Interoperability

The technology employed will be selected to adhere to industry standards and provide the functionality required for future initiatives.

Economic Development

Not Applicable

Environmental Benefits

Not Applicable

IMPACT TO O&M COSTS:

Proactively replacing components identified as being at risk of failure will reduce the operating and maintenance costs by reducing the number of emergency repairs.

ALTERNATIVES CONSIDERED:

An evaluation of different technologies (eg. wired vs. radio) and vendors was conducted to determine the optimal investments.

LINK TO STRATEGIC PLAN:

Section 6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:

Customers were not directly engaged regarding this project, but recent surveys indicate customers value improvements in reliability (refer to DSP Section 3.2.4 Customer Engagement).





CAPITAL PROJECT SUMMARY SHEET SYSTEM SERVICE

Project Number: 18H2, 18H3, 18H4, 18H5, 18H6
Project Name: SCADA Enhancements
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: SCADA Enhancements

Additional Information:

H2 - Serial communications equipment is used throughout London Hydro's SCADA system. However, serial technology has reached technical obsolescence and many of the equipment manufacturers no longer provide product support. To address this change in communications technology London Hydro has developed a program to replace end-of-life serial communications equipment with Ethernet-capable communications equipment. In addition to replacing end-of-life equipment, this program will also advance the decommissioning of leased-lines, thereby reducing monthly communications rental costs.

H3 - DART Remote Terminal Units (RTU) were installed to monitor and control 70 line switches and 2 substations. The RTUs employ circuit-board technology that is now obsolete, requiring expensive batch orders of circuit boards to maintain. Since the switches that the DARTs control have remaining useful lives in excess of 25 years, a replacement RTU was required. To address this challenge London Hydro identified a replacement RTU, developed by Virelec in conjunction with Power Stream and Oakville Hydro, that uses equipment already employed to monitor and control London Hydro's substations and FITs. The program, which began in 2012, will replace all DART RTUs by the end of 2020, assuming that their rate of failure does not increase.

H4 - London Hydro's SCADA system was designed during an era when cyber security was a relatively unknown term. As a result, many of the legacy devices employed by the SCADA system have limited security functions. To address this weakness London Hydro has developed a multi-faceted SCADA Cyber Security program. In coordination with the Asset Sustainment plan, legacy SCADA assets will be replaced with modern devices designed to ensure industrial security. To eliminate opportunities for remote security breaches, SCADA communications will be transferred from publicly accessible networks to privately controlled networks whenever it is economically efficient. This transfer will increase both the length of fibre optic cable employed for operational functions and the volume of traffic on London Hydro's licensed radio frequencies. Where it is economically inefficient to isolate SCADA communications from public networks, efforts will be directed toward enhanced network segregation and encryption.

H5 - For decades utilities have utilized faulted circuit indicators to efficiently locate and isolate faults. As a result of advancements in wireless technology, this information can now be provided to Control Room Operators in real-time using Line Status Sensors. In addition to fault indication, the line sensors also provide real-time load information. This new technology represents an economical alternative to installing SCADA-controlled switches to provide greater visibility into the distribution system.

H6 - FDIR refers to the use of SCADA assets to independently identify faults on the distribution system and reconfigure the system to minimize the number of customers impacted. This type of system automation has been trialed at many of London Hydro's peer utilities and it is now common place within the industry. To enable the application of FDIR to London Hydro's distribution will require a combination of investments in communications equipment and system connectivity intelligence.

Prepared By: Hassan El-Madhoun, P.Eng.
Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM SERVICE**

Project Number: 18H7
Project Name: Control Centre Modernization
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Control Centre Investment - Digital Wide Area Situational Awareness Display

Supporting Reference Material: Planning Study Report: Renovation of the Existing Distribution Control Room

Description: Since the Control Room was first constructed many technological changes have occurred; the introduction of personal computers, SCADA, flat screen displays, and most recently OMS. To accommodate these changes, the Control Room was altered as each change occurred. This has led to a sub-optimal configuration with respect to both technology integration and workflow processes. To optimize the operation of the Control Room, a consultant was hired to design an integrated layout. A series of investments will address the consultant's recommendations over the course of three to five years.

PRIMARY DRIVER:	Interoperability	COST ESTIMATE - BY YEAR		
			COST	AREA/SCOPE
OTHER DRIVERS:	Efficiency	2012	\$59,207	
	Reliability	2013	\$59,408	
		2014	\$72,357	
		2015	\$34,200	
CUSTOMERS IMPACTED:		2016	\$250,000	
		2017	\$250,000	
		2018	\$50,000	
		2019	\$50,000	
		2020	\$50,000	
OEB CAPITAL REPORTING:		2021	\$50,000	
	H3 - Misc. Control Room	TOTAL COST ESTIMATE:		\$925,172
LH PROJECT DRIVER:	REL	LH SECTION #		250



**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM SERVICE**

Project Number: 18H7
Project Name: Control Centre Modernization
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Control Centre Investment - Digital Wide Area Situational Awareness Display

Risks to Completion & Mitigation Plan: The risks to completion are minimal. Relationships have been established with a variety of vendors and significant efforts have been made to define precisely the requirements of a wide-area display. Should internal capabilities be insufficient, external expertise can be acquired.


EVALUATION OF OUTCOMES:	
Efficiency, Customer Value, Reliability	The investment will eliminate the requirement to maintain a record of the system configuration in multiple formats leading to labour efficiencies.
Safety	Enhancing the efficiency of work flows and the presentation of information in the Control Centre will increase the focus of Operators charged with safely managing the system.
Cyber-Security, Privacy	Not Applicable
Co-ordination, Interoperability	The digitalization of our schematic system maps will create a direct line with other corporate technologies (e.g. GIS).
Economic Development	Not Applicable
Environmental Benefits	Not Applicable

IMPACT TO O&M COSTS:
Not Applicable

ALTERNATIVES CONSIDERED:
Do nothing; however, this alternative was rejected because it does not address the inefficient organization of the Control Centre.

LINK TO STRATEGIC PLAN:
6.2.1 - Emphasis on Reliability

CUSTOMER ENGAGEMENT:
Customers were not directly engaged regarding this project, but recent surveys indicate customers value improvements in reliability (refer to DSP Section 3.2.4 Customer Engagement).





**CAPITAL PROJECT
SUMMARY SHEET
SYSTEM SERVICE**

Project Number: 18H7
Project Name: Control Centre Modernization
Start Date: Jan-18
In-Service Date: Dec-18

Project Title: Control Centre Investment - Digital Wide Area Situational Awareness Display

Additional Information:

Not Applicable

Prepared By: Hassan El-Madhoun, P.Eng.
Distribution Engineer

Approved By: William Milroy, P.Eng.
Chief Engineer &
V.P. of Operations